

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Sunday		Date : 03.10.21						
Probable Maximum Demand : 13800 MW					Probable Maximum Generation : 14955 MW					Rule Curve = 106.18 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 106.40 ft.		Today = 106.38 ft.		02.10.21 (Yesterday)				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.10.21 (Yesterday)		03.10.21 (Today)		02.10.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	290	310	310	126			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	320	340	340	40	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	399	412	412	13			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	145	185	150	185	25	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	260	310	305	305				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	8	45	68	68				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	93	102	102				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	20	22	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	50	51	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	17	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	58	105	100	100				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	208	281	250	290				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
28	Bramhangan: 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi: 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	50	100				
30	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	93	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	35	0	30	0				
Dhaka Zone Total					5717	5560	2772	3289	3544	3839	583	799	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	124	161	126	161	40	Unit 2 under overhauling		
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	115	115	115	65	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0				
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	19	25	25				
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	1	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	50	25	50				
41	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	105	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	304	305	300	300				
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	70	100	100	100				
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	87	34	102				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	17	5	15				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	8	86	90	90				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	71	110	110	110				
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100				
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	96	108	116	116				
Chattogram Zone Total					2442	2382	1183	1538	1451	1564	245	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	100	100	100	55	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23				
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	198	206	200	210				
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	320	300	330				
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	330	300	330				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	55	55	55				
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	45	45	187	Gas shortage		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	123	135	135				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	139	141	141				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	52	52	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.086	200	200	0	0	150	200				
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	82	114	100	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	87	87	95				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
**	Impoport (Tripura)	India		160	160	92	142	138	164				
Cumilla Zone Total					3094	3034	1836	2065	2172	2391	505	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	182	200	200	200	2	Gas Shortage		
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	0	0		Dependable cap. : 8MW		
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
80	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	168	199	170	200				
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	57	0	50	0				
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	3	24	22	22				
Myensingh Zone Total					717	708	548	560	581	559	2	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.10.21 (Yesterday)		03.10.21 (Today)		02.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	20	20		70	Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	47	50	50					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	51	31	60	60	35		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	7	160	160	160	170		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	145	150	150					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	316	316	316					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1338	1678	1767	207	97		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	395	400	410					
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	27	5	25			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	224	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	708	700	713	713					
Khulna Zone Total						2133	2129	1292	1451	1598	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	33	30	30					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	82	82	88		112	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	22	22					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	580	622	622		664	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BtC)	Gas/HSD (IPP)	2x75+1x70	220	220	181	224	220	220					
Barishal Zone Total						2046	2046	649	971	1086	1242	0	776	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	33	34	35					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	28	28					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	90	94					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	50					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	192	193	200	220	27		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	191	196	200	220					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	392	414	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	2	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	92	113	94	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2179	2179	1019	1432	1500	1681	408	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	81	81	81	4		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	87	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tatala 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
Rangpur Zone Total						685	605	168	194	202	194	4	359	
Sub-total: Plants in operation						21435	21021	10805.0	13178	13901	14955	1954	2446	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10347	12619	13311	14321					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	159	0	0	0	0	0	0	
Gross Total						22031	21180	10805	13178	13901	14955	1954	2446	
(C) Actual data of 02.10.21 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	13178.00	MW	at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12619.00	MW	at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13178.00	MW	at =	20:00 hrs	Dhaka	4562	4562	0	Mymensingh	1045	1045	0
04.	Minimum Generation (Generation end)	:	9633.00	MW	at =	8:00 hrs	Chattogram	1243	1243	0	Sylhet	536	536	0
05.	Day-peak Generation (Generation end)	:	10805.00	MW	at =	12:00 hrs	Khulna	1561	1561	0	Barisal	375	375	0
06.	Evening-peak Generation (Generation end)	:	13178.00	MW	at =	20:00 hrs	Rajshahi	1342	1342	0	Rangpur	723	723	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW	at =	20:00 hrs	Cumilla	1232	1232	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9621.00	MW	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	1950	MW			13.	Fuel cost :	(a) Gas = 161270194 Taka	(c) Coal = 62763258 Taka				
d)	Coal supply Limitation	:	4	MW				(b) Oil = 644360642 Taka	Total = 868394094 Taka					
b)	Low water level in Kapitai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2446	MW			14.	Maximum Temperature in Dhaka was :	35.2° C					
10.	Total Energy (Generation + India Import)	:	276.08	MKWh			15.	Export through East-West interconnections :						
	By Gas =	156.035	MKWh	By Oil =	82.465	MKWh		At evening peak-hour	:	-144	MW	at	20:00 hrs	
	By Coal =	13.607	MKWh	By Hydro =	3.410	MKWh		Maximum	:	-316	MW	at	22:00 hrs	
	By Solar=	0.709	MKWh					Energy	:	1.4335	MKWh			
11.	Total Gas Supplied	:	1177.78	MMCFD										
(D) Forecast of 03.10.21 (Today) Sunday :														
01.	Maximum Demand	:	13800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14955	MW	(Generation end)		05.	Total Generation	:	289.11	MKWh			
03.	Maximum Shortage	:	-1155	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.7° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation