

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 954667, 9551095

Month October, 2021		Day : Tuesday				Date : 05.10.21						
Probable Maximum Demand :		12500 MW		Probable Maximum Generation :		14860 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 106.35 ft		Today = 106.30 ft		Rule Curve = 106.36 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.10.21 (Yesterday)		05.10.21 (Today)		04.10.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	290	310	310	126		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	200	180	320	320	180	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	339	407	380	380	5		
11	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	12	90	0	0	120	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	1	0	335	335		Under Maintenance	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	270	310	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	50	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	16	55	68	68			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	43	54	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	2	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	75	105	100	100			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	100	150	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	155	280	250	280			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	69	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	95	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0			
Dhaka Zone Total			5717	5560	2524	3086	3677	3927	818	791		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	160	159	161	161	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	50	25	50			
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	289	303	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	43	100	100	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	100	100	100			
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	50	102			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21			
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	5	5	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	2	87	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	109	116	116	116			
Chattogram Zone Total			2442	2382	1233	1555	1507	1564	240	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	135	100	100	100	35	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	0	94	105	140			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	325	305	300	330			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	300	300	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	51	56	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	169	26	26	26	169	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	80	135	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	92	140	140			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	28	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	21	20	21			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	150	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	39	100	100	114			
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	42	94	95	96			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impoprt (Tripura)	India		160	160	118	138	138	164			
Cumilla Zone Total			3094	3034	1708	1854	2065	2302	467	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	141	108	160	150	94	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	0	0		Dependable cap. :8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	107	108	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	39	130	170	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	22	22	22			
Mymensingh Zone Total			717	709	341	390	541	509	94	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.10.21 (Yesterday)		05.10.21 (Today)		04.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	Under maint.
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50			
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	60	60	5		Gas Shortage
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	161	162	160	160	168		Gas Shortage
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	81	81			
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	30	145	190	200			
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	16	16			
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	341	341			
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	321	321	316	316			
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320			
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
Sylhet Zone Total			2422	2377	1603	1742	1809	1819	175	87		
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	260	260	250	300			
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	5	25			Line Overload
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	215	225	225			
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	85	105	105	105			
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload
**	Bheramara (HVDC) India		1000	1000	706	710	724	728				
Khulna Zone Total			2133	2129	1171	1300	1459	1623	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	33	33	33			
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	87	84	88		107	Arrival of GT2 HGPI experts delayed due to covid 19
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	17	17			
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	520	622	622		724	Line Overload
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150			
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	218	223	220	220			
Barisal Zone Total			2046	2046	742	915	1086	1240	0	831		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50			
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	33	34	35			
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	28	28			
121	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	94	90	94			
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	40			
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	0	50			
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	33			
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	156	138	200	220	82		Gas Shortage
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	179	195	200	220			
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	360	420	400	400			
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22			
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	2	52	52	52			
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	65	113	113	113			
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	75	113	94	113			
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0			
Rajshahi Zone Total			2179	2179	869	1391	1500	1681	463	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	79	81	82	6		Coal Shortage
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	82	113	113	113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0			
Rangpur Zone Total			685	605	163	192	202	195	6	359		
Sub-total: Plants in operation			21435	21021	10354.0	12425	13846	14860	2263	2483		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9864	11837	13190	14157				
(B) Plants under long term maintenance/ contract expired												
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
143	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired			596	159	0	0	0	0	0			
Gross Total			22031	21180	10354	12425	13846	14860	2263	2483		
(C) Actual data of 04.10.21 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	12425.00	MW, at = 19:30 hrs	12	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11837.00	MW, at = 19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12425.00	MW, at = 19:30 hrs	Dhaka	4550	4550	0	Mymensingh	724	724	0
04.	Minimum Generation (Generation end)	:	8660.00	MW, at = 7:00 hrs	Chattogram	1203	1203	0	Sylhet	461	461	0
05.	Day-peak Generation (Generation end)	:	10354.00	MW, at = 12:00 hrs	Khulna	1499	1499	0	Barisal	358	358	0
06.	Evening-peak Generation (Generation end)	:	12425.00	MW, at = 19:30 hrs	Rajshahi	1253	1253	0	Rangpur	607	607	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:30 hrs	Cumilla	1182	1182	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9235.00	MW, at = 5:00 hrs					Total	11837	11837	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 156906129 Taka	(c) Coal = 61661120 Taka				
a)	Gas limitation	:	2257	MW		(b) Oil = 528431341 Taka	Total = 746998589 Taka					
c)	Coal supply Limitation	:	6	MW								
b)	Low water level in Kaplai lake	:	0	MW								
c)	Plants under shut down/ maintenance	:	2483	MW	14.	Maximum Temperature in Dhaka was :	33.4° C					
10.	Total Energy (Generation + India Import)	:	254.88	MKWh	15.	Export through East-West interconnections :						
	By Gas = 151.395 MKWh			By Oil = 65.868 MKWh		At evening peak-hour :	-102	MW, at 19:30 hrs				
	By Coal = 13.341 MKWh			By Hydro = 3.775 MKWh		Maximum :	-176	MW, at 24:00				
	By Solar = 0.587 MKWh					Energy :	0.575	MKWh				
11.	Total Gas Supplied	:	1143.89	MMCFD								
(D) Forecast of 05.10.21 (Today) Tuesday :												
01.	Maximum Demand	:	12500	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14860	MW (Generation end)	05.	Total Generation	:	256.42	MKWh			
03.	Maximum Shortage	:	-2360	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.5° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation