

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Friday		Date : 08.10.21					
Probable Maximum Demand : 12200 MW					Probable Maximum Generation : 14300 MW					Rule Curve = 106.63 ft.		
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 106.00 ft.		Today = 105.88 ft.		07.10.21 (Yesterday)			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.10.21 (Yesterday)		08.10.21 (Today)		07.10.21 (Yesterday)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Gen. shortfall for Gas/water/Coal limitation MW	
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310	126		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	172	161	200	200	199	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	334	354	305	360	58		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	333	336	335	335			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	280	295	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	45	45	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	51	51	51	51			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	18	20	20			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x6.73	80	80	54	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	100	100			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	150	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	300	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	110	100	300			
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	21	100	50	100			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	93	94	94			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0			
Dhaka Zone Total					5717	5560	3166	3527	3453	3778	927	844
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	163	159	160	160	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	120	120	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
38	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	9	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	42	46	25	50			
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	97	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	305	305	300	300			
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	80	100	100			
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	17	17			
50	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	15	8	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	88	88	85	88			
52	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	54	54			
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	98	110	110	110			
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	102	116	116	116			
Chattogram Zone Total					2442	2382	1387	1535	1450	1557	240	415
56	a) Ashuganj TPP Unit-3	Gas (APSCCL)	1 x 150	150	135	70	70	70	70	65	Gas Shortage	
57	b) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
58	c) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	13	20	20	20			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	138	141	140	145			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	300	300	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	330	330			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	51	55	55			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	128	135	135			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	93	90	90	92			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	174	166	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x31.015+1x1.086	200	200	20	200	150	200			
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	100	100	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	47	96	95	96			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Impoort (Tripura)	India		160	160	118	120	138	164			
Cumilla Zone Total					3094	3034	1719	2041	2037	2216	515	0
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	132	143	160	160	59	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	85	115	115	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	180	199	170	200			
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	21	22	22	22			
Mymensingh Zone Total					717	622	485	501	541	519	59	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.10.21 (Yesterday)		08.10.21 (Today)		07.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	43	43	43		47			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	44	50	50					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	56	60	62	10		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	159	162	165	165	168		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	78	80	80					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	285	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	322	320	321					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	321	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total				2422	2377	1531	1579	1648	1651	180	74			
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	205	200	250	250					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	29	5	25			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	150	150	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	30	0	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	710	708	722	726					
Khulna Zone Total				2133	2129	1174	1322	1357	1571	0	0			
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	0	33	33	33					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	85	85	85		109	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	17	17					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	530	622	622		714	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	214	215	220	220					
Barishal Zone Total				2046	2046	716	915	1087	1237	0	823			
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	155	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	30	30	30					
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27					
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	90	94					
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	40					
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43					
123	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33					
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	126	125	190	190	95		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	159	130	180	180					
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	373	372	380	380					
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	30	16	52	52					
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	94	113					
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total				2179	2179	946	1369	1445	1578	476	0			
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	76	80	80	9		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	78	107	113	113					
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total				685	605	167	183	201	193	9	359			
Sub-total: Plants in operation				21435	20934	11291.0	12972	13219	14300	2406	2515			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10790	12396	12632	13665					
(B) Plants under long term maintenance/ contract expired														
140	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired				596	0	0	0	0	0					
Gross Total				22031	20934	11291	12972	13219	14300	2406	2515			
(C) Actual data of 07.10.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	12972.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12396.00	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12972.00	MW,	at =	19:00 hrs	Dhaka	4567	4567	0	Mymensingh	997	997	0
04.	Minimum Generation (Generation end)	:	9243.00	MW,	at =	7:00 hrs	Chattogram	1255	1255	0	Sylhet	510	510	0
05.	Day-peak Generation (Generation end)	:	11291.00	MW,	at =	12:00 hrs	Khulna	1565	1565	0	Barisal	323	323	0
06.	Evening-peak Generation (Generation end)	:	12972.00	MW,	at =	19:00 hrs	Rajshahi	1294	1294	0	Rangpur	668	668	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	1217	1217	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8955.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
	a) Gas limitation	:	2397	MW			13.	Fuel cost :	(a) Gas = 147882980 Taka	(c) Coal = 66258832 Taka				
	d) Coal supply Limitation	:	9	MW				(b) Oil = 736272656 Taka	Total = 950414468 Taka					
	b) Low water level in Kapta lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2515	MW			14.	Maximum Temperature in Dhaka was :	34.6° C					
10.	Total Energy (Generation + India Import)	:	275.10	MKWh			15.	Export through East-West interconnections :						
	By Gas = 147.230 MKWh							At evening peak-hour	: -320	MW,	at	19:00 hrs		
	By Coal = 14.392 MKWh							Maximum	: -622	MW,	at	21:00 hrs		
	By Solar= 0.638 MKWh							Energy	: 4.127	MKWh				
11.	Total Gas Supplied	:	1110.50	MMCFD										
(D) Forecast of 08.10.21 (Today) Friday :														
01.	Maximum Demand	:	12200	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14300	MW	(Generation end)		05.	Total Generation	:	258.73	MKWh			
03.	Maximum Shortage	:	-2100	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	32.6° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation