

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Thursday		Date : 07.10.21					
Probable Maximum Demand : 13000 MW					Probable Maximum Generation : 14551 MW					Rule Curve = 106.54 ft.		
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 106.16		Today = 106.00		Rule Curve = 106.54			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.10.21 (Yesterday)		07.10.21 (Today)		06.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310	126		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	188	178	215	215	182	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	398	412	412	14		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	338	335	335			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	260	280	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	45	45	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	43	51	50	55			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	21	19	20			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	31	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	25	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	30	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	38	105	100	100			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	100	150	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	296	300	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	158	100	300			
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurabati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	100	50	100			
30	Nababganj 55 MW PP (Southern power	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	93	94	94			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0			
Dhaka Zone Total					5717	5560	2782	3626	3573	3849	910	800
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	161	157	155	157	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	115	120	120	65	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	4	25	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	50	25	50			
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	305	304	300	300			
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	70	100	100	100			
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	17	17			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	13	8	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	9	87	85	88			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	108	116	116	116			
Chattogram Zone Total					2442	2382	1319	1555	1445	1554	245	415
55	a) Ashuganj TPP Unit-3	Gas (APSCCL)	1 x 150	150	135	80	70	80	80	65	Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	139	124	140	145			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	260	300	330			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	260	360	360			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	55	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	140	135	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	93	90	90	92			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	180	200	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	0	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	10	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	20	21			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x31.015+1x1.086	200	200	50	150	150	200			
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	100	100	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	97	95	96			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impoort (Tripura)	India		160	160	94	140	138	164			
Cumilla Zone Total					3094	3034	1728	1949	2080	2259	515	0
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	154	147	160	160	55	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	107	115	115			
80	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	146	190	170	200			
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0			
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	57	0	50	0			
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	2	22	22	22			
Myensingh Zone Total					717	622	499	488	541	519	55	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.10.21 (Yesterday)		07.10.21 (Today)		06.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	32	30	30		58			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	47	50	50					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	100	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	36	57	60	62	9		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	161	165	165	169		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	81	80	80					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	17	18	18	3		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	10	21	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	280	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	321	323	320	321					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1528	1502	1635	1638	181	85	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	215	215	250	300					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	5	25			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	135	215	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	709	712	724	728					
Khulna Zone Total						2133	2129	1164	1279	1359	1623	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	3	33	33					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	87	84	88		107	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	47	17	17					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	410	540	622	622		704	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BCL)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220					
Barishal Zone Total						2046	2046	753	916	1086	1240	0	811	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	37	30	30					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	90	94					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	50					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	34					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	121	125	200	220	95		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	169	200	220					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	329	414	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	6	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	94	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total						2179	2179	842	1321	1495	1676	476	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80	5		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	85	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabula 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
Rangpur Zone Total						685	605	169	193	201	193	5	359	
Sub-total: Plants in operation						21435	20934	10784.0	12829	13415	14551	2387	2470	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10364	12329	12892	13984					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0				
Gross Total						22031	20934	10784	12829	13415	14551	2387	2470	
(C) Actual data of 06.10.21 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	12829.00	MW,	at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12329.00	MW,	at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12829.00	MW,	at =	19:30 hrs	Dhaka	4358	4358	0	Mymensingh	996	996	0
04.	Minimum Generation (Generation end)	:	9024.00	MW,	at =	7:00 hrs	Chattogram	1334	1334	0	Sylhet	492	492	0
05.	Day-peak Generation (Generation end)	:	10784.00	MW,	at =	12:00 hrs	Khulna	1541	1541	0	Barishal	342	342	0
06.	Evening-peak Generation (Generation end)	:	12829.00	MW,	at =	19:30 hrs	Rajshahi	1323	1323	0	Rangpur	740	740	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:30 hrs	Cumilla	1203	1203	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9243.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	2382	MW			13.	Fuel cost :	(a) Gas = 145517971 Taka	(c) Coal = 64511114 Taka				
d)	Coal supply Limitation	:	5	MW				(b) Oil = 674803551 Taka	Total = 884832636 Taka					
b)	Low water level in Kapitai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2470	MW			14.	Maximum Temperature in Dhaka was :	32.5° C					
10.	Total Energy (Generation + India Import)	:	267.47	MKWh			15.	Export through East-West interconnections :						
	By Gas = 144.541 MKWh							At evening peak-hour	:	-408	MW,	at	19:30 hrs	
	By Coal = 13.990 MKWh							Maximum	:	-444	MW,	at	21:00 hrs	
	By Solar= 0.714 MKWh							Energy	:	2.7855	MKWh			
11.	Total Gas Supplied	:	1104.60	MMCFD										
(D) Forecast of 07.10.21 (Today) Thursday :														
01.	Maximum Demand	:	13000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14551	MW	(Generation end)		05.	Total Generation	:	271.03	MKWh			
03.	Maximum Shortage	:	-1551	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.9° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation