

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021				Day : Friday				Date : 15.10.21			
Probable Maximum Demand : 12900 MW				Probable Maximum Generation : 14700 MW				Rule Curve = 107.30 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 105.26 ft.				Today = 105.09 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.10.21 (Yesterday)		15.10.21 (Today)		14.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	250	250	280	126	Gas Shortage
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	191	232	200	250	128	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	340	360	360	72	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	260	260	280	280		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	285	270	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	50	50	50	50		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	21	21		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	50	51	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	47	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	60	105	105	105		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	149	149		
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	280	300	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	149	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	71	100	300		
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	98	50	100		
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	17	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	150	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0		
Dhaka Zone Total			5717	5560	3158	3355	3408	3758	856	858	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	159	163	160	160	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110	70	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	20	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	90	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	304	305	300	300		
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	55	80	100		
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	25	90	90		
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	51	102		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	16	18		
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			15	13	10	30		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	82	88	90	90		
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	70	100	100		
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	108	108	116	116		
Chattogram Zone Total			2442	2382	1353	1383	1474	1542	250	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	205	210	210	210		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	265	310	350		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	280	310	360		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	48	53	55	55		
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	110	112	135	137		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	50	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	87	90	90		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	0	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	50	200	150	200		
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	80	80	80		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	95	95	96		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impoport (Tripura)	India		160	160	140	132	138	164		
Cumilla Zone Total			3094	3034	1902	2063	2144	2313	505	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	120	136	150	160	66	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8		Dependable cap. : 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	115	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	186	192	170	190		
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0		
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	20	23	22	22		
Mymensingh Zone Total			717	622	437	495	538	516	66	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.10.21 (Yesterday)		15.10.21 (Today)		14.10.21 (Yesterday)		15.10.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW					
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43			26		GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42			49			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	47	42						
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163						
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11						
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	56	60	10				Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	153	158	160	172				Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	80						
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	208	220						
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	2				Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10						
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	16						
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	260	341						
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	322	320						
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320						
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0			100		Under project work	
Sylhet Zone Total					2422	2377	1786	1730	1846	1857	184	75		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0						
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	395	400						
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	28	0					Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0					Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	208	214	225						
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	70	50						
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	89	89	89						
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0					Line Overload	
**	Bheramara (HVDC)	India	1000	1000	699	704	718	718						
Khulna Zone Total					2133	2129	1391	1515	1482	1705	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110					Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	34	33						
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	62	65	65			129		Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	17						
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	570	622			674		Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	0						
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	214	216	220						
Barisal Zone Total					2046	2046	765	956	1067	1217	0	803		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0			71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0			100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50						
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200						
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	39	30			35			
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0						
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	90						
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	0			40			
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0			43			
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	17			35			
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0			210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	132	183	150			37		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	185	215	200			210			
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	407	388	400			400			
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22			22			
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11			11			
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	43	43	52			52			
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	113			113			
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	109	113			113			
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6			0			
Rajshahi Zone Total					2179	2179	1003	1414	1454	1599	418	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	78	80			7		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0			85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0			274		Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0						
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	105	113	113			113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0						
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8			0			
Rangpur Zone Total					685	605	192	191	201	193	7	359		
Sub-total: Plants in operation					21435	20934	11987.0	13102	13614	14700	2286	2510		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11437	12501	12989	14026				
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0						
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0						
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0					Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0						
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0					Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0					Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	0	0	0					Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0		
Gross Total					22031	20934	11987	13102	13614	14700	2286	2510		
(C) Actual data of 14.10.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	13102.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12501.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13102.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10473.00	MW,	at =	8:00 hrs	Dhaka	4554	4554	0	Mymensingh	1005	1005	0
05.	Day-peak Generation (Generation end)	:	11987.00	MW,	at =	12:00 hrs	Chattogram	1337	1337	0	Sylhet	573	573	0
06.	Evening-peak Generation (Generation end)	:	13102.00	MW,	at =	19:00 hrs	Khulna	1464	1464	0	Barisal	380	380	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	1214	1214	0	Rangpur	752	752	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9582.00	MW,	at =	5:00 hrs	Cumilla	1222	1222	0				
09.	Generation shortfall at evening peak due to :	:									Total	12501	12501	0
a)	Gas limitation	:	2279	MW			13.	Fuel cost :	(a) Gas = 158510845 Taka	(c) Coal = 70631081 Taka				
c)	Coal supply Limitation	:	7	MW				(b) Oil = 774742379 Taka	Total = 1003884305 Taka					
b)	Low water level in Kaplai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2510	MW			14.	Maximum Temperature in Dhaka was :	35.9° C					
10.	Total Energy (Generation + India Import)	:	287.72	MKWh			15.	Export through East-West interconnections :						
	By Gas = 153.363 MKWh							At evening peak-hour	: 78	MW,	at	19:00 hrs		
	By Coal = 15.403 MKWh							Maximum	: -370	MW,	at	4:00 hrs		
	By Solar= 0.699 MKWh							Energy	: 3.187	MKWh				
11.	Total Gas Supplied	:	1159.05	MMCFD										
(D) Forecast of 15.10.21 (Today) Friday :														
01.	Maximum Demand	:	12900	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14700	MW	(Generation end)		05.	Total Generation	:	283.28	MKWh			
03.	Maximum Shortage	:	-1800	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	36.9° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-