

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021				Day : Sunday				Date : 17.10.21			
Probable Maximum Demand : 13600 MW				Probable Maximum Generation : 14754 MW				Rule Curve = 107.50 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 104.97 ft.				Today = 104.82 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.10.21 (Yesterday)		17.10.21 (Today)		16.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	255	250	250	126	Gas Shortage
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	322	280	300	38	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	383	380	412	29	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	95	0	200	200	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	240	240	0	0		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	275	255	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	6	50	50	50		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	102	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	21	21		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	53	53	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	50	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	90	105	105		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	149	149		
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	280	298	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	131	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	20	100	300		
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	50	100		
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0		
Dhaka Zone Total				5717	5560	2564	3238	3428	3750	766	815
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	157	161	160	160	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	150	115	115	30	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	10	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	304	305	300	300		
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	100	80	100		
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90		
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	51	102		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	16	18		
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	9	6	10		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	32	90	90		
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	36	54		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	90	100	100		
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	94	108	116	116		
Chattogram Zone Total				2442	2382	1193	1509	1475	1545	210	415
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	110	110	110	25	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	207	208	210	210		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	300	335	350		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	280	320	350		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	50	55	55		
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	26	26	26	169	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	112	125	135	137		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	48	50	50		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	160	200	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	40	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	18	21	21		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	30	0	200		
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	80	80	80		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	87	95	96		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impoort (Tripura)	India		160	160	136	154	138	164		
Cumilla Zone Total				3094	3034	1736	1963	2037	2311	457	0
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	191	170	200	202	32	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	19	21	21		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	3	8	8	8		Dependable cap. : 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	115	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	163	190	190	190		
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0		
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0		
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	0	23	22	22		
Mymensingh Zone Total				717	622	476	525	608	558	32	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.10.21 (Yesterday)		17.10.21 (Today)		16.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	40	42	42		50			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	44	47	47					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	59	60	60	7		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	154	159	160	160	171		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	83	84	84					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	225					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	321	321	320	320					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1790	1777	1863	1868	180	77	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	360	400	400					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	11	0	33			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	215	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	25	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	704	705	718	718					
Khulna Zone Total						2133	2129	1219	1411	1498	1721	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	23	32	33	33					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	65	65	65		129	Gas Shortage		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	82	12	17	17					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	580	622	622		664	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	80	220	107	220					
Barishal Zone Total						2046	2046	665	944	954	1217	0	793	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	35					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	28	28					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	90	95					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	17	35					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	121	113	144	144	97		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	185	176	210	210	44		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	412	372	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	20	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	0	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	111	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total						2179	2179	974	1273	1486	1591	312	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	76	80	80	9		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabula 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total						685	605	198	189	201	193	9	359	
Sub-total: Plants in operation						21435	20934	10815.0	12829	13550	14754	1966	2459	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10364	12294	12985	14139					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0				
Gross Total						22031	20934	10815	12829	13550	14754	1966	2459	
(C) Actual data of 16.10.21 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	12829.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12294.00	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12829.00	MW,	at =	19:00 hrs	Dhaka	4441	4441	0	Mymensingh	1056	1056	0
04.	Minimum Generation (Generation end)	:	9068.00	MW,	at =	7:00 hrs	Chattogram	1315	1315	0	Sylhet	545	545	0
05.	Day-peak Generation (Generation end)	:	10815.00	MW,	at =	12:00 hrs	Khulna	1414	1414	0	Barishal	351	351	0
06.	Evening-peak Generation (Generation end)	:	12829.00	MW,	at =	19:00 hrs	Rajshahi	1319	1319	0	Rangpur	706	706	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	1147	1147	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9764.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	1957	MW			13.	Fuel cost :	(a) Gas = 162234732 Taka	(c) Coal = 69241896 Taka				
d)	Coal supply Limitation	:	9	MW					(b) Oil = 573598943 Taka	Total = 805075571 Taka				
b)	Low water level in Kapta lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2459	MW			14.	Maximum Temperature in Dhaka was :	35.5° C					
10.	Total Energy (Generation + India Import)	:	264.13	MKWh			15.	Export through East-West interconnections :						
	By Gas = 150.857 MKWh							At evening peak-hour	:	-162	MW,	at	19:00 hrs	
	By Coal = 15.075 MKWh							Maximum	:	-162	MW,	at	19:00 hrs	
	By Solar= 0.757 MKWh							Energy	:	0.794	MKWh			
11.	Total Gas Supplied	:	1192.60	MMCFD										
(D) Forecast of 17.10.21 (Today) Sunday :														
01.	Maximum Demand	:	13600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14754	MW	(Generation end)		05.	Total Generation	:	280.01	MKWh			
03.	Maximum Shortage	:	-1154	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.9° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation