

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Thursday		Date : 21.10.21					
Probable Maximum Demand : 12400 MW					Probable Maximum Generation : 14579 MW					Rule Curve = 107.90 ft.		
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 104.58 ft.		Today = 104.55 ft.		20.10.21 (Yesterday)			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.10.21 (Yesterday)		21.10.21 (Today)		20.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	105	105	105	85	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	126	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	94	104	100	100	4	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	308	333	300	330	27	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	397	390	390	15		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	130	154	155	160	56	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	270	255	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	30	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	50	50			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	40	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	14	21	21			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	45	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	8	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	52	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	195	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	80	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	25	35	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	25	74	104	104			
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	130	162	162	162			
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	21	0	30	0			
Dhaka Zone Total				5717	5560	2023	2543	3363	3668	392	801	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	166	145	130	130	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115	65	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	0	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	28	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	7	68	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	302	304	300	300			
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	80	100			
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
47	Dohazari-Kalashish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	102			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
50	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			16	31	5	15			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90			
52	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	36	54			
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	7	68	110	110			
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	7	116	116	116			
Chattogram Zone Total				2442	2382	847	1117	1446	1520	245	415	
56	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage	
57	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
58	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	140	146	146	146			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	290	285	330	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	325	280	330	330			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	26	26	26	169	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	98	135	135	135			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	86	138	138	138			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	120	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	22	21	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200			
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	58	96	100	100			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Impoort (Tripura)	India		160	160	114	136	138	164			
Cumilla Zone Total				3094	3034	1435	1701	2075	2301	487	0	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	166	173	160	170	29	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	21	21			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	8	8		Dependable cap. : 8MW	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	85	115	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	24	40	190	190			
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0			
87	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22			
Mymensingh Zone Total				717	622	345	320	568	526	29	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.10.21 (Yesterday)		21.10.21 (Today)		20.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	42		48		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	50	50				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	60	4		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	109	111	110	219		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	84	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	219	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	20	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	300	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	321	321				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
Sylhet Zone Total					2422	2377	1754	1771	1817	225	75	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	380	410	400				
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	120	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	52	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0			Line Overload	
**	Bheramara (HVDC) India		1000	1000	709	505	727	727				
Khulna Zone Total					2133	2129	1209	1102	1507	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	29	33				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65		129	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	42				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	310	490	622		754	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	224	225	220				
Barisal Zone Total					2046	633	826	1092	1242	0	883	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	95	90				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0				
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	17				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	126	117	126	93		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	199	186	210	34		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0				
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	401	398	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	25	70	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	9	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6				
Rajshahi Zone Total					2179	793	1020	1482	1582	298	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	5		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	70	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0				
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8				
Rangpur Zone Total					685	605	115	150	201	5	359	
Sub-total: Plants in operation					21435	20934	9154.0	10550	13551	14579	1681	2533
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8784	10124	13003	13990			
(B) Plants under long term maintenance/ contract expired												
142	Kaipoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0			
Gross Total					22031	20934	9154	10550	13551	14579	1681	2533
(C) Actual data of 20.10.21 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	10550.00	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10124.00	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10550.00	MW, at = 21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	8096.00	MW, at = 8:00 hrs	Dhaka	3748	3748	0	Myensingingh	732	732	0
05.	Day-peak Generation (Generation end)	:	9154.00	MW, at = 12:00 hrs	Chattogram	1153	1153	0	Sylhet	414	414	0
06.	Evening-peak Generation (Generation end)	:	10550.00	MW, at = 21:00 hrs	Khulna	1289	1289	0	Barishal	301	301	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 21:00 hrs	Rajshahi	978	978	0	Rangpur	516	516	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7981.00	MW, at = 5:00 hrs	Cumilla	993	993	0				
09.	Generation shortfall at evening peak due to :	:							Total	10124	10124	0
a)	Gas limitation	:	1676	MW	13.	Fuel cost :	(a) Gas = 156976530 Taka	(c) Coal = 52766856 Taka				
c)	Coal supply Limitation	:	5	MW		(b) Oil = 293727670 Taka	Total = 503471056 Taka					
b)	Low water level in Kaplai lake	:	0	MW								
c)	Plants under shut down/ maintenance	:	2533	MW	14.	Maximum Temperature in Dhaka was :	31.2° C					
10.	Total Energy (Generation + India Import)	:	223.84	MKWh	15.	Export through East-West interconnections :						
	By Gas = 149.127 MKWH			By Oil = 40.158 MKWh		At evening peak-hour	:	-120	MW, at	21:00 hrs		
	By Coal = 11.307 MKWH			By Hydro = 3.818 MKWh		Maximum	:	-264	MW, at	19:00 hrs		
	By Solar= 0.467 MKWH					Energy	:	0.341	MKWh			
11.	Total Gas Supplied	:	1187.67	MMCFD								
(D) Forecast of 21.10.21 (Today) Thursday :												
01.	Maximum Demand	:	12400	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14579	MW (Generation end)	05.	Total Generation	:	263.10	MKWh			
03.	Maximum Shortage	:	-2179	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.5° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation