

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Sunday		Date : 24.10.21						
Probable Maximum Demand : 12600 MW					Probable Maximum Generation : 14773 MW					Rule Curve = 108.20 ft.			
Water Level of Kaptai Lake at 06:00 AM					Today = 104.92 ft.		24.10.21 (Today)		23.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.10.21 (Yesterday)		24.10.21 (Today)		23.10.21 (Yesterday)		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening	Day	Evening			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	10			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	100	100	86		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	302	300	330	58		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	358	401	350	412		11		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	316	250	335				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	280	260	300	300				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	24	23	50	50				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	21	21				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x6.73	80	80	39	54	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x6.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x6.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	60	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	48	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	300	250	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	80	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
28	Bramhangan: 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi: 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	162	162				
34	Manikgonj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0				
Dhaka Zone Total					5717	5560	2065	3034	3493	3940	584	671	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	161	160	165	165		40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115	65		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25				
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	16	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	47	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	0	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	157	304	300	300				
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	20	80	100				
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	76	90	90				
47	Dohazari -Kalashish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	100				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	5	15				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	65	90	90				
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	36	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	108	110	110				
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	90	100	100				
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	17	116	116	116				
Chattogram Zone Total					2442	2382	673	1327	1481	1553	245	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	135	135	135	0		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	19	29	30	30				
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	141	143	145	145				
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0			Under Maint.	
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	335	330	330				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	55	55	55				
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	78	78	78	78	117		Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	50	125	130	130				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	138	138	138				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	139	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	2	7	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	20	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	21	18	18				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200				
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	62	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	58	96	100	100				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
**	Impoort (Tripura)	India		160	160	124	142	138	164				
Cumilla Zone Total					3094	3034	1193	1617	1815	2073	380	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	186	185	200	200	17		Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	8	8			Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	55	115	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	120	190	190				
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0				
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	9	22	22				
Mymensingh Zone Total					717	622	300	451	609	557	17	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.10.21 (Yesterday)		24.10.21 (Today)		23.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	41	41	50	50				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	60	65	4		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	110	110	110	110	220		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	84	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	275	341	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	323	321	321				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total						2422	2377	1765	1707	1817	1822	226	75
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	320	410	400	400				
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	33			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	120	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	86	105	105				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	714	715	727	727				
Khulna Zone Total						2133	2129	1154	1331	1507	1730	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	27	33	33				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	67	67	65	65		127	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	23	23	42	42				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	430	622	622		814	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyt BCL)	Gas/HSD (IPP)	2x75+1x70	220	220	222	223	220	220				
Barishal Zone Total						2046	2046	651	770	1092	1242	0	941
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	95	90	95				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43				
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	17	35				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	198	166	210	210	54		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	173	170	220	220				
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	422	308	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	100	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	110	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	827	1033	1576	1676	435	0
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	80	80	80	5		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	107	100	100				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
Rangpur Zone Total						685	605	82	187	188	180	5	359
Sub-total: Plants in operation						21435	20934	8710.0	11457	13578	14773	1892	2461
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8429	11088	13140	14297				
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0			
Gross Total						22031	20934	8710	11457	13578	14773	1892	2461
(C) Actual data of 23.10.21 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	11457.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11088.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	11457.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	7677.00	MW,	at =	7:00 hrs	Dhaka	4143	4143	0	Mymensingh	857	857
05.	Day-peak Generation (Generation end)	:	8710.00	MW,	at =	12:00 hrs	Chattogram	1281	1281	0	Sylhet	447	447
06.	Evening-peak Generation (Generation end)	:	11457.00	MW,	at =	19:00 hrs	Khulna	1283	1283	0	Barisal	310	310
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	1063	1063	0	Rangpur	646	646
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7831.00	MW,	at =	5:00 hrs	Cumilla	1058	1058	0			
09.	Generation shortfall at evening peak due to :	:									Total	11088	11088
a)	Gas limitation	:	1887	MW			13.	Fuel cost :	(a) Gas = 155813165 Taka	(c) Coal = 54216685 Taka			
c)	Coal supply Limitation	:	5	MW				(b) Oil = 294178941 Taka	Total = 504208790 Taka				
b)	Low water level in Kapta lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2461	MW			14.	Maximum Temperature in Dhaka was :	31.8° C				
10.	Total Energy (Generation + India Import)	:	217.08	MKWh			15.	Export through East-West interconnections :					
	By Gas = 143.040 MKWh			By Oil = 37.891 MKWh				At evening peak-hour	:	-96	MW,	at	19:00 hrs
	By Coal = 11.626 MKWh			By Hydro = 3.810 MKWh				Maximum	:	-100	MW,	at	21:00 hrs
	By Solar= 0.529 MKWh							Energy	:	0.2425	MKWh		
11.	Total Gas Supplied	:	1161.08	MMCFD									
(D) Forecast of 24.10.21 (Today) Sunday :													
01.	Maximum Demand	:	12600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14773	MW	(Generation end)		05.	Total Generation	:	238.74	MKWh		
03.	Maximum Shortage	:	-2173	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.8° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation