

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 24-Oct-21      |                                  |                 | Page -2             |                  |                      |                  |                              |
|-----------------------|----------------------------------|-----------------|---------------------|------------------|----------------------|------------------|------------------------------|
| No.                   | Name of the Power Stations       | Producer        | Installed Capacity  | Present Capacity | Peak Hour Generation | Energy Generated | Remarks                      |
|                       |                                  |                 | Unit No. X Capacity | MW               | MW                   | KWH              |                              |
| 1                     | Ghorasal Repowered CCPP-Unit-3   | PDB             | 1*260               | 260              | 0                    | 0                | Under maint.                 |
| 2                     | Ghorasal Repowered CCPP Unit-2   | PDB             | 1*210               | 180              | 0                    | 0                | Under maint.                 |
|                       | Ghorasal TPP Unit-5              | PDB             | 1*210               | 190              | 180                  | 4410000          |                              |
| 3                     | Ghorasal 365 MW CCPP Unit-7      | PDB             | 1*243+1*122         | 365              | 0                    | 0                | Under maint.                 |
|                       | Ghorasal 78.5 MW PP(RIMAX)       | ORPP            | 2*40                | 0                | 0                    | 0                | Contract Expired             |
| 4                     | Ghorasal 108MW PP (Regent)       | IPP             | 34*3.35             | 108              | 22                   | 526909           | Gas shortage                 |
| 5                     | Haripur GTTP                     | SBU, PDB        | 2*32                | 20               | 0                    | 0                | Under maint.                 |
| 6                     | Haripur 412 MW CCPP              | EGCB            | 1*273+1*139         | 412              | 342                  | 8783870          | Gas shortage                 |
| 7                     | Haripur 360MW CCPP(HPL)          | IPP             | 1*235+1*125         | 360              | 226                  | 6426000          | Gas shortage                 |
| 8                     | Meghnaghat 450 MW CCPP(MPL)      | IPP             | 2*150+1*150         | 450              | 250                  | 6163750          | Gas shortage                 |
| 9                     | Meghnaghat 100 MW(IEL)           | ORPP            | 12*8.9              | 0                | 0                    | 0                | Contract Expired             |
| 10                    | Meghnaghat CCPP(Summit)          | IPP             | 2*110+1*110         | 305              | 240                  | 6403869          | FGMO                         |
| 11                    | Madanganj 102 PP(Summit)         | ORPP            | 6*17                | 0                | 0                    | 0                | Contract Expired             |
| 12                    | Madanganj-55 MW PP(Summit)       | (IPP)           | 3*17.08+1*11.3      | 55               | 55                   | 1227782          |                              |
| 13                    | Keraniganj 100 MW PP (Powerpac)  | ORPP            | 8*13.45             | 100              | 22                   | 150013           | Engine problem               |
| 14                    | Narsinghā 22 MW PP (Doreen)      | SIPP, REB       | 8*2.90              | 22               | 17                   | 423396           | Engine problem               |
| 15                    | 210 MW Siddhirganj TPP           | PDB             | 1*210               | 115              | 0                    | 0                | Under maint.                 |
| 16                    | Siddhirganj 2*120 MW GTTP        | EGCB            | 2*105               | 210              | 0                    | 0                | Gas shortage                 |
| 17                    | Siddhirganj 100 PP(Dutch Bangla  | ORPP            | 12*8.9              | 0                | 0                    | 0                | Contract Expired             |
| 18                    | Siddhirganj 335 MW CCPP          | EGCB            | 1*217+1*118         | 335              | 300                  | 7353940          | Gas shortage                 |
| 19                    | Gagnagar 102 MW PP (Digital Po   | IPP             | 12*8.924            | 102              | 102                  | 1110096          |                              |
| 20                    | Katpali 52 MW PP (Sinha)         | IPP             | 7*7.9               | 0                | 0                    | 0                |                              |
| 21                    | Kamalaghat 54 MW PP(Banco En     | IPP             | 3*18                | 54               | 54                   | 1304280          |                              |
| 22                    | Kodda 150MW PP                   | BPDB-RPCL       | 9*17.06             | 149              | 32                   | 105600           | Low demand.                  |
| 23                    | Manikganj 55 MW PP (Northern)    | IPP             | 3*19.3              | 55               | 55                   | 769525           |                              |
| 24                    | Nababganj 55 MW PP (Southern)    | IPP             | 3*19.3              | 55               | 55                   | 913563           |                              |
| 25                    | Bosila 108MW RPCL                | IPP             | 12*8.775+1*3.5      | 0                | 0                    | 0                |                              |
| 26                    | Summit Power (Madhabdi-Ashuli    | SIPP,REB        | 3*3.67+4*8.73       | 80               | 54                   | 1253220          | Engine problem               |
| 27                    | Maona 33 MW PP(Summit)           | SIPP,REB        | 4*8.73              | 33               | 33                   | 799000           |                              |
| 28                    | Rupganj 33 MW PP(Summit)         | SIPP,REB        | 4*8.73              | 33               | 33                   | 830300           |                              |
| 29                    | Gazipur 52 MW PP                 | RPCL            | 6*8.9               | 52               | 33                   | 378720           | Low demand.                  |
| 30                    | Tongi 80 MW GTTP                 | PDB             | 1*105               | 105              | 0                    | 0                | Under maint.                 |
| 31                    | Kodda 300 MW PP Unit-2 (Summ     | IPP             | 18*17.076           | 300              | 300                  | 2875417          |                              |
| 32                    | Keraniganj 300 MW PP (APR)       | IPP             | 25*11.4             | 300              | 0                    | 0                | Reserve.                     |
| 33                    | Bramhangaoan 100 MW PP (Aggr     | IPP             | 100                 | 100              | 0                    | 0                | Reserve.                     |
| 34                    | Aurahat 100MW PP (Aggreko)       | IPP             | 0.85*23+0.95*91     | 100              | 0                    | 0                | Reserve.                     |
| 35                    | Kodda 149 MW PP Unit-1 (Summ     | IPP             | 149                 | 149              | 149                  | 2686176          |                              |
| 36                    | Gazipur 100 MW PP                | RPCL            | 100 MW              | 105              | 70                   | 141400           | Low demand.                  |
| 37                    | Meghnaghat 104 MW PP (OPCL)      | IPP             | 18.5*6              | 104              | 104                  | 1506240          |                              |
| 38                    | Manikganj 162MW PP(MPL)          | IPP             | 9*18                | 162              | 108                  | 1942560          | Engine problem               |
| 39                    | Spectra Solar Plant Ltd.         | IPP             | 35                  | 35               | 0                    | 203464           |                              |
| Dhaka area Total      |                                  |                 |                     | 5560             | 2836                 | 58961690         |                              |
| 40                    | Chattogram TPP-1                 | PDB             | 1*210               | 180              | 120                  | 2800000          | Gas shortage                 |
|                       | Chattogram TPP-2                 | PDB             | 1*210               | 180              | 0                    | 0                | Gas shortage                 |
| 41                    | Razzan 25 MW PP                  | IPP             | 3*8.9               | 25               | 17                   | 126567           | Low demand.                  |
| 42                    | Teknaf 20MW PP (Solartech)Teknaf | Solartech Energ | 20                  | 20               | 0                    | 136350           |                              |
| 43                    | Patenga 50MW PP (Baraka)         | IPP             | 8*6.98              | 50               | 50                   | 304800           |                              |
| 44                    | Kaptai Hydro. Unit-1,2,3,4, 5    | PDB             | 2*40+3*50           | 230              | 160                  | 3841982          | Low water level & #2 Under m |
| 45                    | Sikalbaha 225MW                  | PDB             | 1*150+1*175         | 225              | 0                    | 0                | Under maint.                 |
| 46                    | Sikalbaha Peaking GT             | PDB             | 1*150               | 150              | 0                    | 0                | Under maint.                 |
| 47                    | Sikalbaha 105 MW PP (Baraka St   | IPP             | 105 MW              | 105              | 105                  | 1397557          |                              |
| 48                    | Hathazari 100 MW peaking PP      | PDB             | 11*8.9              | 98               | 0                    | 0                | Under S/D                    |
| 49                    | Dohazari-Kalesh 100 MW Peakir    | PDB             | 6*17                | 102              | 67                   | 371657           |                              |
| 50                    | Juidah 100 MW Unit-1 (Acom)      | ORPP            | 8*13.45             | 100              | 50                   | 192480           | Low demand.                  |
| 51                    | Juidah 100 MW PP Unit-3 (Acom)   | IPP             | 0                   | 100              | 90                   | 1691520          | Engine problem               |
| 52                    | Barabkunda 22 MW PP (Regent)     | SIPP, PDB       | 8*2.90              | 22               | 18                   | 426192           | Engine problem               |
|                       | * Malancha, Cig, EP2 (United)    |                 | 5*8.73+3*9.34       | 0                | 4                    | 409440           |                              |
| 53                    | Chattogram 108 MW PP (ECPV)      | IPP             | 16*7                | 108              | 45                   | 83520            | Engine problem               |
| 54                    | Kaptai 7 MW Solar PP             | PDB             | 7.4 MW              | 7                | 0                    | 26281            |                              |
| 55                    | Anwara 300 MW PP (United)        | IPP             | 300 MW              | 300              | 305                  | 5294182          |                              |
| 56                    | Jodiac Power                     | IPP             | 3*18.55+1*3.6       | 54               | 18                   | 524086           | Engine problem               |
| 57                    | Karnaphuli Power Ltd.            | IPP             | 110                 | 110              | 110                  | 1330648          |                              |
| 58                    | Juidah unit-2 (Acom)             | IPP             | 8*13.6              | 100              | 100                  | 1821120          |                              |
| 59                    | Anilma Energy Ltd.               | IPP             | 6*21.2              | 116              | 116                  | 1702418          |                              |
| Chattogram area Total |                                  |                 |                     | 2382             | 1375                 | 22483800         |                              |
| 60                    | Ashuganj TPP Unit-3              | APSCL           | 1*150               | 135              | 80                   | 2837282          | Gas shortage                 |
|                       | Ashuganj TPP Unit-4              | APSCL           | 1*150               | 129              | 0                    | 0                | Gas shortage                 |
|                       | Ashuganj TPP Unit-5              | APSCL           | 1*150               | 134              | 0                    | 0                | Gas shortage                 |
| 61                    | Ashuganj 225 MW CCPP             | APSCL           | 1*142+1*75          | 221              | 179                  | 3624000          | ST under maint               |
| 62                    | Ashuganj 450 MW CCPP(North)      | APSCL           | 1*360               | 360              | 330                  | 7838500          | FGMO                         |
| 63                    | Ashuganj 450 MW CCPP(South)      | APSCL           | 1*360               | 360              | 250                  | 1329000          | Gas shortage                 |
| 64                    | Ashuganj 50 MW PP                | APSCL           | 14*3.968            | 45               | 29                   | 629352           | Engine problem               |
| 65                    | Ashuganj 55 MW PP (Precision)    | RPP             | 15*4                | 55               | 20                   | 1023360          | Gas shortage                 |
| 66                    | Ashuganj 195MW PP (APSCL-UN      | IPP             | 20*9.73+1*16        | 195              | 68                   | 2325090          | Gas shortage                 |
| 67                    | Ashuganj 51 MW PP (Midland)      | IPP             | 6*9.34              | 51               | 51                   | 1136542          |                              |
| 68                    | Ashuganj 150MW PP (Midland)      | IPP             | 23*7.015            | 150              | 122                  | 2229745          | Engine problem               |
| 69                    | Titas 50 MW Peaking PP           | PDB             | 6*8.92              | 52               | 0                    | 50560            | Reserve.                     |
| 70                    | Chandpur 150 MW CCPP             | PDB             | 1*106+1*57          | 163              | 0                    | 3429690          | Machine problem              |
| 71                    | Chandpur 200MW (Desh energy)     | IPP             | 0                   | 200              | 100                  | 1229280          | Low demand.                  |
| 72                    | Feni 22MW PP (Doreen)            | SIPP, PDB       | 8*2.90              | 22               | 19                   | 450180           |                              |
| 73                    | Feni 11 MW PP (Doreen)           | SIPP, REB       | 4*2.90              | 11               | 7                    | 144360           | Engine problem               |
| **                    | Imoport (Tripura)                | Imported power  | 0                   | 160              | 136                  | 2846400          |                              |
| 74                    | Jangalia 33MW PP (Summit)        | SIPP, PDB       | 4*8.73              | 33               | 25                   | 609900           | Engine problem               |
| 75                    | Jangalia 52 MW PP (Lakdanav)     | IPP             | 6*8.92              | 52               | 43                   | 230491           | Engine problem               |
| 76                    | Comilla 25 MW PP (Summit)        | SIPP, PDB       | 3*3.67+2*6.97       | 25               | 21                   | 586820           |                              |
| 77                    | Daudkandi 200 MW PP (B.Trac)     | IPP             | 154*1.4             | 200              | 0                    | 0                | Reserve.                     |
| 78                    | Feni Lanka Power                 | IPP             | 7*18.415+1*9.78     | 114              | 70                   | 205200           | Low demand.                  |
| 79                    | Chowmuhani 113 MW                | IPP             | 12*9.78+2*3.1       | 113              | 97                   | 1651440          | Engine problem               |
| 80                    | Bhairab 54.5 MW                  | IPP             | 3*18.2              | 54               | 17                   | 437400           | 33 KV feeder fault.          |
| Comilla Area Total    |                                  |                 |                     | 2034             | 1664                 | 34766592         |                              |
| 81                    | RPCL 210MW CCPP                  | IPP             | 4*35+1*70           | 202              | 153                  | 4038640          |                              |
| 82                    | Tangail 22 MW PP (Doreen)        | SIPP, PDB       | 8*2.90              | 22               | 22                   | 487152           |                              |
| 83                    | Jamalpur 95 MW PP(Powerpac)      | IPP             | 12*8.924            | 8                | 3                    | 183200           | Engine problem               |
| 84                    | Sarishabari 3 MW Solar Plant     | IPP             | 1*3                 | 3                | 0                    | 13350            |                              |
| 85                    | Mymensingh 200 MW PP (United     | IPP             | 200                 | 200              | 115                  | 655200           | Low demand.                  |
| 86                    | Jamalpur 115 MW PP (United)      | IPP             | 115 MW              | 115              | 115                  | 1888800          |                              |
| 87                    | Sultakhal 50 MW Solar PP         | IPP             | 50                  | 50               | 0                    | 340520           |                              |
| 88                    | Tangail Pali Power Gen 22 MW     | IPP             | 4*6.7               | 22               | 23                   | 105380           |                              |
| Mymensingh Area Total |                                  |                 |                     | 622              | 431                  | 7692222          |                              |
| 89                    | Fenchugonj CCPP Phase-1          | PDB             | 2*32+1*33           | 70               | 43                   | 1023000          | Machine problem              |
| 90                    | Fenchugonj CCPP Phase-2          | PDB             | 2*35+1*35           | 90               | 42                   | 1010760          | Machine problem              |
| 91                    | Kushiara 163 MW CCPP (KP)        | IPP             | 1*109+1*54          | 163              | 163                  | 3547227          |                              |
| 92                    | Shahjibazar 330 MW CCPP          | PDB             | 3*110               | 330              | 111                  | 2484000          | GT-2 under maint             |
| 93                    | Fenchugonj 51 MW PP (Barakati    | RPP             | 18*2.90             | 51               | 44                   | 910200           | Engine problem               |
| 94                    | Fenchugonj 44MW PP (Energyprima  | RPP             | 12*3.3+3*2          | 0                | 0                    | 0                | Contract Expired             |
| 95                    | Shahjibazar GTTP Unit- 8 & 9     | PDB             | 2*35                | 66               | 62                   | 1419456          |                              |
| 96                    | Shahjibazar 86MW PP (Shahjibaz   | RPP             | 32*2.90             | 86               | 80                   | 1646400          |                              |
| 97                    | Shahjibazar 100 MW GTTP          | PDB             | 1*100               | 100              | 0                    | 0                | Under Shut down              |
| 98                    | Sylhet 225 MW CCPP               | PDB             | 1*142+1*89          | 231              | 217                  | 5077750          |                              |
| 99                    | Sylhet 20 MW GTTP                | PDB             | 1*20                | 20               | 18                   | 283900           |                              |
|                       | Sylhet 50MW PP (EPL)             | RPP             | 27*2                | 0                | 0                    | 0                | Contract Expired             |
| 100                   | Shahjahanulla 25 MW PP           | SIPP, REB       | 3*9.34              | 25               | 24                   | 576600           |                              |
| 101                   | Bibiana-II 341 MW CCPP (Summ     | IPP             | 1*222+1*119         | 341              | 290                  | 7133000          | FGMO                         |
| 102                   | Bibiyana-III 400 MW CCPP         | PDB             | 400 MW              | 400              | 323                  | 7759000          | Gas shortage                 |
| 103                   | Sylhet 10MW PP (Desh)            | RPP             | 6*1.95              | 10               | 10                   | 250200           |                              |
| 104                   | Bibiyana South 400 MW            | PDB             | 400 MW              | 383              | 320                  | 7661600          | Gas shortage                 |
| Sylhet Area Total     |                                  |                 |                     | 2377             | 1758                 | 49885737         |                              |
| 105                   | Bheramara GTTP Unit-3            | PDB             | 1*20                | 16               | 0                    | 0                | Reserve.                     |
| **                    | Bheramara (HVDC )                | Imported power  | 2*500               | 1000             | 715                  | 17275636         |                              |
| 106                   | Khulna 115 PP MW (KPCL-2)        | ORPP            | 7*17                | 0                | 0                    | 0                | Contract Expired             |
| 107                   | Faridpur 50 MW Peaking PP        | PDB             | 8*6.89              | 54               | 0                    | 0                | Reserve.                     |
| 108                   | Khulna 225 MW CCPP               | NWPGCL          | 1*150+1*75          | 230              | 120                  | 3014400          | Low demand.                  |
| 109                   | Copalganj 100 MW Peaking PP      | IPP             | 16*6.89             | 109              | 0                    | 0                |                              |
| 110                   | Bheramara 410 MW CCPP            | NWPGCL          | 1*278+1*132         | 410              | 410                  | 9054720          |                              |
|                       | Noapara 40 MW PP (Khanjahan A    | ORPP            | 5*8.5               | 0                | 0                    | 0                | Contract Expired             |
| 111                   | Noapara 100 MW PP (Bangla Tre    | IPP             | 70*1.4              | 100              | 0                    | 0                | Reserve.                     |
| 112                   | Rupsha 105 MW PP (Orion rupsh    | IPP             | 6*18.445            | 105              | 70                   | 568320           | Engine problem               |
| 113                   | Madhumati 100 MW PP              | NWPGCL          | 100 MW              | 105              | 0                    | 0                | Reserve.                     |
| Khulna Area Total     |                                  |                 |                     | 2129             | 1315                 | 29913076         |                              |
| 114                   | Barisal 110 MW PP (Summit )      | IPP             | 7*17.076            | 110              | 0                    | 0                | Line O/L                     |
| 115                   | Bhola 33 MW PP (Venture)         | RPP             | 1*34.50             | 33               | 27                   | 516513           | Engine problem               |
| 116                   | Bhola 225 MW CCPP                | PDB             | 2*63+1*68           | 194              | 62                   | 1594000          | Machine problem              |
| 117                   | Bhola 95 MW PP (Aggreko)         | ORPP            | 96*1.10             | 95               | 17                   | 421594           | Gas shortage                 |
| 118                   | Payra 1320 MW                    | BCPCL           | 2*622               | 1244             | 500                  | 9539100          | Line O/L                     |
| 119                   | Bhola Nutan Biddut BD LTD        | IPP             | 220                 | 220              | 206                  | 482749           | Gas shortage                 |
| 120                   | United Payra Power Ltd.          | IPP             | 8*18.5+1*9.5        | 150              | 17                   | 26000            | Line O/L                     |
| Barisal Area Total    |                                  |                 |                     | 2046             | 829                  | 12625956         |                              |
| 121                   | Baghabari 71 MW GTTP             | PDB             | 1*71                | 71               | 0                    | 0                | Gas shortage                 |
|                       | Baghabari 100 MW GTTP            | PDB             | 1*100               | 100              | 0                    | 0                | Gas shortage                 |
| 122                   | Baghabari 50 MW Peaking PP       | PDB             | 6*8.9               | 52               | 30                   | 75072            |                              |
| 123                   | Bera 70 MW Peaking PP            | PDB             | 9*8.29              | 71               | 0                    | 10272            | Reserve.                     |
| 124                   | Ammura 50 MW PP(Sinna)           | ORPP            | 7*7.79              | 50               | 27                   | 51130            | Fuel shortage                |
| 125                   | Katakhal 50 MW PP (Northern)     | ORPP            | 6*8.9               | 50               | 0                    | 74364            | Reserve.                     |
| 126                   | Katakhal 50 MW Peaking PP        | PDB             | 6*8.7               | 50               | 0                    | 44117            | Reserve.                     |
| 127                   | Sirajgonj Unit-1 225MW           | NWPGCL          | 1*150+1*75          | 210              | 0                    | 0                | Gas shortage                 |
| 12                    |                                  |                 |                     |                  |                      |                  |                              |