

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Wednesday				Date : 27.10.21					
Probable Maximum Demand : 12000 MW					Probable Maximum Generation : 14687 MW					Rule Curve = 108.50 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 104.69 ft.					Today = 104.53 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.10.21 (Yesterday)		27.10.21 (Today)		26.10.21 (Yesterday)		27.10.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	10				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			Under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	21	22	22	22	86		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	214	207	250	280	153		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	400	400	400		12			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	336	232	232					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	275	255	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	45	55	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	37	40	40					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	102	102	102					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	19	19	20					
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	53	54	55	55					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	33	33	33	33					
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	25	33	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	25	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	149	149					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	35	54	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	163	298	250	300					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	134	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300					
28	Bramhangan: 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	104	104					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	162	162					
34	Manikgonj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	29	0	30	0					
Dhaka Zone Total					5717	5560	2572	2972	3385	3686	679	672		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	158	156	154	154	40		Unit 2 under overhauling		
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	115	120	120	65		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25					
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	15	0	20	0					
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	14	50	50	50					
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	104	105	105	105					
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting for purchase committee approval		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	303	305	300	300					
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	100	80	100					
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90					
47	Dohazari-Kalashish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	100					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
50	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	2	5	5					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	67	90	90					
52	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	36	54					
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	112	110	110	110					
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100					
55	Chattogram 116 MW PP (Anlima Ener	HFO (IPP)	6x21.06	116	116	11	116	116	116					
Chattogram Zone Total					2442	2382	1084	1394	1475	1537	245	415		
56	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	100	110	100	110	25		Gas Shortage		
57	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage		
58	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	29	29					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	190	210	200	215					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	270	270	270					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	285	320	330					
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	55	20	55					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	68	26	68	68	169		Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	73	130	135	135					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	135	138	138					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	22	200	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	0	22	22					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	20	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.086	200	200	0	0	0	200					
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	82	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	49	98	100	100					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	** Impoort (Tripura)	India		160	160	132	120	138	164					
Cumilla Zone Total					3094	3034	1597	1918	2056	2384	457	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	156	152	175	175	50		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8			Dependable cap. : 8MW		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	65	115	115					
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	86	200	200	200					
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0					
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22					
Myensingh Zone Total					717	622	319	471	594	542	50	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.10.21 (Yesterday)		27.10.21 (Today)		26.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	42	42	50				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	60	65	4		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	109	111	110	110	219		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	81	84	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	219	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	322	324	324				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	394	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total						2422	2377	1739	1758	1820	1825	225	75
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	300	300	300	300				
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	16	0	30			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	120	120	120	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	102	105	105				
107	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	67	0	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	715	714	728	728				
Khulna Zone Total						2133	2129	1135	1319	1303	1628	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	24	28	28	28				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	90	90	90	90		104	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	22	22	22	22				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	620	620		1244	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	81	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	173	221	220	220				
Barishali Zone Total						2046	2046	326	474	1090	1240	0	1348
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	95	95	95				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43				
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	17	35				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	198	182	210	210	38		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	191	203	210	220				
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	387	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	0	52	43	43				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	111	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	1044	1330	1547	1652	419	0
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	78	80	80	7		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	60	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total						685	605	146	191	201	193	7	359
Sub-total: Plants in operation						21435	20934	9962.0	11827	13471	14687	2082	2869
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9554	11343	12919	14086				
(B) Plants under long term maintenance/ contract expired													
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0			
Gross Total						22031	20934	9962	11827	13471	14687	2082	2869
(C) Actual data of 26.10.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11827.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11343.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	11827.00	MW,	at =	19:00 hrs		MW	MW			MW	MW
04.	Minimum Generation (Generation end)	:	8053.00	MW,	at =	7:00 hrs	Dhaka	4248	4248	0	Myrnsingh	881	881
05.	Day-peak Generation (Generation end)	:	9962.00	MW,	at =	12:00 hrs	Chattogram	1280	1280	0	Sylhet	469	469
06.	Evening-peak Generation (Generation end)	:	11827.00	MW,	at =	19:00 hrs	Khulna	1344	1344	0	Barisal	311	311
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	1089	1089	0	Rangpur	659	659
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8234.00	MW,	at =	5:00 hrs	Cumilla	1062	1062	0			
09.	Generation shortfall at evening peak due to :	:									Total	11343	11343
a)	Gas limitation	:	2075	MW			13.	Fuel cost :	(a) Gas = 162836753 Taka	(c) Coal = 11882721 Taka			
c)	Coal supply Limitation	:	7	MW				(b) Oil = 471967905 Taka	Total = 646687380 Taka				
b)	Low water level in Kapati lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2869	MW			14.	Maximum Temperature in Dhaka was :	31.8° C				
10.	Total Energy (Generation + India Import)	:	245.82	MKWh			15.	Export through East-West interconnections :					
	By Gas = 155.692 MKWH							At evening peak-hour	: -254 MW,	at	19:00 hrs		
	By Coal = 1.991 MKWH							Maximum	: -290 MW,	at	21:00 hrs		
	By Solar= 0.618 MKWH							Energy	: 0.84 MKWh				
11.	Total Gas Supplied	:	1174.53	MMCFD									
(D) Forecast of 27.10.21 (Today) Wednesday :													
01.	Maximum Demand	:	12000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14687	MW	(Generation end)		05.	Total Generation	:	249.42	MKWh		
03.	Maximum Shortage	:	-2687	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.9° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation