

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2021					Day : Friday		Date : 29.10.21					
Probable Maximum Demand : 10700 MW					Probable Maximum Generation : 14776 MW					Rule Curve = 108.70 ft.		
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 104.34 ft.		Today = 104.17 ft.		28.10.21 (Yesterday)			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.10.21 (Yesterday)		29.10.21 (Today)		28.10.21 (Yesterday)	28.10.21 (Yesterday)	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)				Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	10		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	22	22	86	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	152	167	315	320	193	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	340	330	400	400	82		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	180	200	232	232			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	290	240	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	0	40	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	37	25	40	40			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	50	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	215	300	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	115	133	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nababganj 55 MW PP (Southern power	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	29	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	154	162	162	162			
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	26	0	30	0			
Dhaka Zone Total					5717	5560	2487	2779	3350	3725	719	742
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	157	158	158	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	110	115	115	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	50	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	90	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	303	304	300	300			
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	100	80	100			
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
47	Dohazari-Kalashish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	51	100			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	19	40	40			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	45	85	90	90			
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	36	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	101	110	110	110			
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	53	91	116	116			
Chattogram Zone Total					2442	2382	1173	1476	1509	1571	250	415
55	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	80	80	100	55		Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	186	216	200	215			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	300	320	330			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	290	320	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	45	51	55	55			
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	16	8	8	179	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	132	135	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	134	138	138			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	43	43	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	20	20	20			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200			
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	97	100	100			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impoort (Tripura)	India		160	160	122	140	138	164			
Cumilla Zone Total					3094	3034	1667	2030	2084	2374	497	0
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	123	135	160	160	67	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8		Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	16	85	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	100	180	200	200			
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0			
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	17	24	22	22			
Mymensingh Zone Total					717	622	329	454	579	527	67	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.10.21 (Yesterday)		29.10.21 (Today)		28.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	44	50	50				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	120	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	40	60	65	26		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	108	112	110	110	218		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	280	341	341				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	321	324	324				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total						2422	2377	1745	1685	1817	1822	246	75
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	300	300				
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	225	120	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	55	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	0	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	713	713	727	727				
Khulna Zone Total						2133	2129	888	1110	1302	1627	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	27	28	28				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	90	90		129	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	32	58	22	58				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	600	620	620		644	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	81	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	108	107	220	220				
Barisal Zone Total						2046	2046	641	938	1090	1276	0	773
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	12	27	27				
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	96	95	95				
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	40				
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43				
123	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	17	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	178	181	210	210	39		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	193	181	210	220				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	360	310	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	920	1261	1556	1661	420	0
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	83	80	80	80	5		Coal Shortage	
134	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total						685	605	123	193	201	193	5	359
Sub-total: Plants in operation						21435	20934	9973.0	11926	13488	14776	2204	2364
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9511	11374	12863	14092				
(B) Plants under long term maintenance/ contract expired													
140	Kalpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0	0		
Gross Total						22031	20934	9973	11926	13488	14776	2204	2364
(C) Actual data of 28.10.21 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	11926.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11374.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	11926.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	8070.00	MW,	at =	7:00 hrs	Dhaka	4379	4379	0	Myrnsingh	866	866
05.	Day-peak Generation (Generation end)	:	9973.00	MW,	at =	12:00 hrs	Chattogram	1288	1288	0	Sylhet	478	478
06.	Evening-peak Generation (Generation end)	:	11926.00	MW,	at =	19:00 hrs	Khulna	1325	1325	0	Barisal	307	307
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	1054	1054	0	Rangpur	640	640
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7757.00	MW,	at =	5:00 hrs	Cumilla	1037	1037	0			
09.	Generation shortfall at evening peak due to :	:									Total	11374	11374
a)	Gas limitation	:	2199	MW			13.	Fuel cost :	(a) Gas = 155827883 Taka	(c) Coal = 59747945 Taka			
d)	Coal supply Limitation	:	5	MW				(b) Oil = 562029888 Taka	Total = 777605716 Taka				
b)	Low water level in Kaplai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2364	MW			14.	Maximum Temperature in Dhaka was :	32.0° C				
10.	Total Energy (Generation + India Import)	:	250.91	MKWh			15.	Export through East-West interconnections :					
	By Gas = 145.177 MKWh							At evening peak-hour	:	-48	MW,	at	19:00 hrs
	By Coal = 12.894 MKWh							Maximum	:	-220	MW,	at	1:00 hrs
	By Solar= 0.630 MKWh							Energy	:	0.899	MKWh		
11.	Total Gas Supplied	:	1086.66	MMCFD									
(D) Forecast of 29.10.21 (Today) Friday :													
01.	Maximum Demand	:	10700	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14776	MW	(Generation end)		05.	Total Generation	:	319.78	MKWh		
03.	Maximum Shortage	:	-4076	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.9° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation