

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021										Day : Tuesday				Date : 02.11.21			
Probable Maximum Demand : 11000 MW										Probable Maximum Generation : 15038 MW				Rule Curve = 108.90 ft.			
Water Level of Kaptai Lake at 06:00 AM										Today = 103.85 ft.				Yesterday = 103.93 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.11.21 (Yesterday)		02.11.21 (Today)		01.11.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	02.11.21 (Today) Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)										
					Day	Evening	Day	Evening									
(A) Plants in operation:																	
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work						
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80							
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.						
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	99	102	90	102	6	Gas Shortage						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem						
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Gas Shortage						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	292	328	290	360	32	Gas Shortage						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling						
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	318	352	350	412	60							
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	280	300	335	335								
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	275	260	300	300								
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	42	42	45	45								
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	25	25	35	35								
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	40	102	102								
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	21	20	20								
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	52	54	55	55								
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	33	33	33	33								
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	25	25	33	33								
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51								
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105								
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149								
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54								
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	15	250	300								
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	115	135	149	149								
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300								
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100								
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100								
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	40	55	55								
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	55	55								
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	104	104	104								
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	59	162	162	162								
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	26	0	30	0								
Dhaka Zone Total					5717	5560	2234	2452	3343	3876	548	720					
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	114	104	110	110	40	Unit 2 under overhauling						
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	120	120	60	Gas Shortage						
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage						
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0								
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25								
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0								
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	25	20	50	50								
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	17	105	105	105								
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.						
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval						
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	306	302	300	300								
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	80	100								
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	60	90	90	90								
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	100								
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue						
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21								
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	16	5	15								
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90								
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	35	54								
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110	110								
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	100	100	100								
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	0	0	116	116								
Chattogram Zone Total					2442	2382	798	1118	1433	1506	240	415					
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	135	110	135	0	Gas Shortage						
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage						
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage						
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	29	29								
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	216	182	200	215								
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	305	320	330								
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	335	320	330								
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	51	55	55								
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	36	8	8	159	Gas shortage						
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51								
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	80	135	135								
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50								
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	136	138	138								
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	0	200	200								
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22								
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11								
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	33	33								
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43								
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	20								
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.086	200	200	0	0	0	200								
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114								
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	25	101	100	100								
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17								
**	Impoort (Tripura)	India		160	160	96	102	138	164								
Cumilla Zone Total					3094	3034	1356	1639	2114	2400	422	0					
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	157	162	205	205	40	Gas Shortage						
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22								
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8		Dependable cap. : 8MW						
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115								
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	100	140	200	200								
81	Sarikhabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0								
82	Sutishakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0								
83	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	0	22	22								
Mymensingh Zone Total					727	622	334	338	624	572	40	0					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.11.21 (Yesterday)		02.11.21 (Today)		01.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	43	43		40	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	42	42		60			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	50	50					
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	60	65	3		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	118	126	131	131	204		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	84	81	84					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	179	179	220	220					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	280	341	341					
97	Bibiyan-I 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	321	322	324	324					
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1656	1707	1838	1846	209	100	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	350	350	410					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload		
103	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	0	220	220					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	0	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	725	715	733	733					
Khulna Zone Total						2133	2129	1195	1237	1458	1738	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	21	28	30					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65		129	Gas Shortage		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	18	22	58					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	260	400	620	620		844	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	181	202	220	220					
Barishal Zone Total						2046	2046	539	706	1065	1253	0	973	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	27	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	95	95					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	17	35					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	190	173	210	210	47		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	171	178	210	210					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	385	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	21	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
131	Natore 22 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	111	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2179	2179	842	992	1556	1651	428	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	84	82	83	83	3		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	60	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabula 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
Rangpur Zone Total						685	605	90	142	204	196	3	359	
Sub-total: Plants in operation						21435	20934	9044.0	10331	13635	15038	1890	2567	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8699	9937	13115	14464					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0	0			
Gross Total						22031	20934	9044	10331	13635	15038	1890	2567	
(C) Actual data of 01.11.21 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	:	10331.00	MW	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9937.00	MW	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10331.00	MW	at =	19:00 hrs	Dhaka	3896	3896	0	Mymensingh	733	733	0
04.	Minimum Generation (Generation end)	:	7312.00	MW	at =	6:00 hrs	Chattogram	1209	1209	0	Sylhet	390	390	0
05.	Day-peak Generation (Generation end)	:	9044.00	MW	at =	12:00 hrs	Khulna	1111	1111	0	Barishal	256	256	0
06.	Evening-peak Generation (Generation end)	:	10331.00	MW	at =	19:00 hrs	Rajshahi	919	919	0	Rangpur	576	576	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW	at =	19:00 hrs	Cumilla	847	847	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6986.00	MW	at =	5:00 hrs					Total	9937	9937	0
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	(a) Gas = 153983767 Taka	(c) Coal = 47650812 Taka				
a)	Gas limitation	:	1887	MW				(b) Oil = 238455786 Taka	Total = 440090364 Taka					
d)	Coal supply Limitation	:	3	MW										
b)	Low water level in Kapitai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2567	MW										
10.	Total Energy (Generation + India Import)	:	212.52	MKWh			14.	Maximum Temperature in Dhaka was :	31.1° C					
	By Gas = 149.309 MKWH				By Oil = 30.763 MKWh		15.	Export through East-West interconnections :						
	By Coal = 10.120 MKWH				By Hydro = 1.956 MKWh			At evening peak-hour	:	82	MW	at	19:00 hrs	
	By Solar= 0.691 MKWH							Maximum	:	-26	MW	at	18:00 hrs	
11.	Total Gas Supplied	:	1123.42	MMCFD				Energy	:	0.047	MKWh			
(D) Forecast of 02.11.21 (Today) Tuesday :														
01.	Maximum Demand	:	11000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15038	MW	(Generation end)		05.	Total Generation	:	226.28	MKWh			
03.	Maximum Shortage	:	-4038	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	28.7° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation