

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021										Day : Thursday				Date : 04.11.21					
Probable Maximum Demand : 10500 MW										Probable Maximum Generation : 14362 MW									
Water Level of Kaptai Lake at 06:00 AM										Today = 103.64 ft.				Rule Curve = 108.70 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.11.21 (Yesterday)		04.11.21 (Today)		03.11.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	04.11.21 (Today) Probable Peak Generation (MW)	03.11.21 (Yesterday) Probable Peak Generation (MW)	04.11.21 (Today) Probable Peak Generation (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)												
					Day	Evening	Day	Evening											
(A) Plants in operation:																			
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0				260	Under project work					
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				180	Under project work					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80									
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					Under maint.					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	105	100	105	3				Gas Shortage					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				105	CB Problem					
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				20	Gas Shortage					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	137	153	150	150	207				Gas Shortage					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200				Gas Shortage					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0				115	Under Overhauling					
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	388	396	400	400				16						
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210				Gas Shortage					
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335										
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	270	260	300	300										
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	45	55	55	55										
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	25	25	25										
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	5	64	102	102										
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	21	20	21										
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x6.73	80	80	52	55	55	55										
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33										
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33										
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51										
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	0	105	105										
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	10	149	149										
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54										
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	25	120	250	300										
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	117	149	149	149										
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300										
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100										
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100										
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55										
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	52	55	55										
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	50	104	104	104										
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	101	162	162	162										
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	34	0	30	0										
Dhaka Zone Total				5717	5560	2235	2593	3282	3658	720	676								
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	103	102	103	103				40	Unit 2 under overhauling					
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60				Gas Shortage					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Gas Shortage					
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0										
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25										
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	18	0	20	0										
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	50	50	50										
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	57	105	105	105										
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0				150	Under maint.					
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0				225	HGPI awaiting for purchase committee approval					
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	205	304	300	300										
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	80	100										
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	52	90	90	90										
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	100										
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					Environment issue					
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	21	21										
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	3	7	15										
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90										
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54										
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	63	110	110	110										
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100										
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	5	35	116	116										
Chattogram Zone Total				2442	2382	824	1171	1447	1499	240	415								
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55				Gas Shortage					
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129				Gas Shortage					
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134				Gas Shortage					
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	29	29										
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	179	180	200	215										
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	285	320	340										
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	295	280	320	340										
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	10	10										
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187				Gas shortage					
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51										
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	60	130	135	135										
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50										
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	139	138	138										
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	22	120	200	200										
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22										
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11										
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25										
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	43	43										
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	22	20	22										
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200										
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114										
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	105	100	100										
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17										
**	Impoort (Tripura)	India		160	160	102	114	138	164										
Cumilla Zone Total				3094	3034	1369	1631	2031	2314	505	0								
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	131	126	120	120	76				Gas Shortage					
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22										
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	8	8	8					Dependable cap. : 8MW					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115										
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	55	170	200	200										
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0										
82	Sutiskhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0										
83	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	24	22	22										
Mymensingh Zone Total				717	622	254	356	539	487	76	0								

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.11.21 (Yesterday)		04.11.21 (Today)		03.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	65	6		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	117	121	131	132	209		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	84	81	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	199	192	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	285	341	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	322	324	324				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total						2422	2377	1744	1717	1813	1822	217	100
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	275	275	270	250				
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	0	0	220	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	718	718	445	736				
Khulna Zone Total						2133	2129	1046	1098	1090	1581	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	22	28	30				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	15	88	90	90		106	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	41	23	22	30				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	400	620	620		844	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	174	222	220	220				
Barishali Zone Total						2046	2046	585	755	1090	1250	0	950
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	27				
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	23	95	95				
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	40				
123	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	17	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	0	0	0	130	220		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	172	207	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	374	380	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
130	Natore 22 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	25	70	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	46	113	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	648	882	1334	1558	601	0
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80	5		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	106	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total						685	605	86	186	201	193	5	359
Sub-total: Plants in operation						21435	20934	8791.0	10389	12827	14362	2364	2500
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8383	9907	12232	13696				
(B) Plants under long term maintenance/ contract expired													
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0			
Gross Total						22031	20934	8791	10389	12827	14362	2364	2500
(C) Actual data of 03.11.21 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10389.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	9907.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	10389.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	7085.00	MW,	at =	6:00 hrs	Dhaka	3840	3840	0	Myrmensingh	745	745
05.	Day-peak Generation (Generation end)	:	8791.00	MW,	at =	12:00 hrs	Chattogram	1222	1222	0	Sylhet	384	384
06.	Evening-peak Generation (Generation end)	:	10389.00	MW,	at =	19:00 hrs	Khulna	1115	1115	0	Barishal	254	254
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	928	928	0	Rangpur	576	576
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6838.00	MW,	at =	5:00 hrs	Cumilla	843	843	0			
09.	Generation shortfall at evening peak due to :	:									Total	9907	9907
a)	Gas limitation	:	2359	MW			13.	Fuel cost :	(a) Gas = 144321627 Taka	(c) Coal = 49228825 Taka			
c)	Coal supply Limitation	:	5	MW				(b) Oil = 243992563 Taka	Total = 437543015 Taka				
b)	Low water level in Kapta lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2500	MW			14.	Maximum Temperature in Dhaka was :	31.0° C				
10.	Total Energy (Generation + India Import)	:	208.78	MKWh			15.	Export through East-West interconnections :					
	By Gas =	141.110	MKWh	By Oil =	34.211	MKWh		At evening peak-hour	:	-104	MW,	at	19:00 hrs
	By Coal =	10.494	MKWh	By Hydro =	2.503	MKWh		Maximum	:	-130	MW,	at	20:00 hrs
	By Solar=	0.766	MKWh					Energy	:	0.615	MKWh		
11.	Total Gas Supplied	:	1068.10	MMCFD									
(D) Forecast of 04.11.21 (Today) Thursday :													
01.	Maximum Demand	:	10500	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14362	MW	(Generation end)		05.	Total Generation	:	211.01	MKWh		
03.	Maximum Shortage	:	-3862	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	29.0° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation