

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021					Day : Friday		Date : 05.11.21							
Probable Maximum Demand :					9600 MW		Probable Maximum Generation : 14087 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 103.64		Today = 103.52		Rule Curve = 108.60					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.11.21 (Yesterday)		05.11.21 (Today)		04.11.21 (Yesterday)		05.11.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	102	13	70	105	95			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	127	130	150	200	230			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	354	353	400	400		59			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	300	335	335					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	250	250	250	250					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	42	55	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	25	25	25					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	72	102	102					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	18	20	21					
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	46	56	55	55					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	33	33	33	33					
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	25	25	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	105	105					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	149	149					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	95	250	300					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	103	131	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300					
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162					
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0					
Dhaka Zone Total					5717	5560	2237	2379	3202	3658	835	719		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	103	102	103	103		40		Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	11	0	20	0					
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	19	50	50	50					
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	67	105	105	105					
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	304	304	300	300					
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	80	100					
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90					
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	100					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	21	21					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	15	7	15					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90					
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	95	110	110	110					
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	80	100	100	100					
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	0	70	116	116					
Chattogram Zone Total					2442	2382	971	1218	1447	1499	240	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	100	80	80	80	55			Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	29	29					
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	190	207	200	215					
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	330	265	320	340					
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	360	290	320	340					
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	5	10	10					
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	8	8	187			Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	71	135	135	135					
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50					
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	138	138	138					
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	13	100	200	200					
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25					
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	12	43	43					
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	22	20	22					
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.086	200	200	0	0	0	200					
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	49	115	100	100					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
**	Impoort (Tripura)	India		160	160	100	112	138	164					
Cumilla Zone Total					3094	3034	1566	1644	2031	2314	505	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	116	109	120	120	93			Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22	22					
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	8	8				Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	0	115	115					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	90	191	200	200					
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	34	0	50	0					
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22					
Mymensing Zone Total					717	622	242	324	539	487	93	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.11.21 (Yesterday)		05.11.21 (Today)		04.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	52	53	50	50					
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	60	65	4		Gas Shortage		
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	115	120	131	132	210		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	83	81	84					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	192	192	220	220					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	322	324	324					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	0	0					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1730	1685	1493	1502	216	100	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	240	125	270	300					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	220	220					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	108	107	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	439	723	729	729					
Khulna Zone Total						2133	2129	787	955	1374	1624	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	21	28	30					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	90	90	90		104	Gas Shortage		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	12	12	12					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	260	390	620	620		854	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	151	223	220	220					
Barishali Zone Total						2046	2046	520	771	1080	1232	0	958	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	95	95					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	40					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	17	35					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	5	62	130	150	158		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	195	166	200	200					
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	398	316	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	17	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	25	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	95	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2179	2179	734	945	1464	1578	539	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	84	80	80	80	5		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	42	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabula 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
Rangpur Zone Total						685	605	132	193	201	193	5	359	
Sub-total: Plants in operation						21435	20934	8919.0	10114	12831	14087	2433	2551	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8449	9581	12154	13345					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0	0			
Gross Total						22031	20934	8919	10114	12831	14087	2433	2551	
(C) Actual data of 04.11.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	10114.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9581.00	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10114.00	MW,	at =	19:00 hrs	Dhaka	3641	3641	0	Mymensingh	728	728	0
04.	Minimum Generation (Generation end)	:	6838.00	MW,	at =	6:00 hrs	Chattogram	1248	1248	0	Sylhet	371	371	0
05.	Day-peak Generation (Generation end)	:	8919.00	MW,	at =	12:00 hrs	Khulna	1084	1084	0	Barisal	251	251	0
06.	Evening-peak Generation (Generation end)	:	10114.00	MW,	at =	19:00 hrs	Rajshahi	882	882	0	Rangpur	570	570	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	806	806	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6471.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
	a) Gas limitation	:	2428	MW			13.	Fuel cost :	(a) Gas = 142348744 Taka	(c) Coal = 47386157 Taka				
	d) Coal supply Limitation	:	5	MW				(b) Oil = 255504181 Taka	Total = 445239082 Taka					
	b) Low water level in Kapitai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2551	MW			14.	Maximum Temperature in Dhaka was :	31.4° C					
10.	Total Energy (Generation + India Import)	:	205.89	MKWh			15.	Export through East-West interconnections :						
	By Gas =	139.354	MKWh	By Oil =	35.864	MKWh		At evening peak-hour	:	-62	MW,	at	19:00 hrs	
	By Coal =	10.089	MKWh	By Hydro =	2.406	MKWh		Maximum	:	-178	MW,	at	8:00 hrs	
	By Solar=	0.687	MKWh					Energy	:	0.681	MKWh			
11.	Total Gas Supplied	:	1053.23	MMCFD										
(D) Forecast of 05.11.21 (Today) Friday :														
01.	Maximum Demand	:	9600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14087	MW	(Generation end)		05.	Total Generation	:	195.42	MKWh			
03.	Maximum Shortage	:	-4487	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	28.3° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation