

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021					Day : Saturday		Date : 06.11.21						
Probable Maximum Demand : 10300 MW					Probable Maximum Generation : 14387 MW								
Water Level of Kaptai Lake at 06:00 AM					Today = 103.37 ft.		Rule Curve = 106.50 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.11.21 (Yesterday)		06.11.21 (Today)		05.11.21 (Yesterday) Gen. shortfall for Gas/water/Coal limitation MW	06.11.21 (Today) Gen. shortfall for Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	70	105	96	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	20	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	53	305	300	320	55	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	328	342	400	400		70		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	300	335	335				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	235	225	250	250				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	30	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	25	25				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	102	102				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	20	21				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	43	48	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	32	32	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300				
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	53	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	1	108	162	162				
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0				
Dhaka Zone Total					5717	5560	1608	2058	3352	3778	661	730	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	103	102	103	103		40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25				
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	26	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	17	34	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	230	178	300	300				
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	80	100				
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	90	90				
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	100				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	21	21				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			28	37	15	25				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	10	90	90				
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	51	110	110				
53	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	40	100	100	100				
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	0	0	116	116				
Chattogram Zone Total					2442	2382	702	908	1455	1509	240	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	120	80	100	120	55	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	29	29				
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	181	180	200	215				
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	305	320	340				
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	365	270	320	340				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	20	20	20				
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	29	51	51	51				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	10	135	135				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	135	138	138				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	9	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	22	20	22				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.086	200	200	0	0	0	200				
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	55	100	100				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
**	Impoport (Tripura)	India		160	160	80	92	138	164				
Cumilla Zone Total					3094	3034	1345	1330	2061	2364	505	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	142	162	140	160	40	Gas Shortage		
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	8	8		Dependable cap. : 8MW		
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	120	200	200				
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22				
Mymensingh Zone Total					717	622	275	312	559	527	40	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.11.21 (Yesterday)		06.11.21 (Today)		05.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	34	53	50	50				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	110	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	50	60	65	16		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	117	123	131	132	207		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	84	81	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	225	192	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	270	341	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	322	400	324	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total						2422	2377	1343	1387	1493	1578	243	100
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	150	115	270	300				
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	220	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	70	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	714	715	733	733				
Khulna Zone Total						2133	2129	864	900	1378	1628	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	13	20	28	30				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	77	78	90	90		116	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	12	12				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	400	620	620		844	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	130	224	220	220				
Barishal Zone Total						2046	2046	570	722	1080	1232	0	960
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	9	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	27				
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	41	95	95				
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	0	40				
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	40				
123	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	17	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	51	59	130	150	161		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	169	153	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	329	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	6	20	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
130	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	105	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2179	2179	619	876	1464	1578	542	0
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	81	80	80	4		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	107	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total						685	605	87	188	201	193	4	359
Sub-total: Plants in operation						21435	20934	7413.0	8681	13043	14387	2235	2564
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7151	8374	12581	13878				
(B) Plants under long term maintenance/ contract expired													
140	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0			
Gross Total						22031	20934	7413	8681	13043	14387	2235	2564
(C) Actual data of 05.11.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	8681.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	8374.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	8681.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	6407.00	MW,	at =	9:00 hrs	Dhaka	3010	3010	0	Mymensingh	681	681
05.	Day-peak Generation (Generation end)	:	7413.00	MW,	at =	12:00 hrs	Chattogram	1022	1022	0	Sylhet	349	349
06.	Evening-peak Generation (Generation end)	:	8681.00	MW,	at =	19:00 hrs	Khulna	978	978	0	Barisal	233	233
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	818	818	0	Rangpur	541	541
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6094.00	MW,	at =	5:00 hrs	Cumilla	742	742	0			
09.	Generation shortfall at evening peak due to :	:									Total	8374	8374
a)	Gas limitation	:	2231	MW			13.	Fuel cost :	(a) Gas = 138137944 Taka	(c) Coal = 50659965 Taka			
c)	Coal supply Limitation	:	4	MW				(b) Oil = 129553119 Taka	Total = 318351029 Taka				
b)	Low water level in Kaplai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2564	MW			14.	Maximum Temperature in Dhaka was :	31.2° C				
10.	Total Energy (Generation + India Import)	:	180.39	MKWh			15.	Export through East-West interconnections :					
	By Gas = 129.598 MKWh							At evening peak-hour	:	-10	MW,	at	19:00 hrs
	By Coal = 10.820 MKWh							Maximum	:	-136	MW,	at	21:00 hrs
	By Solar= 0.780 MKWh							Energy	:	0.4205	MKWh		
11.	Total Gas Supplied	:	987.99	MMCFD									
(D) Forecast of 06.11.21 (Today) Saturday :													
01.	Maximum Demand	:	10300	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14387	MW	(Generation end)		05.	Total Generation	:	214.03	MKWh		
03.	Maximum Shortage	:	-4087	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.5° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation