

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021					Day : Sunday		Date : 14.11.21							
Probable Maximum Demand : 9800 MW					Probable Maximum Generation : 13624 MW					Rule Curve = 107.70 ft.				
Water Level of Kaptai Lake at 06:00 AM					Today = 102.49 ft.					13.11.21 (Yesterday)				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.11.21 (Yesterday)		14.11.21 (Today)		13.11.21 (Yesterday)	Gen. shortfall for Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under project work		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	0	0	80				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			Under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	100	100	108		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		CB Problem		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	270	300	360	90		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	352	397	400	400	15				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	263	260	0	0					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	295	260	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	40	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	25	25					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	0	102	102					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	16	19	19					
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x6.73	80	80	53	56	55	55					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x6.73	33	33	33	33	33	33					
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x6.73	33	33	33	33	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	0	105	105					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	45	250	300					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	80	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300					
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	17	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	104	104	104					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	162	162					
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	9	0	30	0					
Dhaka Zone Total					5717	5560	2173	2187	2986	3416	708	675		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	70	70	70	40		Unit 2 under overhauling		
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	115	115	115	65		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25					
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	0	0	20	0					
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	24	50	50					
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	17	105	105	105					
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting for purchase committee approval		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	242	304	300	300					
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	80	100					
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	60	90	80	80					
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	51	85					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	20	21					
50	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	13	5	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90					
52	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	110	110	110					
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	40	100	100					
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	0	0	116	116					
Chattogram Zone Total					2442	2382	554	993	1396	1441	245	415		
56	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	135	80	80	0		Gas Shortage		
57	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage		
58	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	23	29	29					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	215	221	200	220					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0			Under Maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	300	330	330					
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	35	30	30					
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	45	16	45	150		Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	100	130	130					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	135	136	138					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	51	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	25	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	22	22					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200					
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	113	113	113					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	Impoort (Tripura)	India		160	160	68	102	138	164					
Cumilla Zone Total					3094	3034	1037	1415	1757	2042	413	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	156	190	160	200	12		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	0	22	22					
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	3	8	115	115					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	100	120	200	200					
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0					
87	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22					
Mymensingh Zone Total					717	622	332	318	571	559	12	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.11.21 (Yesterday)		14.11.21 (Today)		13.11.21 (Yesterday)		14.11.21 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT1 Load gear problem			
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	0	0	0	0		90				
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50						
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163						
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11						
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	60	65	4		Gas Shortage			
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	163	160	162	167		Gas Shortage			
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	80	84						
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	205	205	220	220						
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage			
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24						
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341						
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	389	353	324	400						
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0						
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	70	50	80	80		50	Under project work			
Sylhet Zone Total						2422	2377	1548	1492	1571	1658	191	130		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	350	350	370						
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload			
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload			
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220						
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100						
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	70	105	105						
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			Line Overload			
**	Bheramara (HVDC)	India		1000	1000	732	726	741	741						
Khulna Zone Total						2133	2129	1032	1146	1246	1706	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload			
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	13	21	28	30						
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	93	90	90		101	Gas Shortage			
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12						
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	340	620	620		904	Line Overload			
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150						
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	151	220	220	220						
Barishal Zone Total						2046	2046	538	685	1080	1232	0	1005		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	9	50	50						
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200						
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30						
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	12	18	18						
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	42	95	95						
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	7	0	40						
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	8						
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	20	33						
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.			
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	185	177	190	190	43		Gas Shortage			
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0			Under Maint.			
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	421	322	400	400						
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22						
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11						
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	0	0	52	52						
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113						
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	70	113	113						
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0						
Rajshahi Zone Total						2179	2179	636	744	1320	1375	424	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	81	80	82	4		Coal Shortage			
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.			
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113						
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
Rangpur Zone Total						685	605	88	194	201	195	4	359		
Sub-total: Plants in operation						21435	20934	7938.0	9174	12128	13624	1997	2584		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7607	8792	11623	13057						
(B) Plants under long term maintenance/ contract expired															
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired			
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0						
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021			
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021			
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0					
Gross Total						22031	20934	7938	9174	12128	13624	1997	2584		
(C) Actual data of 13.11.21 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	9174.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8792.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply		
03.	Highest Generation (Generation end)	:	9174.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW		
04.	Minimum Generation (Generation end)	:	6283.00	MW,	at =	5:00 hrs	Dhaka	3244	3244	0	Mymensingh	678	678		
05.	Day-peak Generation (Generation end)	:	7938.00	MW,	at =	12:00 hrs	Chattogram	1095	1095	0	Sylhet	351	351		
06.	Evening-peak Generation (Generation end)	:	9174.00	MW,	at =	19:00 hrs	Khulna	1009	1009	0	Barisal	253	253		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	838	838	0	Rangpur	562	562		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6147.00	MW,	at =	5:00 hrs	Cumilla	762	762	0					
09.	Generation shortfall at evening peak due to :	:									Total	8792	8792		
a)	Gas limitation	:	1993	MW			13.	Fuel cost :	(a) Gas = 142104299 Taka	(c) Coal = 47646113 Taka					
c)	Coal supply Limitation	:	4	MW				(b) Oil = 172372135 Taka	Total = 362122546 Taka						
b)	Low water level in Kapta lake	:	0	MW											
c)	Plants under shut down/ maintenance	:	2584	MW			14.	Maximum Temperature in Dhaka was :	29.2° C						
10.	Total Energy (Generation + India Import)	:	186.46	MKWh			15.	Export through East-West interconnections :							
	By Gas = 132.873 MKWh							At evening peak-hour	:	-6	MW,	at	19:00 hrs		
	By Coal = 10.126 MKWh							Maximum	:	-124	MW,	at	18:00 hrs		
	By Solar= 0.370 MKWh							Energy	:	0.106	MKWh				
11.	Total Gas Supplied	:	987.29	MMCFD											
(D) Forecast of 14.11.21 (Today) Sunday :															
01.	Maximum Demand	:	9800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13624	MW	(Generation end)		05.	Total Generation	:	199.19	MKWh				
03.	Maximum Shortage	:	-3824	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	25.8° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation