

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		17-Nov-21		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	102	2153636	
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	369	8653600	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	191	6036000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6452750	Gas shortage
9	Meghnaghat 100 MW(IEL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	280	6674182	FGMO
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	466334	
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	25	75015	Engine problem
14	Narsinghā 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	334584	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	40	1252000	GT-2 under maint.
17	Siddhirgonj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*18	335	1	346973	Under maint.
19	Gaganagar 102 MW PP (Digital Po	IPP	12*8.924	102	32	62064	High voltage
20	Kaptai 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1300680	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	183840	Low demand.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	239535	
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	621958	
25	Bosila 108MW RPCL	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power (Madabad)-Ashuli	SIPP, REB	3*3.67+4*8.73	80	55	1211460	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	28	767200	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	834300	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	46	240960	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	145	383691	Low demand.
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	81	354240	Low demand.
36	Gazipur 100 MW PP	RPCL	100 MW	105	52	145200	Low demand.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1168320	
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2463840	
39	Spectra Solar Plant Ltd	IPP	35	35	0	205227	
Dhaka area Total				5560	2304	42829689	
40	Chattogram TPP-1	PDB	1*210	180	100	2500000	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Razzan 25 MW PP	IPP	3*8.9	25	8	21708	Low demand.
42	Teknaf 220MW PP (Solartech)Teknaf	Solartech Energ	20	20	0	121770	
43	Palenaga 50MW PP (Baraka)	IPP	8*6.98	50	46	387390	
44	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	2264509	Low water level & #2 Under n
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	105	1236981	
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dobhazari-Kalash 100 MW Peakin	PDB	6*17	102	68	713238	Engine problem
50	Juidah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	20	70560	Low demand.
51	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	1589760	
52	Barabkunda 22 MW PP (Regent)	SiPP, PDB	8*2.90	22	21	492912	
	* Malancha, Cig, EPZ (United)		5*8.73+3*9.34	0	10	464160	
53	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Reserve.
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	24680	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	304	6220036	
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1185424	
57	Karnaphuli Power Ltd.	IPP	110	110	110	1713701	
58	Juidah unit-2 (Acom)	IPP	8*13.6	100	100	1130880	
59	Anilima Energy Ltd.	IPP	6*21.2	116	30	55200	Low demand.
Chattogram area Total				2382	1146	20192799	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2006558	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	192	4527000	FGMO
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	290	7303200	FGMO
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	310	7263000	Under maint.
64	Ashuganj 50 MW PP	IPP	14*3.968	45	29	656136	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	10	674080	Engine problem
66	Ashuganj 195MW PP (APSCL-UN	IPP	20*9.73+1*16	195	8	217454	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1158466	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	145	1043781	
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
70	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	138	3269590	Machine problem
71	Chandpur 200MW (Desh energy)	IPP	0	200	50	351840	Low demand.
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	418320	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	149580	Engine problem
**	Impoport (Tripura)	Imported power	0	160	110	2288640	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	615800	
75	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	8	39595	Low demand.
76	Comilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	230600	Engine problem
77	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	108	1157520	
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	444960	33 KV feeder fault.
Cumilla Area Total				3034	1618	34032780	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	152	3794560	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	398412	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Engine problem
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13500	
85	Mymensingh 200 MW PP (United	IPP	200	200	160	2181600	Low demand.
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	8	38400	Low demand.
87	Sultakhal 50 MW Solar PP	IPP	50	50	0	331540	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	23	36980	
Mymensingh Area Total				622	365	6794972	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	0	0	Under maint.
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	699720	Machine problem
91	Kushlara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3567927	Frequency control
92	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	2594000	GT-1 under maint
93	Fenchugonj 51 MW PP (Barakati	RPP	18*2.90	51	50	970200	
94	Fenchugonj 44MW PP (Confidence	RPP	12*3.3+3*5.2	0	0	0	Contract Expired
94	Habiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	189120	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	61	1215648	
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	81	1441920	
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	70	1701418	Engine problem
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	20	476040	
99	Sylhet 20 MW GTTP	PDB	1*20	20	18	402000	
	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	415080	
101	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	305	7328960	FGMO
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	299	6975000	
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	198180	
104	Bibiyana South 400 MW	PDB	400 MW	383	0	0	Under maint.
Sylhet Area Total				2377	1109	28175213	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	733	16028363	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Copalganj 100 MW Peaking PP	IPP	16*6.89	109	0	0	Reserve.
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	380	8416512	Gas shortage
	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	0	0	Reserve.
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	377760	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khulna Area Total				2129	1218	24822835	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	21	395500	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	68	1611000	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	10	264441	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	400	8565900	Line O/L
119	Bhola Nutan Biddut BD LTD	IPP	220	220	220	4116791	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total				2046	719	14853632	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
122	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	25	30560	
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Engine problem
124	Ammura 50 MW PP(Sinha)	ORPP	7*7.79	50	27	90320	Engine problem
125	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	43	92965	Engine problem
126	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	40	77991	Engine problem
127	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
128	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	181	4290118	Gas shortage
129	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	0	0	Gas shortage
130	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	351	8800218	FGMO
131	Santahar 50 MW Peaking PP	PDB	6*8.7	50	35	80832	Engine problem
132	Bogra 22 MW PP (GBD)	RPP	6*4	22	18	334800	Engine problem
133	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
134	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	8	155268	Engine problem
135	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	8	53288	Low demand.
136	Chapainawabganj 100 MW Peakr	PDB	12*8.924	104	0	0	Reserve.
137	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.
138	Bogra 113 MW PP (Confidence)	IPP	113	113	113	1390656	
139	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	859200	
140	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	35100	
Rajshahi Area Total				2179	962	16291316	
141	Barapukuria TPP Unit-1	PDB	1*125	85	83	1916945	
	Barapukuria TPP Unit-2	PDB	1*125	85	0	0	Under maint.