

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 19-Nov-21      |                                  |                 |                     |          |           |                  | Page -2                      |
|-----------------------|----------------------------------|-----------------|---------------------|----------|-----------|------------------|------------------------------|
| No.                   | Name of the Power Stations       | Producer        | Installed Capacity  | Capacity | Peak Hour | Energy Generated | Remarks                      |
|                       |                                  |                 | Unit No. X Capacity | MW       | MW        | KWH              |                              |
| 1                     | Ghorasal Repowered CCPP-Unit-    | PDB             | 1*260               | 260      | 0         | 0                | Under maint.                 |
| 2                     | Ghorasal Repowered CCPP Unit-    | PDB             | 1*210               | 180      | 0         | 0                | Under maint.                 |
|                       | Ghorasal TPP Unit-5              | PDB             | 1*210               | 190      | 170       | 2929500          |                              |
| 3                     | Ghorasal 365 MW CCPP Unit-7      | PDB             | 1*243+1*122         | 365      | 0         | 0                | Under maint.                 |
|                       | Ghorasal 78.5 MW PP(MAX)         | QRPP            | 2*40                | 0        | 0         | 0                | Contract Expired             |
| 4                     | Ghorasal 108MW PP (Regent)       | IPP             | 34*3.35             | 108      | 100       | 1330863          |                              |
| 5                     | Haripur GTTP                     | SBU, PDB        | 2*32                | 20       | 0         | 0                | Under maint.                 |
| 6                     | Haripur 412 MW CCPP              | EGCB            | 1*273+1*139         | 412      | 341       | 7952990          | Gas shortage                 |
| 7                     | Haripur 360MW CCPP(HPL)          | IPP             | 1*235+1*125         | 360      | 332       | 6964000          | Gas shortage                 |
| 8                     | Meghnaghat 450 MW CCPP(MPL)      | IPP             | 2*150+1*150         | 450      | 270       | 6561000          | Gas shortage                 |
| 9                     | Meghnaghat 100 MW(IEL)           | QRPP            | 12*8.9              | 0        | 0         | 0                | Contract Expired             |
| 10                    | Meghnaghat CCPP(Summit)          | IPP             | 2*110+1*110         | 305      | 255       | 6530327          | FGMO                         |
| 11                    | Madanganj 102 PP(Summit)         | QRPP            | 6*17                | 0        | 0         | 0                | Contract Expired             |
| 12                    | Madanganj-55 MW PP(Summit)       | (IPP)           | 3*17.08+1*11.3      | 55       | 55        | 627190           |                              |
| 13                    | Keraniganj 100 MW PP (Powerpac)  | QRPP            | 8*13.45             | 100      | 0         | 0                | Reserve.                     |
| 14                    | Narsinghdi 22 MW PP (Doreen)     | SIPP, REB       | 8*2.90              | 22       | 21        | 238032           |                              |
| 15                    | 210 MW Siddhirganj TPP           | PDB             | 1*210               | 115      | 0         | 0                | Under maint.                 |
| 16                    | Siddhirganj 2120 MW GTTP         | EGCB            | 2*105               | 210      | 0         | 0                | Gas shortage                 |
| 17                    | Siddhirganj 102 PP(Dutch Bangla  | QRPP            | 12*8.9              | 0        | 0         | 0                | Contract Expired             |
| 18                    | Siddhirganj 335 MW CCPP          | EGCB            | 1*217+1*18          | 335      | 0         | 3229410          | Gas shortage                 |
| 19                    | Gaagnagar 102 MW PP (Digital Po  | IPP             | 12*8.924            | 102      | 32        | 389520           | Line O/L                     |
| 20                    | Katpotti 52 MW PP (Sinha)        | IPP             | 7*7.9               | 0        | 0         | 0                |                              |
| 21                    | Kamalaghat 54 MW PP(Banco En     | IPP             | 3*18                | 54       | 0         | 578160           | Reserve.                     |
| 22                    | Kodda 1500MW PP                  | BPDB-RPCL       | 9*17.06             | 149      | 8         | 30240            | Low demand.                  |
| 23                    | Sidkaganj 55 MW PP (Northern)    | IPP             | 3*19.3              | 55       | 0         | 0                | Reserve.                     |
| 24                    | Nababganj 55 MW PP (Southern     | IPP             | 3*19.3              | 55       | 0         | 31208            | Reserve.                     |
| 25                    | Bosila 108MW PP(OLC)             | IPP             | 12*8.775+1*3.5      | 0        | 0         | 0                |                              |
| 26                    | Summit Power (Madhabadi-Ashuli   | SIPP, REB       | 3*3.67+4*8.73       | 80       | 45        | 1055220          | Engine problem               |
| 27                    | Maona 33 MW PP(Summit)           | SIPP, REB       | 4*8.73              | 33       | 25        | 760300           | Engine problem               |
| 28                    | Rupganj 33 MW PP(Summit)         | SIPP, REB       | 4*8.73              | 33       | 33        | 785100           |                              |
| 29                    | Gazipur 52 MW PP                 | RPCL            | 6*8.9               | 52       | 0         | 0                | Reserve.                     |
| 30                    | Tongi 80 MW GTTP                 | PDB             | 1*105               | 105      | 0         | 0                | Under maint.                 |
| 31                    | Kodda 300 MW PP Unit-2 (Summ     | IPP             | 18*17.076           | 300      | 0         | 102873           | Reserve.                     |
| 32                    | Keraniganj 300 MW PP (APR)       | IPP             | 25*11.4             | 300      | 0         | 0                | Reserve.                     |
| 33                    | Bramhangaoan 100 MW PP (Aggr     | IPP             | 100                 | 100      | 0         | 0                | Reserve.                     |
| 34                    | Aurahati 100MW PP (Aggreko)      | IPP             | 0.85*23+0.95*91     | 100      | 0         | 0                | Reserve.                     |
| 35                    | Kodda 149 MW PP Unit-1 (Summ     | IPP             | 149                 | 149      | 0         | 0                | Reserve.                     |
| 36                    | Gazipur 100 MW PP                | RPCL            | 100 MW              | 105      | 0         | 0                | Reserve.                     |
| 37                    | Meghnaghat 104 MW PP (OPCL)      | IPP             | 18.5*6              | 66       | 244800    | 104              | Low demand.                  |
| 38                    | Manikgonj 162MW PP(MPL)          | IPP             | 9*18                | 162      | 108       | 469440           | Engine problem               |
| 39                    | Spectra Solar Plant Ltd.         | IPP             | 35                  | 35       | 0         | 199611           |                              |
| Dhaka area Total      |                                  |                 |                     | 5560     | 1861      | 41009184         |                              |
| 40                    | Chattogram TPP-1                 | PDB             | 1*210               | 180      | 110       | 2600000          | Gas shortage                 |
|                       | Chattogram TPP-2                 | PDB             | 1*210               | 180      | 0         | 0                | Gas shortage                 |
| 41                    | Razzan 25 MW PP                  | IPP             | 3*8.9               | 25       | 8         | 93457            | Low demand.                  |
| 42                    | Teknaf 20MW PP (Solartech)Teknaf | Solartech Energ | 20                  | 20       | 0         | 132030           |                              |
| 43                    | Patenga 50MW PP (Baraka)         | IPP             | 8*6.98              | 50       | 32        | 86400            | Low demand.                  |
| 44                    | Kaptai Hydro. Unit-1,2,3,4, 5    | PDB             | 2*40+3*50           | 230      | 107       | 2408393          | Low water level & #2 Under m |
| 45                    | Sikalbaha 225MW                  | PDB             | 1*150+1*175         | 225      | 0         | 0                | Under maint.                 |
| 46                    | Sikalbaha Peaking GT             | PDB             | 1*150               | 150      | 0         | 0                | Under maint.                 |
| 47                    | Sikalbaha 105 MW PP (Baraka St   | IPP             | 105 MW              | 105      | 68        | 399781           | Low demand.                  |
| 48                    | Hathazari 100 MW peaking PP      | PDB             | 11*8.9              | 98       | 0         | 0                | Under S/D                    |
| 49                    | Dohazari-Kalash 100 MW Peakr     | PDB             | 6*17                | 102      | 34        | 253658           | Low demand.                  |
| 50                    | Juidah 100 MW Unit-1 (Acorn)     | QRPP            | 8*13.45             | 100      | 0         | 0                | Reserve.                     |
| 51                    | Juidah 100 MW PP Unit-3 (Acorn   | IPP             | 0                   | 100      | 100       | 1384320          |                              |
| 52                    | Barabkunda 22 MW PP (Regent)     | SIPP, PDB       | 8*2.90              | 22       | 18        | 426432           | Engine problem               |
|                       | * Malancha, Cig, EP2 (United)    |                 | 5*8.73+3*9.34       | 0        | 42        | 796800           |                              |
| 53                    | Chattogram 108 MW PP (ECPV)      | IPP             | 16*7                | 108      | 0         | 0                | Reserve.                     |
| 54                    | Kaptai 7 MW Solar PP             | PDB             | 7.4 MW              | 7        | 0         | 18480            |                              |
| 55                    | Anwara 300 MW PP (United)        | IPP             | 300 MW              | 300      | 304       | 4242873          |                              |
| 56                    | Jodiac Power                     | IPP             | 3*18.55+1*3.6       | 54       | 54        | 1300524          |                              |
| 57                    | Karnaphuli Power Ltd.            | IPP             | 110                 | 110      | 68        | 577920           | Low demand.                  |
| 58                    | Juidah unit-2 (Acorn)            | IPP             | 8*13.6              | 100      | 60        | 204480           | Low demand.                  |
| 59                    | Anilma Energy Ltd.               | IPP             | 6*21.2              | 116      | 0         | 0                | Reserve.                     |
| Chattogram area Total |                                  |                 |                     | 2382     | 1005      | 14925548         |                              |
| 60                    | Ashuganj TPP Unit-3              | APSCL           | 1*150               | 135      | 80        | 1997086          | Gas shortage                 |
|                       | Ashuganj TPP Unit-4              | APSCL           | 1*150               | 129      | 0         | 0                | Gas shortage                 |
|                       | Ashuganj TPP Unit-5              | APSCL           | 1*150               | 134      | 0         | 0                | Gas shortage                 |
| 61                    | Ashuganj 225 MW CCPP             | APSCL           | 1*142+1*75          | 221      | 178       | 4480000          | FGMO                         |
| 62                    | Ashuganj 450 MW CCPP(North)      | APSCL           | 1*360               | 360      | 280       | 7405000          | FGMO                         |
| 63                    | Ashuganj 450 MW CCPP(South)      | APSCL           | 1*360               | 300      | 300       | 7063000          | FGMO                         |
| 64                    | Ashuganj 50 MW PP                | APSCL           | 14*3.968            | 45       | 29        | 514860           | Engine problem               |
| 65                    | Ashuganj 55 MW PP (Precision)    | RPP             | 15*4                | 55       | 20        | 264480           | Gas shortage                 |
| 66                    | Ashuganj 195MW PP (APSCL-UN      | IPP             | 20*9.73+1*16        | 195      | 8         | 217454           | Gas shortage                 |
| 67                    | Ashuganj 51 MW PP (Midland)      | IPP             | 6*9.34              | 51       | 51        | 939260           |                              |
| 68                    | Ashuganj 150MW PP (Midland)      | IPP             | 23*7.015            | 150      | 70        | 250908           | Low demand.                  |
| 69                    | Titas 50 MW Peaking PP           | PDB             | 6*8.92              | 52       | 0         | 0                | Reserve.                     |
| 70                    | Chandpur 150 MW CCPP             | PDB             | 1*106+1*57          | 163      | 134       | 3270470          | Machine problem              |
| 71                    | Chandpur 200MW (Desh energy)     | IPP             | 0                   | 200      | 0         | 36840            | Reserve.                     |
| 72                    | Feni 22MW PP (Doreen)            | SIPP, PDB       | 8*2.90              | 22       | 22        | 513684           |                              |
| 73                    | Feni 11 MW PP (Doreen)           | SIPP, REB       | 4*2.90              | 11       | 0         | 134460           | Engine problem               |
| **                    | Imoport (Tripura)                | Imported power  | 0                   | 160      | 94        | 2001600          |                              |
| 74                    | Jangalia 33MW PP (Summit)        | SIPP, PDB       | 4*8.73              | 33       | 33        | 764200           |                              |
| 75                    | Jangalia 52 MW PP (Lakdanavi)    | IPP             | 6*8.92              | 52       | 0         | 0                | Reserve.                     |
| 76                    | Comilla 25 MW PP (Summit)        | SIPP, PDB       | 3*3.67+2*6.97       | 25       | 9         | 211920           | Engine problem               |
| 77                    | Daudkandi 200 MW PP (B. Trac)    | IPP             | 154*1.4             | 200      | 0         | 0                | Reserve.                     |
| 78                    | Feni Lanka Power                 | IPP             | 7*18.415+1*9.78     | 114      | 0         | 0                | Reserve.                     |
| 79                    | Chowmuhani 113 MW                | IPP             | 12*9.78+2*3.1       | 113      | 75        | 228480           | Low demand.                  |
| 80                    | Bhairab 54.5 MW                  | IPP             | 3*18.2              | 54       | 17        | 444240           | 33 KV feeder fault.          |
| Cumilla Area Total    |                                  |                 |                     | 3034     | 1400      | 30730882         |                              |
| 81                    | RPCL 210MW CCPP                  | IPP             | 4*35+1*70           | 202      | 189       | 4276800          | Gas shortage                 |
| 82                    | Tangail 22 MW PP (Doreen)        | SIPP, PDB       | 8*2.90              | 22       | 22        | 231480           |                              |
| 83                    | Jamalpur 95 MW PP(Powerpac)      | IPP             | 12*8.924            | 8        | 0         | 0                | Engine problem               |
| 84                    | Sarishabari 3 MW Solar Plant     | IPP             | 1*3                 | 3        | 0         | 12600            |                              |
| 85                    | Mymensingh 200 MW PP (United     | IPP             | 200                 | 200      | 80        | 1156800          | Low demand.                  |
| 86                    | Jamalpur 115 MW PP (United)      | IPP             | 115 MW              | 115      | 0         | 0                | Reserve.                     |
| 87                    | Sultakhal 50 MW Solar PP         | IPP             | 50                  | 50       | 0         | 294480           |                              |
| 88                    | Tangail Pali Power Gen 22 MW     | IPP             | 4*6.7               | 22       | 0         | 0                | Reserve.                     |
| Mymensingh Area Total |                                  |                 |                     | 622      | 291       | 5972160          |                              |
| 89                    | Fenchugonj CCPP Phase-1          | PDB             | 2*32+1*33           | 70       | 0         | 0                | Under maint.                 |
| 90                    | Fenchugonj CCPP Phase-2          | PDB             | 2*35+1*35           | 90       | 30        | 720000           | Machine problem              |
| 91                    | Kushlara 163 MW CCPP (KP)        | IPP             | 1*109+1*54          | 163      | 163       | 3296945          |                              |
| 92                    | Shahjibazar 330 MW CCPP          | PDB             | 3*110               | 330      | 157       | 3373000          | GT-1 under maint             |
| 93                    | Fenchugonj 51 MW PP (Barakata    | RPP             | 18*2.90             | 51       | 48        | 477000           |                              |
| 94                    | Fenchugonj 44MW PP (Energyprima  | RPP             | 12*3.3+3*2          | 0        | 0         | 0                | Contract Expired             |
| 94                    | Hobiganj 11MW PP Confidence-E    | SIPP, REB       | 4*2.90              | 11       | 11        | 152000           |                              |
| 95                    | Shahjibazar GTTP Unit- 8 & 9     | PDB             | 2*35                | 66       | 63        | 1148544          |                              |
| 96                    | Shahjibazar 86MW PP (Shahjibaz   | RPP             | 32*2.90             | 86       | 81        | 648000           |                              |
| 97                    | Shahjibazar 100 MW GTTP          | PDB             | 1*100               | 100      | 0         | 1130364          | Reserve.                     |
| 98                    | Sylhet 225 MW CCPP               | PDB             | 1*142+1*89          | 231      | 120       | 2460880          |                              |
| 99                    | Sylhet 20 MW GTTP                | PDB             | 1*20                | 20       | 0         | 0                | Gas shortage                 |
|                       | Sylhet 50MW PP (EPL)             | RPP             | 27*2                | 0        | 0         | 0                | Contract Expired             |
| 100                   | Shahjahanulla 25 MW PP           | SIPP, REB       | 3*9.34              | 25       | 24        | 520056           |                              |
| 101                   | Bibiana-II 341 MW CCPP (Summ     | IPP             | 1*222+1*119         | 341      | 270       | 7193500          | FGMO                         |
| 102                   | Bibiyana-III 400 MW CCPP         | PDB             | 400 MW              | 400      | 80        | 4614000          | ST preparation.              |
| 103                   | Sylhet 10MW PP (Desh)            | RPP             | 6*1.95              | 10       | 10        | 252180           |                              |
| 104                   | Bibiyana South 400 MW            | PDB             | 400 MW              | 383      | 0         | 0                | Under maint.                 |
| Sylhet Area Total     |                                  |                 |                     | 2377     | 1057      | 25986269         |                              |
| 105                   | Bheramara GTTP Unit-3            | PDB             | 1*20                | 16       | 0         | 0                | Reserve.                     |
| **                    | Bheramara (HVDC )                | Imported power  | 2*500               | 1000     | 726       | 14490909         |                              |
| 106                   | Khulna 115 PP MW (KPCL-2)        | QRPP            | 7*17                | 0        | 0         | 0                | Contract Expired             |
| 107                   | Faridpur 50 MW Peaking PP        | PDB             | 8*6.89              | 54       | 0         | 0                | Reserve.                     |
| 108                   | Khulna 225 MW CCPP               | NWPGCL          | 1*150+1*75          | 230      | 0         | 0                | Reserve.                     |
| 109                   | Copalganj 100 MW Peaking PP      | IPP             | 16*8.98             | 109      | 0         | 0                | Reserve.                     |
| 110                   | Bheramara 410 MW CCPP            | NWPGCL          | 1*278+1*132         | 410      | 410       | 8237952          |                              |
|                       | Noapara 40 MW PP (Khanjahan A    | QRPP            | 5*8.5               | 0        | 0         | 0                | Contract Expired             |
| 111                   | Noapara 100 MW PP (Bangla Tre    | IPP             | 70*1.4              | 100      | 0         | 0                | Reserve.                     |
| 112                   | Rupsha 105 MW PP (Orion rupsh    | IPP             | 6*18.445            | 105      | 35        | 76800            | Low demand.                  |
| 113                   | Madhumati 100 MW PP              | NWPGCL          | 100 MW              | 105      | 0         | 0                | Line O/L                     |
| Khulna Area Total     |                                  |                 |                     | 2129     | 1171      | 22805861         |                              |
| 114                   | Barisal 110 MW PP (Summit )      | IPP             | 7*17.076            | 110      | 0         | 0                | Reserve.                     |
| 115                   | Bhola 33 MW PP (Venture)         | RPP             | 1*34.50             | 33       | 20        | 372400           | Engine problem.              |
| 116                   | Bhola 225 MW CCPP                | PDB             | 2*63+1*68           | 194      | 66        | 1587000          | Machine problem              |
| 117                   | Bhola 95 MW PP (Aggreko)         | QRPP            | 96*1.10             | 95       | 11        | 270446           | Gas shortage                 |
| 118                   | Payra 1320 MW                    | BCPCL           | 2*622               | 1244     | 350       | 7638000          | Line O/L                     |
| 119                   | Bhola Nuran Biddut BD LTD        | IPP             | 220                 | 220      | 180       | 4114282          |                              |
| 120                   | United Payra Power Ltd.          | IPP             | 8*18.5+1*9.5        | 150      | 0         | 0                | Reserve.                     |
| Barisal Area Total    |                                  |                 |                     | 2046     | 627       | 13982128         |                              |
| 121                   | Baghabari 71 MW GTTP             | PDB             | 1*71                | 71       | 0         | 0                | Gas shortage                 |
|                       | Baghabari 100 MW GTTP            | PDB             | 1*100               | 100      | 0         | 0                | Gas shortage                 |
| 122                   | Baghabari 50 MW Peaking PP       | PDB             | 6*8.9               | 52       | 9         | 14480            |                              |
| 123                   | Bera 70 MW Peaking PP            | PDB             | 9*8.29              | 71       | 0         | 0                | Reserve.                     |
| 124                   | Ammura 50 MW PP(Sinha)           | QRPP            | 7*7.79              | 50       | 27        | 101880           | Low demand.                  |
| 125                   | Katakhal 50 MW PP (Northern)     | QRPP            | 6*8.9               | 50       | 0         | 31865            | Reserve.                     |
| 126                   | Katakhal 50 MW Peaking PP        | PDB             | 6*8.7               | 50       | 0         | 9954             | Reserve.                     |
| 127                   | Sirajgonj Unit-1 225MW           | NWPGCL          | 1*150+1*75          | 210      | 0         | 0                | Gas shortage                 |
| 128                   | Sirajgonj Unit-2 225MW           | NWPGCL          | 1*150+1*75          | 220      |           |                  |                              |