

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021				Day : Saturday				Date : 20.11.21				
Probable Maximum Demand : 9200 MW				Probable Maximum Generation : 14514 MW				Rule Curve = 107.10 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 101.97 ft.		Today = 101.85 ft.		19.11.21 (Yesterday)		20.11.21 (Today)		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.11.21 (Yesterday)		20.11.21 (Today)		19.11.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	20.11.21 (Today) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	170	170	170	20		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	53	100	100	102	8	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	313	332	330	350	28	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	327	341	350	400	71		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	100	100	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	160	0	200	220			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	295	255	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	30	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	32	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	21	20	21			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	43	45	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	25	25	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x4.73	33	33	0	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	8	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	66	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	108	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0			
Dhaka Zone Total				5717	5560	1696	1861	3457	3920	466	731	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	110	107	115	115	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	18	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	32	43	43			
41	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	68	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	141	304	300	300			
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	80	100			
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	40	100	80	100			
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	51	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	21	21			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			16	42	15	30			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	68	110	110			
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	60	100	100			
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	0	0	116	116			
Chattogram Zone Total				2442	2382	515	1005	1440	1504	250	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	29	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	196	178	220	220			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	350	300	340	340			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	280	330	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	20	20	55			
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	70	130	133			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	134	136	138			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
71	Cumilla 55 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	22	22			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.086	200	200	0	0	0	200			
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	75	113	113			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impoport (Tripura)	India		160	160	84	94	138	164			
Cumilla Zone Total				3094	3034	1336	1400	2116	2382	505	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	160	189	200	200	13	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	0	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	60	80	200	200			
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
82	Sutakahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22			
Mymensingh Zone Total				717	622	266	291	611	559	13	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.11.21 (Yesterday)		20.11.21 (Today)		19.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT1 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	8	48	50	50				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	60	65	3		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	156	157	160	160	173		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	5	81	80	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	90	120	120	120				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	341	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	241	80	324	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	80	80		100	Under project work	
Sylhet Zone Total						2422	2377	1046	1057	1471	1556	196	130
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	300	410	400	410				
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	105	105				
107	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	679	726	727	727				
Khulna Zone Total						2133	2129	979	1171	1282	1732	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	20	28	30				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	66	66	90	90		128	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	350	620	620		894	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyt BCL)	Gas/HSD (IPP)	2x75+1x70	220	220	171	180	220	220				
Barishali Zone Total						2046	2046	512	627	1080	1232	0	1022
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	9	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	95	95				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	50				
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	20	35				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	183	168	200	200	52		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	0	0	0	0			Under Maint.	
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	403	350	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	18	18				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	70	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	100	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2179	2179	617	757	1335	1434	433	0
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	77	80	80	82	5		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	22	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total						685	605	84	102	201	195	5	359
Sub-total: Plants in operation						21435	20934	7051.0	8271	12993	14514	1868	2657
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6859	8046	12639	14119				
(B) Plants under long term maintenance/ contract expired													
140	Katpolti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0			
Gross Total						22031	20934	7051	8271	12993	14514	1868	2657
(C) Actual data of 19.11.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	8271.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	8046.00	MW,	at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	8271.00	MW,	at =	19:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	6270.00	MW,	at =	7:00 hrs	Dhaka	2845	2845	0	Myrmensingh	670	670
05.	Day-peak Generation (Generation end)	:	7051.00	MW,	at =	12:00 hrs	Chattogram	1034	1034	0	Sylhet	330	330
06.	Evening-peak Generation (Generation end)	:	8271.00	MW,	at =	19:00 hrs	Khulna	937	937	0	Barishal	230	230
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	782	782	0	Rangpur	543	543
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5815.00	MW,	at =	5:00 hrs	Cumilla	675	675	0			
09.	Generation shortfall at evening peak due to :	:									Total	8046	8046
a)	Gas limitation	:	1863	MW			13.	Fuel cost :	(a) Gas =	136429059	Taka	(c) Coal =	44726884
b)	Coal supply Limitation	:	5	MW					(b) Oil =	100690068	Taka	Total =	281846011
c)	Low water level in Kaplai lake	:	0	MW									Taka
d)	Plants under shut down/ maintenance	:	2657	MW			14.	Maximum Temperature in Dhaka was :		30.8° C			
10.	Total Energy (Generation + India Import)	:	171.37	MKWh			15.	Export through East-West interconnections :					
	By Gas =	128.295	MKWh	By Oil =	13.961	MKWh		At evening peak-hour	:	64	MW,	at	19:00 hrs
	By Coal =	9.495	MKWh	By Hydro =	2.408	MKWh		Maximum	:	-62	MW,	at	12:00 hrs
	By Solar =	0.722	MKWh					Energy	:	0.1415	MKWh		
11.	Total Gas Supplied	:	993.00	MMCFD									
(D) Forecast of 20.11.21 (Today) Saturday :													
01.	Maximum Demand	:	9200	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14514	MW	(Generation end)		05.	Total Generation	:	190.62	MKWh		
03.	Maximum Shortage	:	-5314	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	28.7° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation