

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021				Day : Wednesday				Date : 24.11.21				
Probable Maximum Demand : 10300 MW				Probable Maximum Generation : 13553 MW				Rule Curve = 106.70 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 101.45 ft.				Today = 101.39 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.11.21 (Yesterday)		24.11.21 (Today)		23.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	20	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	123	82	150	180	278	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	322	327	350	350			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	150	150	0	0	185	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	265	285	150	150			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	20	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	23	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	64	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	21	21			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x6.73	80	80	50	43	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	30	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	9	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	34	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	82	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	155	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	80	105	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	35	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	88	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	25	0	30	0			
Dhaka Zone Total				5717	5560	2005	2405	2793	3143	981	660	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	87	79	70	79		40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	30	45	46	46			
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	102	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	300	300	300	300			
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	70	80	100			
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	80	100			
47	Dohazari-Kalashish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20			
50	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	5	10	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	90	90			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	95	110	110	110			
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	8	24	116	116			
Chattogram Zone Total				2442	2382	1022	1191	1392	1445	250	415	
56	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
57	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
58	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	70	70	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	29	29	29			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	216	195	220	220			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	315	340	340			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	55	55	55			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	167	150	160	160	45	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	40	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	15	120	125			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	91	90	90			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	22	76	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	52	52			
74	Cumilla 52 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	10	10			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200			
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	52	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	64	115	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
79	Impoort (Tripura)	India		160	160	93	110	138	164			
Cumilla Zone Total				3094	3034	1186	1345	1895	2126	443	360	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	137	151	150	150	51	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	24	115	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	45	127	200	200			
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0			
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22			
Mymensingh Zone Total				717	622	241	348	561	509	51	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.11.21 (Yesterday)		24.11.21 (Today)		23.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	10	42	41	42		28	GT1 Load gear problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30		60			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	53	50	50					
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	31	31	33					
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	154	153	160	160	177		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	80	80	84					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	211	218	200	200					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	295	341	341					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	344	390	400	400					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.		
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	80	100	100	100					
Sylhet Zone Total				2422	2377	1430	1600	1659	1666	197	88			
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	410	410	410					
102	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30					
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40					
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	85	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	0	0	100					
**	Bheramara (HVDC)	India		1000	1000	736	727	751	751					
Khulna Zone Total				2133	2129	1186	1242	1316	1756	0	0			
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	21	25	25					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	79	91	90	90		103	Under maint.		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	42	42					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	330	620	620		914	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	141	214	220	220					
Barishal Zone Total				2046	2046	531	667	1107	1257	0	1017			
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	3	0	30	30					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	22	95	95					
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	40					
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	0	50					
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	20	35					
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Under Overhauling		
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	170	178	200	220	42		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	399	419	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	18	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	35	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	50	109	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total				2179	2179	686	1034	1335	1458	433	210			
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	81	80	80					
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	25	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabula 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
Rangpur Zone Total				685	605	109	194	201	193	0	359			
Sub-total: Plants in operation				21435	20934	8396.0	10026	12259	13553	2355	3109			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8248	9849	12042	13314					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired				596	0	0	0	0	0					
Gross Total				22031	20934	8396	10026	12259	13553	2355	3109			
(C) Actual data of 23.11.21 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	10026.00	MW,	at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9849.00	MW,	at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10026.00	MW,	at =	18:00 hrs	Dhaka	3818	3818	0	Mymensingh	728	728	0
04.	Minimum Generation (Generation end)	:	6450.00	MW,	at =	5:00 hrs	Chattogram	1339	1339	0	Sylhet	340	340	0
05.	Day-peak Generation (Generation end)	:	8396.00	MW,	at =	12:00 hrs	Khulna	1096	1096	0	Barisal	237	237	0
06.	Evening-peak Generation (Generation end)	:	10026.00	MW,	at =	18:00 hrs	Rajshahi	881	881	0	Rangpur	620	620	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	18:00 hrs	Cumilla	790	790	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6582.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	2355	MW			13.	Fuel cost :	(a) Gas = 141931983 Taka	(c) Coal = 48314388 Taka				
d)	Coal supply Limitation	:	0	MW				(b) Oil = 254373790 Taka	Total = 444620162 Taka					
b)	Low water level in Kapitai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	3109	MW			14.	Maximum Temperature in Dhaka was :	31.8° C					
10.	Total Energy (Generation + India Import)	:	197.20	MKWh			15.	Export through East-West interconnections :						
	By Gas =	130.038	MKWH					At evening peak-hour	:	176	MW,	at	18:00 hrs	
	By Coal =	10.286	MKWH					Maximum	:	-138	MW,	at	8:00 hrs	
	By Solar=	0.585	MKWH					Energy	:	0.1235	MKWh			
11.	Total Gas Supplied	:	1001.60	MMCFD										
(D) Forecast of 24.11.21 (Today) Wednesday :														
01.	Maximum Demand	:	10300	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13553	MW	(Generation end)		05.	Total Generation	:	202.59	MKWh			
03.	Maximum Shortage	:	-3253	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	28.9° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation