

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2021					Day : Friday				Date : 26.11.21				
Probable Maximum Demand : 9000 MW					Probable Maximum Generation : 13209 MW					Rule Curve = 106.50 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 101.33 ft.				Today = 101.27 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.11.21 (Yesterday)		26.11.21 (Today)		25.11.21 (Yesterday)		26.11.21 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0		108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	62	0	150	250		360	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270		180	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	285	347	350	350				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	150	150	150	150				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	24	25	25				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	22	22	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x6.73	80	80	49	50	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	17	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	32	100	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	298	300	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	112	143	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300				
28	Bramhangan: 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
30	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	53	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	27	0	30	0				
Dhaka Zone Total					5717	5560	2132	2403	2799	3219	1213	1025	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	81	72	75	75		40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	0	5	0				
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	14	25	25				
39	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	45	46	46				
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	19	51	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	300	300	300	300				
45	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	5	40	80	100				
46	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	100	100	100				
47	Dohazari-Kalashish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20				
50	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	6	30	40				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90				
52	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
53	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	94	110	110	110				
54	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	40	100	100	100				
55	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	1	17	116	116				
Chattogram Zone Total					2442	2382	735	978	1327	1361	0	775	
56	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage	
57	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129	Gas Shortage	
58	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	90	100	100	100		34	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	29	29				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	217	183	220	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	300	340	340				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	51	55	55				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	45	45	75	75		150	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	138	120	138				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	88	90	90				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	154	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	33	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	10	10				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.015+1x1.086	200	200	0	0	0	200				
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	114	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
79	Impoort (Tripura)	India		160	160	96	99	138	164				
Cumilla Zone Total					3094	3034	1277	1516	1840	2084	448	360	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	135	144	164	164		58	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap : 8MW	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	16	16	115	115				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	90	140	200	200				
85	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0				
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensingh Zone Total					717	622	333	346	575	523	58	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.11.21 (Yesterday)		26.11.21 (Today)		25.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	GT1 Coupling problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT4 Load gear problem	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	53	50	50				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	33	33	33				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	148	149	100	100	181		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	77	80	84				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	218	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	341	341				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	402	400	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	70	68	100	100				
Sylhet Zone Total				2422	2377	1501	1570	1622	1626	201	88		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0				
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Bheramara (HVDC)	India		1000	1000	720	721	645	693				
Khulna Zone Total				2133	2129	825	826	800	1288	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	25	25	25				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	67	90	90		127	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	42	42				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	330	400	620	620		844	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BCL)	Gas/HSD (IPP)	2x75+1x70	220	220	151	220	220	220				
Barishal Zone Total				2046	2046	571	723	1107	1257	0	971		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	0	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	27	27	27	27				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	100	95	95				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	0	0	40				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	50	43	0	50				
124	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	36	20	35				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Under Overhauling	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	219	182	200	220	38		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	77	200	200	143		Gas Shortage	
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	334	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	108	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	40	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2179	2179	651	1110	1539	1658	352	210		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	80	80	80				
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	112	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabula 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total				685	605	196	192	201	193	0	359		
Sub-total: Plants in operation				21435	20934	8221.0	9664	11810	13209	2272	3788		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7834	9209	11254	12587				
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				596	0	0	0	0	0				
Gross Total				22031	20934	8221	9664	11810	13209	2272	3788		
(C) Actual data of 25.11.21 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	9664.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	9209.00	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	9664.00	MW,	at =	19:00 hrs	Dhaka	3603	3603	0	Mymensingh	684	684
04.	Minimum Generation (Generation end)	:	6354.00	MW,	at =	5:00 hrs	Chattogram	1121	1121	0	Sylhet	334	334
05.	Day-peak Generation (Generation end)	:	8221.00	MW,	at =	12:00 hrs	Khulna	1039	1039	0	Barishal	254	254
06.	Evening-peak Generation (Generation end)	:	9664.00	MW,	at =	19:00 hrs	Rajshahi	836	836	0	Rangpur	584	584
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	754	754	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6255.00	MW,	at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:											
a)	Gas limitation	:	2272	MW			13.	Fuel cost :	(a) Gas = 123700318 Taka	(c) Coal = 51693371 Taka			
d)	Coal supply Limitation	:	0	MW				(b) Oil = 351411115 Taka	Total = 526804804 Taka				
b)	Low water level in Kapitai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	3788	MW			14.	Maximum Temperature in Dhaka was :	30.2° C				
10.	Total Energy (Generation + India Import)	:	191.59	MKWh			15.	Export through East-West interconnections :					
	By Gas = 112.811 MKWh							At evening peak-hour	:	-2	MW,	at	19:00 hrs
	By Coal = 11.055 MKWh							Maximum	:	-466	MW,	at	8:00 hrs
	By Solar= 0.638 MKWh							Energy	:	0.909	MKWh		
11.	Total Gas Supplied	:	864.74	MMCFD									
(D) Forecast of 26.11.21 (Today) Friday :													
01.	Maximum Demand	:	9000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13209	MW	(Generation end)		05.	Total Generation	:	178.43	MKWh		
03.	Maximum Shortage	:	-4209	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	27.3° C			

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation