

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 29-Nov-21		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4504500	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	336	8601600	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	240	1794000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6419250	Gas shortage
9	Meghnaghat 100 MW(IEL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3619113	Gas shortage
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	171386	Low demand.
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	25	125079	Engine problem
14	Narsingh 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	338508	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirganj 335 MW CCPP	EGCB	1*217+1*18	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	437184	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1048680	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	93600	Low demand.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	440232	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	53	850281	
25	Bosila 108MW PP(RCL)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	43	1239540	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	722000	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	817300	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	52	145920	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	185	923345	Low demand.
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangon 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	96	568800	Low demand.
36	Gazipur 100 MW PP	RPCL	100 MW	105	50	1164000	Low demand.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1813440	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3097440	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	209888	
Dhaka area Total				5560	2340	39145066	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Razcan 25 MW PP	IPP	3*8.9	25	15	157172	Engine problem
42	Teknaf 20MW PP (Solartech)Teknaf	Solartech Energ	20	20	0	121500	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	30	677280	
44	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	106	2342991	Low water level & #2 Under n
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	75	465854	High Voltage.
48	Hatibazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dobhazari-Kalshah 100 MW Peakir	PDB	6*17	102	51	110407	Low demand.
50	Juidah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	40	78240	High Voltage.
51	Juidah 100 MW PP Unit-3 (Acorn	IPP	0	100	100	1213440	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	18	432144	Engine problem
	* Malancha, Cig, EP2 (United)		5*8*73+3*9.34	0	5	422880	
53	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	45	107520	High Voltage.
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25318	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	300	6297818	
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1301405	
57	Karnaphuli Power Ltd.	IPP	110	110	103	1684430	
58	Juidah unit-2 (Acorn)	IPP	8*13.6	100	80	145920	High Voltage.
59	Antima Energy Ltd.	IPP	6*21.2	116	90	1992218	High Voltage.
Chattogram area Total				2382	1112	17576537	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	120	2875166	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	218	4602000	FGMO
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	Ashuganj 400 kV Bus S/D
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	265	7140000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	664200	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	50	1091040	
66	Ashuganj 195MW PP (APSCL-UN	IPP	20*9.73+1*16	195	68	1722909	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1043808	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	118	1834981	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
70	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	86	2129450	Machine problem
71	Chandpur 200MW (Desh energy)	IPP	0	200	58	267840	Low demand.
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	513036	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	233460	Engine problem
**	Impoport (Tripura)	Imported power	0	160	107	2118720	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	700700	
75	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	43	441605	
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	208960	Engine problem
77	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	52	95760	High Voltage.
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	65	1047480	High Voltage.
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	438120	33 kV feeder fault.
	Chandpur 115(Doreen)	IPP	115	0	4	87360	On test
Cumilla Area Total				3034	1423	29256595	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	131	3361920	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	509472	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Engine problem
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13700	
85	Mymensingh 200 MW PP (United	IPP	200	200	39	98400	High Voltage.
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	88	1320000	High Voltage.
87	Sutakhal 50 MW Solar PP	IPP	50	50	0	303480	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	22	356980	
Mymensingh Area Total				622	302	5857852	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	41	980000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	708240	Machine problem
91	Kushiar 163 MW CCPP (KP)	IPP	1*109+1*54	163	120	3569809	frequency control.
92	Shajibazar 330 MW CCPP	PDB	3*110	330	142	3022000	GT-1 under maint
93	Fenchugonj 51 MW PP (Barakati	RPP	19*2.90	51	50	1106400	
94	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	134100	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	33	673344	GT-8 under maint
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	77	1541760	
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	80	1993873	Gas shortage
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	191	4835980	
99	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	532656	
101	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	280	7274000	FGMO
102	Bibiyana-III - 400 MW CCPP	PDB	400 MW	400	400	9196000	
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	252900	
104	Bibiyana South 400 MW	PDB	400 MW	383	0	526000	Under maint.
Sylhet Area Total				2377	1486	36350662	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	723	14884363	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Gopaldang 100 MW Peaking PP	PDB	16*6.98	109	0	2432	Reserve.
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Under maint.
	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	0	0	Reserve.
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	863040	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khulna Area Total				2129	828	15748835	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	20	399000	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	66	1576000	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	265779	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	330	8576500	Line O/L
119	Bhola Nutan Bidrut BD LTD	IPP	220	220	219	4394673	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total				2046	646	15211952	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
122	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	16	38720	Low demand.
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
124	Amnura 50 MW PP (Sinha)	ORPP	7*7.79	50	27	84200	Engine problem
125	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	24	65144	Low demand.
126	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	16	23516	Low demand.