

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel:- 9564667, 9551095

Month December, 2021				Day : Sunday				Date : 05.12.21						
Probable Maximum Demand : 9600 MW				Probable Maximum Generation : 12926 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 100.42 ft Today = 100.28 ft Rule Curve = 105.64 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.12.21 (Yesterday)		05.12.21 (Today)		04.12.21 (Yesterday)		05.12.21 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x4.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		CB Problem	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	212	300	320		148		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	67	400	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	95	60	95	115			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	140	140	140	140					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	25	55	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	24	24	25	25					
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	18	18	18					
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.07+1x4.73	80	80	50	54	55	55					
19	Mona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	25	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	149	149	149					
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	160	260	300	300					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	52	149	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300					
28	Biraniganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	0	100	100					
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	27	25	50	100					
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162					
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	5	0	30	0					
	Kanchan Purbachal Power Generation	HFO (IPP)			26	0	0	0	0					
Dhaka Zone Total				5717	5560	1665	2408	3037	3424	906	1025			
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	72	73	80	80		40		Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0					
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	25	25					
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0					
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	50	50	50	50					
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	0	51	105	105					
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	280	300	300	300					
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	50	100	100					
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	50	100	100	100					
47	Dohazari -Kalesh 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	80					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	21					
	* Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			2	3	5	10					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	90	90					
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110	110					
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	0	60	100	100					
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	50	105	116	116					
Chattogram Zone Total				2442	2382	662	1061	1331	1341	0	775			
55	a) Ashuganj TPP Unit- 3	Gas (APSCS)	1 x 150	150	135	0	0	0	0		135		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCS)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCS)	1 x 150	150	134	130	130	130	130					
56	Ashuganj 50 MW PP	Gas (APSCS)	14x3.968	53	45	29	29	29	29					
57	Ashuganj 225 MW CCPP	Gas (APSCS)	1x142+1*75	221	221	0	0	0	0					
58	Ashuganj 450 MW CCPP(South)	Gas (APSCS)	1x360	360	360	280	300	360	360					
59	Ashuganj 450 MW CCPP(North)	Gas (APSCS)	1x361	360	360	0	0	0	0		360		Under maint.	
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	56	55	55					
61	Ashuganj 195MW PP (APSCS-United)	Gas (IPP)	20*9.73+1*16	195	195	187	180	180	180	15			Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51					
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	33	125	123	132					
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50					
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	15	34	200	200					
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22					
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	30	52	52	52					
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	7	9	9	9					
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+15x1.086	200	200	0	0	0	200					
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	58	116	113	113					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
	Chandpur 115(Doreen)	HFO (IPP)				28	0	0	0				On Test	
**	Impoport (Tripura)	India		160	160	93	103	138	164					
Cumilla Zone Total				3094	3034	1027	1310	1687	1922	279	523			
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	158	139	160	160	63			Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	22	22					
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	115	115	115					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	32	200	200					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
82	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0					
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22					
Mymensingh Zone Total				717	622	299	330	571	519	63	0			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.12.21 (Yesterday)		05.12.21 (Today)		04.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		28	GT1 Coupling problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30		60	GT4 reduction gear problem	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	53	50				
87	Kushira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	30	33				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	130	330		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	77	80				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	198	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	20	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	383				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	80	80	80				
Sylhet Zone Total					2422	2377	1138	1136	1272	1276	330	88
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0		410	Under maint.	
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30			
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	50	100			
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105			
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100			
**	Bheramara (HVDC)	India		1000	1000	656	704	653	701			
Khulna Zone Total					2133	2129	673	809	808	1296	0	410
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	26	20	23			
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	60	65	65		134	Under maint.
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	52	94	70	72			
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	470	620	620		774	Line Overload
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
114	Bhola 220MW CCPP (Nutan Bidyut BCL)	Gas/HSD (IPP)	2x75+1x70	220	220	109	110	110	110			
Barisal Zone Total					2046	2046	560	760	995	1150	0	908
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	50	50			
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30			
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	27	27			
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	98	95	100			
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40			
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	0	50			
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	20	35			
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Under Overhauling	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	199	181	200	220			
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	208	201	200	200			
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	358	400	400			
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	24	52	52	52			
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113			
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	50	113	113	113			
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
Rajshahi Zone Total					2179	2179	944	1277	1539	1663	171	210
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	82			
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	133	134	140	140	140	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	49	105	113	113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
Rangpur Zone Total					685	605	267	318	341	335	0	225
Sub-total: Plants in operation					21435	20934	7235.0	9409	11581	12926	1749	4164
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					6925	9006	11085	12372				
(B) Plants under long term maintenance/ contract expired												
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0			
Gross Total					22031	20934	7235	9409	11581	12926	1749	4164
(C) Actual data of 04.12.21 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	9409.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9006.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	9409.00 MW, at = 19:00 hrs	Dhaka	3413	3413	0	Mymensingh	692	692	0	
04.	Minimum Generation (Generation end)	:	5694.00 MW, at = 5:00 hrs	Chattogram	1059	1059	0	Sylhet	335	335	0	
05.	Day-peak Generation (Generation end)	:	7235.00 MW, at = 12:00 hrs	Khulna	1028	1028	0	Barisal	253	253	0	
06.	Evening-peak Generation (Generation end)	:	9409.00 MW, at = 19:00 hrs	Rajshahi	873	873	0	Rangpur	601	601	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:00 hrs	Cumilla	752	752	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6053.00 MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:										
a)	Gas limitation	:	1749 MW	13.	Fuel cost :	(a) Gas = 109977577 Taka	(c) Coal = 71062820 Taka					
b)	Coal supply Limitation	:	0 MW		(b) Oil = 297246909 Taka	Total = 478287306 Taka						
c)	Low water level in Kapali lake	:	0 MW									
d)	Plants under shut down/ maintenance	:	4164 MW	14.	Maximum Temperature in Dhaka was :	26.7° C						
e)	Total Energy (Generation + India Import)	:	178.05 MKWh	15.	Export through East-West interconnections :							
	By Gas = 103.682 MKWh		By Oil = 42.678 MKWh		At evening peak-hour :	221 MW, at 19:00 hrs						
	By Coal = 14.699 MKWh		By Hydro = 1.632 MKWh		Maximum :	20 MW, at 8:00 hrs						
	By Solar = 0.290 MKWh				Energy :	0.005 MKWh						
11.	Total Gas Supplied	:	848.05 MMCFD									
(D) Forecast of 05.12.21 (Today) Sunday :												
01.	Maximum Demand	:	9600 MW (Generation end)	04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	12926 MW (Generation end)	05.	Total Generation	:	181.66 MKWh					
03.	Maximum Shortage	:	-3326 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	22.2° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation