

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 7-Dec-21							Page -2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
5	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	392	8099830	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	321	6184000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6647300	Gas shortage
9	Meghnaghat 100 MW(IEI)	QRPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat 100 MW PP(Summit)	IPP	2*110+1*110	305	150	3611084	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	495374	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	23	120726	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	18	339192	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 210 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	0	0	0	Contract Expired
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	72	887904	High Voltage.
20	Kaipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	648720	Engine problem
22	Kodda 150MW PP	RPDB-RPCL	9*17.06	149	82	583200	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	594196	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	880898	
25	Bosila 108MW PP(PLC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power.(Madhabad+Ashulia)	SIPP,REB	3*3.67+4*8.73	80	55	1222440	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	665000	
28	Rugganji 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	840200	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	50	593040	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	245	2559272	Low demand.
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramhanaganj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
34	Auralhati 100MW PP (Aggreko)	IPP	0.85*223+95*91	0	100	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	114	1306800	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	17	110400	High Voltage.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1850880	
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2916000	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	54816	
Kanchan Purbanchal Power Generation Ltd.			IPP	55	0	29160	On test
Dhaka area Total				5560	2523	45681932	
40	Chattoagram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattoagram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	3*8.9	25	0	6859	Reserve.
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	67500	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	25	569760	Low demand.
44	Kapila Hydrr Unit-1,2,3,4, 5	PDB	2*40+2*50	230	72	1719640	Low water level & #2 Under n
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	169781	High Voltage.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	180263	Low demand.
50	Juidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	76320	High Voltage.
51	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1302720	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	473616	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	12	476160	
53	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	261120	High Voltage.
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	8400	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	300	5755895	
56	Jodica Power	IPP	3*18.55+1*3.6	54	54	1348627	
57	Kamagphuli Power Ltd.	IPP	110	110	110	1252867	
58	Juidah unit-2 (Acorn)	IPP	8*13.6	100	40	436900	High Voltage.
59	Anilma Energy Ltd.	IPP	6*21.2	116	105	1664782	High Voltage.
Chattoagram area Total				2382	890	15772070	
60	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Gas shortage
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	1542772	Under maint.
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*175	221	0	0	Under maint. (REF)
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	Under maint.
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	300	6967000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	662184	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1273920	
66	Ashuganj 195MW PP (APSCL-United)	IPP	20*7.9+1*116	185	200	4761262	
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1241304	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	117	1366612	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	36136	Reserve.
70	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
71	Chandpur 200MW (Desh energy)	IPP	0	200	17	236640	High Voltage.
72	Feni 224MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	434304	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	129420	
**	Import (Tirupura)	Imported power	0	160	94	1891200	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	731100	
75	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	497189	
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	233870	Engine problem
77	Daudkandi 200 MW PP (B.Trac)	IPP	15*41.4	200	0	0	Reserve.
78	Feni Lanka Power	IPP	7*18.40+1*9.78	0	114	0	Reserve.
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	115	1455720	
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	402480	33 kV feeder O/L
	Chandpur 115(Doreen)	IPP	115	0	0	256320	On test
Cumilla Area Total				3034	1117	24125443	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	110	3000000	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	436320	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	9	0	0	Under maint.
84	Sarisababari 3 MW Solar Plant	IPP	1*3	3	0	6000	
85	Mymensingh 200 MW PP (United)	IPP	200	200	64	307200	High Voltage.
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	95	1570800	High Voltage.
87	Sutikhal 50 MW Solar PP	IPP	50	50	0	116160	
88	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	315600	
Mymensingh Area Total				622	315	5782080	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	990000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	45	1029480	Machine problem
91	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3586745	
92	Shajibazar 330 MW CCPP	PDB	3*110	330	103	3401000	GT-1 sync at 18:06
93	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1117200	
94	Fenchugonj 44MW (Energiyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
95	Hobaganj 11MW PP (Confidence-E	SIPP, REB	4*2.90	11	11	187100	
96	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	69	1455552	
97	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	81	1614720	
98	Shahjibazar 100 MW GTTP	PDB	1*100	100	60	1527527	On test
99	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	191	4555780	Gas shortage
100	Sylhet 20 MW GTTP	PDB	1*20	20	18	415000	Gas shortage
101	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	497352	
101	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
102	Bibiyan-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	238140	
104	Bibiyan South 400 MW	PDB	400 MW	383	400	9217300	
Sylhet Area Total				2377	1271	29840896	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	707	14008000	
106	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
107	Fardipur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
108	Khulna 225 MW CCPP	NWPGLCL	1*150+1*75	230	0	0	Reserve.
109	Gopaganj 100 MW Peaking PP	PDB	16*98	109	0	7805	Reserve.
110	Bheramara 410 MW CCPP	NWPGLCL	1*278+1*132	410	0	0	Under maint.
	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
112	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	989290	
113	Madhumati 100 MW PP	NWPGLCL	100 MW	105	0	0	Line O/L
Khulna Area Total				2129	812	15005085	
114	Barsail 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	24	392700	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	65	1524000	Machine problem
117	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	279780	Engine problem
118	Payra 1320 MW	BCPCL	2*622	1244	420	8997100	Line O/L
119	Bhola Nutan Siddut BD LTD	IPP	220	220	211	4568427	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total				2046	731	15762007	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
122	Baghabari 50 MW Peaking PP	PDB	6*8.9</				