

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Dec-21			Page -2				
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-7	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	190	4441500	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	30	873136	ST start up process
4	Ghorasal 78.5 MW PP(RIMAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	335	8822780	Frequency control
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	342	7298000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6646050	Gas shortage
9	Meghnaghat 100 MW(IEL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	140	3505367	Gas shortage
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	38	173042	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	24	200397	Engine problem
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	446148	Engine problem
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirganj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	925776	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Bancoo En	IPP	3*18	54	35	877680	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	82	1681440	Low demand.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	459242	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	723113	Engine problem
25	Bosila 108MW PP(RCLC)	IPP	12*8.75+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	42	1127040	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	760600	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	641700	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	51	701760	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit	IPP	18*17.076	300	280	1259563	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit	IPP	149	149	106	604800	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	52	140400	High Voltage.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1913280	
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	3216860	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	163002	
Kanchan Purbachal Power Gener				IPP	55	0	82800
Dhaka area Total					5560	2544	47685576
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Razzan 25 MW PP	IPP	3*8.9	25	8	40032	Low demand.
43	Teknaf 20MW PP (SolarTech)Teknaf	SolarTech, Energy	20	20	0	111915	
44	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	707520	
45	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	71	1527080	Low water level & #2 Under m
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	17	200727	High Voltage.
49	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under S/D
50	Dohazari -Kaleash 100 MW Peakin	PDB	6*17	102	51	233512	Low demand.
51	Juldah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	10	36840	Low demand.
52	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	1262400	
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	499680	
54	Malancha, Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	10	501600	
55	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	45	186950	High Voltage.
56	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	15479	
57	Anwara 300 MW PP (United)	IPP	300 MW	300	300	6636545	
58	Jodiac Power	IPP	3*18.55+1*3.6	54	37	1275266	Engine problem
59	Karnaphuli Power Ltd.	IPP	110	110	110	1792319	
60	Juldah unit-2 (Acorn)	IPP	8*13.6	100	40	216960	High Voltage.
61	Anilma Energy Ltd.	IPP	6*21.2	116	87	1780200	
Chattogram area Total					2382	947	17607035
62	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
63	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
64	Ashuganj TPP Unit- 5	APSCL	1*150	134	130	3135634	
65	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	0	0	#REF!
66	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	Under maint.
67	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	7036000	FGMO
68	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	694152	Engine problem
69	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1328160	
70	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	200	4733818	
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	40	1185918	
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	91	883200	Low demand.
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	42	34928	Engine problem
74	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
75	Chandpur 200MW (Dash energy)	IPP	0	200	48	418560	High Voltage.
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	454284	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	178200	
78	** Imoport (Tripura)	Imported power	0	160	106	2118720	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	771300	
80	Jangalia 52 MW PP (Lakadnawi)	IPP	6*8.92	52	52	619373	
81	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	209130	Engine problem
82	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	115	1741320	
85	Bhairab 54.5 MW	IPP	3*18.2	54	17	444600	33 kV feeder O/L
Chandpur 113(Doreen)				IPP	115	0	0
Cumilla Area Total					3034	1264	25897297
86	RPCL 210MW CCPP	IPP	4*35+1*70	202	110	285760	Gas shortage
87	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	463644	
88	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
89	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11400	
90	Mymensingh 200 MW PP (United	IPP	200	200	41	208800	High Voltage.
91	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1983609	
92	Sutakhal 50 MW Solar PP	IPP	50	50	0	280000	
93	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	162720	
Mymensingh Area Total					622	312	5995933
94	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1002000	Machine problem
95	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	44	1041360	Machine problem
96	Kushlara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3285655	
97	Shahjibazar 330 MW CCPP	PDB	3*110	330	120	2850000	Engine problem
98	Fenchugonj 51 MW PP (Barakati	RPP	19*2.90	51	53	1251000	
99	Fenchugonj 44MW (Energyprima	RPP	12*3.5+5*2	0	0	0	Contract Expired
100	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	234048	
101	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	40	1142880	
102	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	78	1813440	Engine problem
103	Shahjibazar 100 MW GTTP	PDB	1*100	100	64	1622418	On test
104	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	190	4180510	Gas shortage
105	Sylhet 20 MW GTTP	PDB	1*20	20	18	405000	Gas shortage
106	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
107	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	462744	
108	Bibiana-II 341 MW CCPP (Summit	IPP	1*222+1*119	341	0	0	Under maint.
109	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
110	Sylhet 10MW PP (Desh)	IPP	6*1.95	10	10	240680	
111	Bibiyana South 400 MW	PDB	400 MW	383	400	8968100	
Sylhet Area Total					2377	1258	28515815
112	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	701	14016000	
114	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
115	Faridpur 50 MW Peaking PP	PDB	6*8.89	54	0	0	Reserve.
116	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
117	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
118	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	355	6183360	FGMO
119	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
120	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	0	0	Reserve.
121	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	70	535680	High Voltage.
122	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khulna Area Total					2129	1126	20725040
123	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
124	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	23	465500	Engine problem
125	Bhola 225 MW CCPP	PDB	2*63+1*68	194	50	1381000	Machine problem
126	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	280625	Engine problem
127	Payra 1320 MW	BPCLP	2*622	1244	290	8436500	Line O/L
128	Bhola Nuten Bickit BD LTD	IPP	220	162	162	4275491	High Voltage.
129	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total					2046	536	14839116
130	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
131	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
132	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	43	79229	Engine problem
133	Bara 70 MW Peaking PP	PDB	6*8.28	71	11	30651	Machine problem
134	Armura 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	Reserve.
135	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	50	83287	
136	Katakhal 50 MW Peaking PP	PDB	6*8.7	50</			