

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 10-Dec-21			Page -2				
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	2110500	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	380	6423291	
5	Ghorasal 78.5 MW PP(RIMAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	349	7968770	Frequency control
9	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	352	6780000	
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6645050	Gas shortage
11	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3628480	Gas shortage
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	0	29336	Reserve.
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	25	272079	Engine problem
16	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	328068	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	16	314640	Low demand.
22	Katpottti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	826560	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	20160	Reserve.
25	Keraniganj 55 MW PP (Northern)	IPP	3*19.3	55	17	103016	Low demand.
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	534703	Engine problem
27	Bosila 108MW PP(RCL)	IPP	12*8.75+1*3.5	0	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	49	1111740	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	767000	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	796300	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	25	129600	Low demand.
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	30	178145	Low demand.
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
35	Bramhangon 100 MW PP (Aggarwal)	IPP	100	100	0	0	Reserve.
36	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	29	221900	High Voltage.
38	Gazipur 100 MW PP	RPCL	100 MW	105	0	0	Reserve.
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1242240	
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2396160	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	137609	
Kanchan Purbachal Power Generation				55	0	154440	On test
Dhaka area Total				5560	2102	43119787	
42	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	0	55386	Reserve.
45	Teknaf 20MW PP (Solaratech)	Solaratech Energy	20	20	0	131220	
46	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	25	615360	Low demand.
47	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	72	1653000	Low water level & #2 Under maint.
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka South)	IPP	105 MW	105	0	0	Reserve.
51	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari -Kalaish 100 MW Peakir	PDB	6*17	102	51	197961	Low demand.
53	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	0	Reserve.
54	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	10	363840	Low demand.
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	496128	
56	Malancha Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	42	784800	
57	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	12	41280	High Voltage.
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	21602	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	225	5266582	Low demand.
60	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1308219	
61	Karnaphuli Power Ltd.	IPP	110	110	34	671597	Low demand.
62	Juldah unit-2 (Acorn)	IPP	8*13.6	100	0	0	Reserve.
63	Anilma Energy Ltd.	IPP	6*21.2	116	51	1126582	Low demand.
Chattogram area Total				2382	587	12733557	
64	Ashuganj TPP Unit-3	APSCL	1*150	133	0	0	Gas shortage
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	90	3135634	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1*142+1*175	221	123	1186000	#REF!
68	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	Gas shortage
69	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	310	7360000	FGMO
70	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	639286	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1106400	
72	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	185	3646545	
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	900474	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	115	978545	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
76	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
77	Chandpur 200MW (Dash energy)	IPP	0	200	17	107520	Low demand.
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	467568	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	197460	Engine problem
80	Import (Tripura)	Imported power	0	160	90	1864320	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	808600	
82	Jangalia 52 MW PP (Lakshadweep)	IPP	6*9.92	52	32	405893	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	203830	Engine problem
84	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	84	1554840	High Voltage.
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	433080	33 kV feeder O/L
88	Chandpur 115(Doreen)	IPP	115	0	0	0	On test
Cumilla Area Total				3034	1260	24959597	
89	RPCL 210MW CCPP	IPP	4*35+1*70	202	138	3036480	Gas shortage
90	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	486504	
91	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11400	
93	Mymensingh 200 MW PP (United)	IPP	200	200	16	55200	High Voltage.
94	Jamalpur 115 MW PP (United)	IPP	115 MW	115	84	1429520	Low demand.
95	Sultakhal 50 MW Solar PP	IPP	50	50	0	215470	
96	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	294960	
Mymensingh Area Total				622	284	5529214	
97	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	42	993000	Machine problem
98	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	44	1034880	Machine problem
99	Kushlara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	910800	
100	Shahjibazar 330 MW CCPP	PDB	3*110	330	121	2850000	Engine problem
101	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	25	516400	
102	Fenchuganj 44MW (Energyprima)	RPP	12*3.5+5*2	0	0	0	Contract Expired
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	238896	
104	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	40	954240	Frequency control
105	Shahjibazar 96MW PP (Shahjibazar)	RPP	32*2.90	86	81	1425600	
106	Shahjibazar 100 MW GTTP	PDB	1*100	100	70	1674691	On test
107	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	190	4285010	
108	Sylhet 20 MW GTTP	PDB	1*20	20	18	407000	
109	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
110	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	23	520224	
111	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
112	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
113	Sylhet 10MW PP (Dash)	RPP	6*1.95	10	10	248940	
114	Bibiyana South 400 MW	PDB	400 MW	383	400	8967900	
Sylhet Area Total				2377	1075	25038481	
115	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
116	Bheramara (HVDC)	Imported power	2*500	1000	655	11741090	
117	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
118	Fariapur 50 MW Peaking PP	PDB	6*6.89	54	0	0	Reserve.
119	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
121	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	410	8933760	FGMO
122	Noapara 40 MW PP (Khanjahan Area)	QRPP	5*8.5	0	0	0	Contract Expired
123	Noapara 100 MW PP (Bangladesh Trac)	IPP	70*1.4	100	0	0	Reserve.
124	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	53	286960	High Voltage.
125	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khulna Area Total				2129	1118	20963810	
126	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
127	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	21	398300	Engine problem
128	Bhola 225 MW CCPP	PDB	2*63+1*68	194	51	1345000	Machine problem
129	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	267979	Engine problem
130	Payra 1320 MW	BCPCL	2*622	1244	370	8401100	Line O/L
131	Bhola Nuten Biddat BD LTD	IPP	220	220	220	4437955	
132	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total				2046	673	14650334	
133	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
134	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
135	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	8	18432	Low demand.
136	Bara 70 MW Peaking PP	PDB	6*8.28	71	0	0	Reserve.
137	Amrauta 50 MW PP (Sinha)	QRPP	7*7.79	50	0	0	Reserve.
138	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	8	17628	Low demand.
139	Katakhal 50 MW Pe						