

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel:- 9564667, 9551095

Month December, 2021					Day : Saturday				Date : 11.12.21				
Probable Maximum Demand : 9000 MW					Probable Maximum Generation : 13484 MW								
Water Level of Kaptai Lake at 06:00 AM					Today = 100.65 ft					Rule Curve = 105.10 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.12.21 (Yesterday)		11.12.21 (Today)		10.12.21 (Yesterday)		10.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	380	380	380				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	272	352	320	360			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	375	349	380	412	63		Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	150	150	150	150	155		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	24	25	25	25				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	16	102	102				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	18	18				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.07+1x4.73	80	80	37	49	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	30				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	30	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	29	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300				
28	Birananganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	38	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	100	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra Solar)	Solar (IPP)	1x35	35	35	27	0	30	0				
	Kanchan Purbachal Power Generation	HFO (IPP)				34	0	0	0				
Dhaka Zone Total													
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	72	72	71	71		60	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
40	Palenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	25	25	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	265	225	300	300				
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	10	10	90	90				
47	Dohazari -Kalesh 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	21				
	* Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			17	42	25	25				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	90	90				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	110	110				
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	0	0	100	100				
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	36	51	116	116				
Chattogram Zone Total													
				2442	2382	548	597	1332	1337	0	775		
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	90	90	100	44		Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	29	29	29				
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	0	123	225	225	98		Under Start up process	
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	310	360	360				
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Under maint.	
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	55	55	55				
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	140	185	195	195				
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	51	51				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	26	115	125	125				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.	
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	32	52	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	9	9	9				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+15x1.086	200	200	0	0	0	200				
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	84	113	113				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test	
**	Imphort (Tripura)	India		160	160	82	90	138	164				
Cumilla Zone Total													
				3094	3034	898	1260	1889	2125	308	621		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	110	138	180	180	64		Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	65	84	95	95				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	16	200	200				
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
82	Sutlakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0				
83	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	23	24	22	22				
Mymensingh Zone Total													
				717	622	266	284	571	519	64	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.12.21 (Yesterday)		11.12.21 (Today)		10.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	42	42	42	28	GT1 Coupling problem		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	44	44	44	44	46	GT4 reduction gear problem		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	25	50	50				
87	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	66	66				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	120	121	0	0	209	Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	81	80	85				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	191	190	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	23	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0	341	Under maint.		
97	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	70	70	70	70				
Sylhet Zone Total						2422	2377	1023	1075	1035	1040	209	415
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	360	410	355	410				
102	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	53	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Bheramara (HVDC)	India		1000	1000	584	655	668	716				
Khulna Zone Total						2133	2129	961	1118	1178	1721	0	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	21	21	21				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	41	51	65	65	143	Under maint.		
111	Bhola 95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	270	370	620	620	874	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BL)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	200	220				
Barishal Zone Total						2046	2046	516	673	1027	1197	0	1017
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	8	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	27	27				
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	42	96	100				
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	8	0	33				
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	50	50				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	120	120	134	140				
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	192	203	200	220				
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	205	183	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	46	400	400		Under Start up process		
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2179	2179	624	920	1704	1796	171	0
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	81	81				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274	Under maint.		
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	105	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total						685	605	85	185	202	194	0	359
Sub-total: Plants in operation						21435	20934	6751.0	8214	12096	13484	2013	3847
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								6546	7964	11727	13074		
(B) Plants under long term maintenance/ contract expired													
140	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0			
Gross Total						22031	20934	6751	8214	12096	13484	2013	3847
(C) Actual data of 10.12.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	8214.00	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	7964.00	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	8214.00	MW, at =	19:00 hrs	Dhaka	2687	2687	0	Mymensingh	661	661	0
04.	Minimum Generation (Generation end)	:	6056.00	MW, at =	5:00 hrs	Chattogram	1029	1029	0	Sylhet	325	325	0
05.	Day-peak Generation (Generation end)	:	6751.00	MW, at =	12:00 hrs	Khulna	974	974	0	Barishal	232	232	0
06.	Evening-peak Generation (Generation end)	:	8214.00	MW, at =	19:00 hrs	Rajshahi	802	802	0	Rangpur	574	574	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:00 hrs	Cumilla	680	680	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5515.00	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	7964	7964	0
	a) Gas limitation	:	2013	MW		13.	Fuel cost :	a) Gas = 121044401 Taka	(c) Coal = 48379490 Taka				
	d) Coal supply Limitation	:	0	MW				b) Oil = 155878826 Taka	Total = 325302717 Taka				
	b) Low water level in Kapai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	3847	MW		14.	Maximum Temperature in Dhaka was :	27.8° C					
10.	Total Energy (Generation + India Import)	:	167.91	MKWh		15.	Export through East-West interconnections :						
	By Gas = 117.360 MKWh			By Oil = 24.415 MKWh			At evening peak-hour	:	194	MW, at	19:00 hrs		
	By Coal = 10.308 MKWh			By Hydro = 1.653 MKWh			Maximum	:	-80	MW, at	8:00 hrs		
	By Solar= 0.572 MKWh						Energy	:	0.033	MKWh			
11.	Total Gas Supplied	:	866.78	MMCFD									
(D) Forecast of 11.12.21 (Today) Saturday :													
01.	Maximum Demand	:	9000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13484	MW	(Generation end)	05.	Total Generation	:	183.98	MKWh			
03.	Maximum Shortage	:	-4484	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.0° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation