

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 14-Dec-21							Page -2
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	1544745	Under maint.
	Ghorasal 78.5 MW PP(MAX)	ORPP	12*8.9	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	101	1290090	Engine problem
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	398	7929860	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	342	7898000	Engine problem
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6650000	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	270279	
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	24	313825	Engine problem
14	Narsinghā 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	421668	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	95345	Gas shortage
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	891072	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Bancoo En	IPP	3*18	54	35	876960	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	82	318240	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	536764	
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	1027342	
25	Bosila 108MW PP(PLC)	IPP	12*9.75+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	51	1172040	Engine problem
27	Maoria 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	698600	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	825800	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	52	659520	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	285	3239235	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	90	1297440	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	70	229200	High Voltage.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2020800	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	144	3150720	Engine problem
39	Spectra Solar Plant Ltd.	IPP	35	35	0	186481	
Kanchan Purbachal Power Gener				55	0	1231200	On test
Dhaka area Total				5560	2449	44775226	
40	Chattoqram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattoqram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Razcan 25 MW PP	IPP	3*8.9	25	16	70630	Engine problem
43	Teknaf 20MW PP (Solartech)Teknaf	Solartech	20	20	0	88290	
44	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	811200	
44	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	73	1680620	Low water level & #2 Under m
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	68	171454	High Voltage.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dokhazari-Kalaish 100 MW Peakin	PDB	6*17	102	51	126763	Low demand.
50	Juidah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	40	129600	High Voltage.
51	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	90	1018560	Engine problem
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	491760	
	Malancha Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	11	487200	
53	Chattoqram 108 MW PP (ECPV)	IPP	16*7	108	0	118080	High Voltage.
54	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	23641	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	16	6144764	High Voltage.
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1369742	
57	Karnaphuli Power Ltd.	IPP	110	110	110	945923	
58	Juidah unit-2 (Acom)	IPP	8*13.6	100	90	397440	High Voltage.
59	Anlima Energy Ltd.	IPP	6*21.2	116	105	1392545	High Voltage.
Chattoqram area Total				2382	795	15466212	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
61	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
62	Ashuganj TPP Unit-5	APSCL	1*150	134	90	2033654	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	160	3977000	#REF!
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	250	5131800	Gas shortage
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	250	5661000	Gas shortage
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	10	204624	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	143520	Gas shortage
66	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	8	217454	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1119722	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	142	2540872	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
70	Chandpur 150 MW CCPP	IPP	1*106+1*57	163	0	0	Under maint.
71	Chandpur 200MW (Dash energy)	IPP	0	200	34	94560	High Voltage.
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	502092	Engine problem
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	228240	
**	Impoport (Tripura)	Imported power	0	160	95	1951680	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	319800	
75	Jangalia 52 MW PP (Lakdaman)	IPP	6*9.92	52	52	668947	
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	243070	Engine problem
77	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	13	41040	Reserve.
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	109	1909320	
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	444960	33 kV feeder O/L
Chandpur 115(Doreen)				115	0	0	On test
Cumilla Area Total				3034	1360	27833355	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	103	2403840	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	496098	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11850	
85	Mymensingh 200 MW PP (United	IPP	200	200	120	799200	High Voltage.
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1606800	
87	Sutikhal 50 MW Solar PP	IPP	50	50	0	274450	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	415680	
Mymensingh Area Total				622	384	6002728	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1008000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	43	1026120	Machine problem
91	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3609327	
92	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Engine problem
93	Fenchugonj 51 MW PP (Barakata	RPP	19*2.90	51	53	1269000	
93	Fenchuganj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	248976	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	67	1477056	
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	77	1665600	Engine problem
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	On test
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	165	4065350	Gas shortage
99	Sylhet 20 MW GTTP	PDB	1*20	20	18	420000	Engine problem
	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	525648	
101	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	0	0	Under maint.
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
103	Sylhet 10MW PP (Dash)	RPP	6*1.95	10	10	253620	Line O/L
104	Bibiyana South 400 MW	PDB	400 MW	383	392	9401600	
Sylhet Area Total				2377	1066	24970297	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	708	14265454	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Fandpur 50 MW Peaking PP	PDB	6*6.89	54	0	0	Reserve.
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	9600	Reserve.
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	155	4282560	Gas shortage
	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	0	0	Reserve.
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1193280	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
	Mongla Orion 100 MW Solar PP	IPP	100	0	0	192536	On test
Khulna Area Total				2129	968	19943430	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	20	404600	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	64	1337000	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	9*67.10	95	76	780519	Engine problem
118	Payra 1320 MW	BCPCL	2*622	1244	590	19855700	Line O/L
119	Bhola Nutan Biddut BD LTD	IPP	220	220	0	2505682	TRIP
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	35	242400	Line O/L
Barisal Area Total				2046	785	15226801	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
122	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
123	Bara 70 MW Peaking PP	PDB	9*8.29	71	25	68768	Engine problem
124	Amamura 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	Reserve.
125	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	5		