

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month December, 2021				Day: Wednesday				Date: 15.12.21				
Probable Maximum Demand: 9200 MW				Probable Maximum Generation: 13042 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 100.41 ft				Today = 100.27 ft				
								Rule Curve = 104.70 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.12.21 (Yesterday)		15.12.21 (Today)		14.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	100	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	82	101	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	343	342	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	271	398	0	0	14	Gas Shortage	
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	0	0	15	300	305	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	12	24	25	25			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x8.07+1x4.73	80	80	49	51	55	55			
19	Mona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	25	25	25			
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	52	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	6	70	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	82	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	130	285	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	118	90	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300			
28	Biraniganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	132	144	162	162			
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	30	0	30	0			
	Kanchan Purbachal Power Generation	HFO (IPP)			56	57	0	0	0		On test	
Dhaka Zone Total				5717	5560	1942	2449	2407	3112	1254	660	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	72	73	73	73		40 Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
38	Razucan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	38	50	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	0	68	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	16	300	300			
45	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	10	40	100	100			
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	78	90	90	90			
47	Dohazari -Kalesh 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	80			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue	
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
	* Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			0	11	10	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	15	0	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	38	110	110	110			
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	90	100	100			
54	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	66	105	116	116			
Chattogram Zone Total				2442	2382	725	795	1320	1324	0	775	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	90	100	100			
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	10	29	29			
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	166	160	225	225			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	220	250	360	360			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	245	250	270	270			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	55	55			
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	16			
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	142	125	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	34	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	24	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x0.1+0.05+15x1.086	200	200	0	0	0	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	13	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	59	109	113	113			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0		On Test	
**	Import (Tripura)	India		160	160	87	95	138	164			
Cumilla Zone Total				3094	3034	1120	1360	1982	2226	264	163	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	97	103	120	120	99	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap.: 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	55	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	120	200	200			
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutlakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	25	24	22	22			
Mymensingh Zone Total				717	622	255	384	531	479	99	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.12.21 (Yesterday)		15.12.21 (Today)		14.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Water/Coal limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	42		27	GT1 Coupling problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	44	43	44	44		47	GT4 reduction gear problem	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	67	66	66				
90	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	77	80	80				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	165	165	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	
97	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	392	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	70	70				
Sylhet Zone Total				2422	2377	1003	1066	1199	1199	0	745		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	165	155	300	370	255		Gas Shortage	
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	6	0	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Nospara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	45	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Mongla Orion 100 MW Solar PP	Solar (IPP)				30	0	0	0				
Bheramara (HVDC)				1000	1000	660	708	675	723				
Khulna Zone Total				2133	2129	906	968	1130	1688	255	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	20	23	23				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	50	64	72	72		130	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	76	11	11				
112	Payra 1320 MW PP	Coal (BCPCL)	2x622	1244	1244	270	590	620	620		654	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	160	0	200	220				
Barisal Zone Total				2046	2046	506	785	1036	1206	0	784		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	50	96	100				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	33				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	118	125	0	95			Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	156	200	200			Gas Shortage	
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	337	335	400	400	79		Gas Shortage	
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	52	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	60	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	91	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total				2179	2179	818	1052	1368	1434	619	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	80	81	81				
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	169	169	180	180				
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	107	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total				685	605	363	362	382	374	0	85		
Sub-total: Plants in operation				21435	20934	7638.0	9221	11355	13042	2491	3212		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7369	8896	10954	12582				
(B) Plants under long term maintenance/ contract expired													
142	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energysirma)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				596	0	0	0	0	0				
Gross Total				22031	20934	7638	9221	11355	13042	2491	3212		
(C) Actual data of 14.12.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	9221.00	MW,	at = 19:30 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8896.00	MW,	at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9221.00	MW,	at = 19:30 hrs	Dhaka	3299	3299	0	Mymensingh	706	706	0
04.	Minimum Generation (Generation end)	:	5814.00	MW,	at = 5:00 hrs	Chattogram	1014	1014	0	Sylhet	336	336	0
05.	Day-peak Generation (Generation end)	:	7638.00	MW,	at = 12:00 hrs	Khulna	1055	1055	0	Barishal	260	260	0
06.	Evening-peak Generation (Generation end)	:	9221.00	MW,	at = 19:30 hrs	Rajshahi	884	884	0	Rangpur	597	597	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at = 19:30 hrs	Cumilla	745	745	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5793.00	MW,	at = 5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
a)	Gas limitation	:	2491	MW		13.	Fuel cost :	(a) Gas = 104326545 Taka	(c) Coal = 77669530 Taka				
d)	Coal supply Limitation	:	0	MW			(b) Oil = 281894689 Taka	Total = 463890763 Taka					
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	3212	MW									
10.	Total Energy (Generation + India Import)	:	180.47	MKWh		14.	Maximum Temperature in Dhaka was :	26.7° C					
	By Gas = 102.696 MKWH				By Oil = 43.046 MKWh	15.	Export through East-West interconnections :						
	By Coal = 16.004 MKWH				By Hydro = 1.681 MKWh		At evening peak-hour	:	206	MW,	at 19:30 hrs		
	By Solar= 0.826 MKWH						Maximum	:	126	MW,	at 1:00 hrs		
11.	Total Gas Supplied	:	780.67	MMCFD			Energy	:	0	MKWh			
(D) Forecast of 15.12.21 (Today) Wednesday :													
01.	Maximum Demand	:	9200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13042	MW	(Generation end)	05.	Total Generation	:	180.06	MKWh			
03.	Maximum Shortage	:	-3842	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	25.4° C				

* Captive Power: ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation