

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 15-Dec-21			Page -2				
No.	Name of the Power Stations	Producer	Installed Capacity	Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	106	2374227	
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	348	7566000	Engine problem
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6654500	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	240	1682764	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	30	86260	Engine problem
13	Keraniganj 100 MW PP (Powerpe	QRPP	8*13.45	100	24	420923	Engine problem
14	Narsingga 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	455004	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	228	4763511	Engine problem
19	Gaganagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	1127808	
20	Katohli 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Bancoo En	IPP	3*18	54	35	844920	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	16	49440	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	0	260581	High Voltage.
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	1117890	
25	Bosila 108MW PP(CLC)	IPP	12*8.75+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	47	1052160	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	716200	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	819400	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	51	590880	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	250	2905008	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	133	1350720	High Voltage.
36	Gazipur 100 MW PP	RPCL	100 MW	105	17	162000	High Voltage.
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1918080	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3857760	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	181156	
Kanchan Purbachal Power Gener				55	0	57	1324080
Dhaka area Total				5560	2355	42276772	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Razcan 25 MW PP	IPP	3*8.9	25	25	71456	
43	Teknaf 20MW PP (SolarTech)Teknaf	SolarTech Energy	20	20	0	128655	
44	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	973440	
44	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	73	1666860	Low water level & #2 Under n
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	0	16727	High Voltage.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari -Kaleish 100 MW Peakir	PDB	6*17	102	51	229803	Low demand.
50	Juidah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	0	0	High Voltage.
51	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	90	2048640	Engine problem
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	433344	Engine problem
	Malancha Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	18	491040	
53	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	0	23040	High Voltage.
54	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	23279	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	282	6330436	High Voltage.
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1370419	
57	Karnaphuli Power Ltd.	IPP	110	110	51	1042940	High Voltage.
58	Juidah unit-2 (Acom)	IPP	8*13.6	100	0	56640	High Voltage.
59	Anlima Energy Ltd.	IPP	6*21.2	116	51	1392545	High Voltage.
Chattogram area Total				2382	764	16302084	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
61	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
61	Ashuganj TPP Unit-5	APSCL	1*150	134	90	1963528	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	181	4625000	#REF!
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	180	4540800	Gas shortage
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	300	7281000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	452086	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	145440	Gas shortage
66	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	16	384727	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1191644	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	142	3112945	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	20792	Reserve.
70	Chandpur 150 MW CCPP	IPP	1*106+1*57	163	0	0	Under maint.
71	Chandpur 200MW (Dash energy)	IPP	0	200	17	62400	High Voltage.
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	493344	Engine problem
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	244980	
**	Impoport (Tripura)	Imported power	0	160	98	1619520	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	801100	
75	Jangalia 52 MW PP (Kandana)	IPP	6*9.92	52	52	597293	
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	244230	Engine problem
77	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	3420	Reserve.
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	118	1848840	
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	434880	33 kV feeder O/L
Chandpur 115(Doreen)				115	0	0	On test
Cumilla Area Total				3034	1362	30867791	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	102	2418240	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	391536	Engine problem
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11100	
85	Mymensingh 200 MW PP (Unitec	IPP	200	200	120	672000	High Voltage.
86	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	115	1953600	
87	Sutakhal 50 MW Solar PP	IPP	50	0	0	272510	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	497520	
Mymensingh Area Total				622	381	6246506	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1010000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	43	1000080	Machine problem
91	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3643200	
92	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Engine problem
93	Fenchugonj 51 MW PP (Barakata	RPP	19*2.90	51	50	1159800	
93	Fenchuganj 44MW (Energyprima	RPP	12*3.5+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	233088	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	69	1479552	
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	77	1763520	Engine problem
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	241945	On test
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	165	3890520	Gas shortage
99	Sylhet 20 MW GTTP	PDB	1*20	20	18	419000	Engine problem
	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	524856	
101	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	0	0	Under maint.
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
103	Sylhet 10MW PP (Dash)	RPP	6*1.95	10	10	252980	
104	Bibiyana South 400 MW	PDB	400 MW	383	400	9189800	
Sylhet Area Total				2377	1073	24816821	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	709	14313454	
106	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
107	Fandpur 50 MW Peaking PP	PDB	6*8.9	54	0	0	Reserve.
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	1152	Reserve.
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	265	6297984	Gas shortage
	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	0	0	Reserve.
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1033920	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
	Mongla Orion 100 MW Solar PP	IPP	100	0	0	239780	On test
Khulna Area Total				2129	1079	21886270	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	21	394100	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	65	1559000	Machine problem
117	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	52	577015	Engine problem
118	Payra 1320 MW PP (Pash)	BCPCL	2*622	1244	480	10486530	FGMO
119	Bhola Nutan Biddut BD LTD	IPP	220	220	111	2411236	Engine problem
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				2046	729	15427851	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
122	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
123	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	25	58864	Engine problem
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Engine problem
124	Ammura 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	
125	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	8	54952	Low demand.
126							