

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		17-Dec-21					Page -2
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	290	6626582	
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	100	1692590	
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
9	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	352	7782000	
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6659000	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	255	6464087	FGMO
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	0	19745	High Voltage.
15	Karaniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	25	155514	Engine problem
16	Narsinghā 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	18	401256	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirganj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	16	86112	High Voltage.
22	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	35	461520	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	8160	Reserve.
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	17	89946	High Voltage.
26	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	55	466744	
27	Bosila 108MW PP(ELC)	IPP	12*8.75+1*3.5	0	0	0	
28	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	35	792780	Engine problem
29	Maoria 33 MW PP(Summit)	SIPP, REB	4*8.73	33	16	540300	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	29	706500	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	16	87840	Transformer O/L
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summ	IPP	16*17.076	300	45	321164	High Voltage.
34	Keraniganj 300 MW PP (APR)	IPP	2*26.14	300	0	0	Reserve.
35	Bramhangaoan 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	35	139680	High Voltage.
38	Gazipur 100 MW PP	RPCL	100 MW	105	0	27600	Reserve.
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	71	679680	High Voltage.
40	Manikiganj 162MW PP(MPGL)	IPP	9*18	162	108	1058400	High Voltage.
41	Spectra Solar Plant Ltd.	IPP	35	35	0	201442	
Kanchan Purbachal Power Gener				55	56	1316520	On test
Dhaka area Total				5560	1844	36787162	
42	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razcan 25 MW PP	IPP	3*8.9	25	8	17235	Low demand.
45	Teknaf 20MW PP (SolarTech)Teknaf	SolarTech	20	20	0	136675	
46	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	36	775200	Transformer O/L
47	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	72	1188540	Low water level & #2 Under m
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	0	30109	High Voltage.
51	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
52	Dohazari-Kalash 100 MW Peakir	PDB	6*17	102	34	137043	Low Voltage
53	Juidah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	0	15600	High Voltage.
54	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	90	454080	
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	440880	Engine problem
56	Malancha, Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	25	1015200	
57	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	13	55680	High Voltage.
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	27240	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	225	3256800	High Voltage.
60	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1331863	
61	Karnaphuli Power Ltd.	IPP	110	110	17	272653	High Voltage.
62	Juidah unit-2 (Acom)	IPP	8*13.6	100	10	47040	High Voltage.
63	Anilma Energy Ltd.	IPP	6*21.2	116	17	498055	High Voltage.
Chattogram area Total				2382	620	9698893	
64	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	90	2023636	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1*142+1*175	221	184	4300000	#REF!
68	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	260	5549000	FGMO
69	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	0	110000	Under maint.
70	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	661464	Gas shortage
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1150560	Gas shortage
72	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	16	334545	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1141124	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	50	786181	High Voltage.
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
76	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
77	Chandpur 200MW (Dash energy)	IPP	0	200	17	89280	High Voltage.
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	499968	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	229140	
80	Impoport (Tripura)	Imported power	0	160	85	1684800	Low demand.
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	721700	
82	Jangalia 52 MW PP (Kandanaav)	IPP	6*9.92	52	8	131530	High Voltage.
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	241090	Engine problem
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	55	732480	High Voltage.
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	440280	33 kV feeder O/L
Chandpur 115(Doreen)				115	0	0	On test
Cumilla Area Total				3034	891	20826778	
88	RPCL 210MW CCPP	IPP	4*35+1*70	202	213	5020800	
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	357876	
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12850	
92	Mymensingh 200 MW PP (Unitec	IPP	200	200	45	134400	High Voltage.
93	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	113	936000	
94	Sutikhal 50 MW Solar PP	IPP	50	50	0	291480	
95	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	70080	
Mymensingh Area Total				622	395	6823486	
96	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1007000	Machine problem
97	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	44	1021440	Machine problem
98	Kushihara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3562281	frequency control.
99	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
100	Fenchugonj 51 MW PP (Barabaka)	RPP	19*2.90	51	53	1123800	
101	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	173520	
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	70	1197120	
104	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	76	1625280	Engine problem
105	Shahjibazar 100 MW GTTP	PDB	1*100	100	70	1808200	On test
106	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	80	1428800	ST under maint.
107	Sylhet 20 MW GTTP	PDB	1*20	20	18	415000	Engine problem
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	510432	
110	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	0	0	Under maint.
111	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
112	Sylhet 10MW PP (Dash)	RPP	6*1.95	10	10	252900	Line O/L
113	Bibiyana South 400 MW	PDB	400 MW	383	400	9037800	
Sylhet Area Total				2377	1029	23163573	
114	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
115	Bheramara (HVDC)	Imported power	2*500	1000	659	10973090	
116	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
117	Faridpur 50 MW Peaking PP	PDB	6*8.9	54	0	0	Reserve.
118	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
119	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0	Reserve.
120	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	410	8257536	Gas shortage
121	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	0	0	Reserve.
123	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	17	202080	High Voltage.
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
125	Mongla Orion 100 MW Solar PP	IPP	100	0	0	426980	On test
Khulna Area Total				2129	1086	19859666	
126	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
127	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	21	383600	Engine problem
128	Bhola 225 MW CCPP	PDB	2*63+1*68	194	91	2191268	Machine problem
129	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	211357	Gas shortage
130	Payra 1320 MW	BPCL	2*622	1244	370	1840700	Line O/L
131	Bhola Nutan Bidrut BD LTD	IPP	220	224	224	4005136	
132	United Payra Power Ltd.	IPP	6*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				2046	717	15132061	
133	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
134	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
135	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	25	44800	Low demand.
136	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
137	Ammura 50 MW PP(Sinha)	ORPP					