

Date :		23-Dec-21		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	90	2143000	Machine problem
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	150	3059100	Gas shortage
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
5	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
6	Haripur GTTP	SBU, PDB	2*32	20	0	0	Engine problem
7	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Under maint.
8	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	244	6080000	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6290850	Gas shortage
9	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3639185	Gas shortage GT-1 Under S/D
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	330882	Contract problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	11	206499	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	428292	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1067472	
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	0	0	143664	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	941400	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	82	833760	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	677525	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	762635	
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashulia)	SIPP,REB	3*3.67+4*8.73	80	30	690540	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	20	735500	Engine problem
28	Ruganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	648300	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	51	698880	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	280	4232835	High Voltage.
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	41	146320	due to payra trip.
33	Bramhangsan 100 MW PP (P. Aggreko)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*9.1	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	2092030	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	466800	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2180160	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3529440	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	115785	
Kanchan Purbachal Power Generation. Ltd.				55	0	55	482040
Dhaka area Total				5560	2347	42550894	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	25	200000	Gas shortage
41	Razzan 25 MW PP	IPP	3*8.9	25	8	37269	High Voltage.
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	93825	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	25	583680	High Voltage.
44	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	86	1821020	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	51	688218	High Voltage.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	215550	High Voltage.
50	Juldah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	10	99000	High Voltage.
51	Juldah 100 MW PP Unit-3 (Acom)	IPP	0	100	90	1110720	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	412464	
**	Malancha, Ctp. EPZ (United)		5*8.73+9*9.34	0	21	564000	
53	Chattogram 108 MW PP (ECPV)	IPP	1*67	108	54	276480	High Voltage.
54	Kaptai 7 MW. Solar PP	PDB	7.4 MW	7	0	22318	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	300	6255164	
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1310548	
57	Karnaphuli Power Ltd.	IPP	110	110	85	1419303	High Voltage.
58	Juldah unit-2 (Acom)	IPP	8*13.6	100	50	323520	High Voltage.
59	Anilima Energy Ltd.	IPP	6*21.2	116	87	811855	High Voltage.
Chattogram area Total				2382	1016	15914934	
60	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Contract Expired
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	80	2083744	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	215	4350000	#REF!
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	270	7472300	Gas shortage
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	0	0	Under maint.
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	659088	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	30	432320	Gas shortage
66	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	78	1773090	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1187108	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	127	2537527	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	25	70424	High Voltage.
70	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	140	3325940	Engine problem
71	Chandpur 200MW (Desh energy)	IPP	0	200	0	0	Reserve.
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	499212	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	247320	
**	Impoport (Tripura)	Imported power	0	160	92	1817280	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*13	33	33	745300	
75	Jangalia 52 MW PP (Lakdhan)	IPP	6*8.92	52	25	209688	High Voltage.
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	243380	Engine problem
77	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	1605240	
80	Bharat 54.5 MW	IPP	3*18.2	54	17	444960	33 kV feeder OIL.
	Chandpur 115(Doreen)	IPP	115	0	0	0	On test
Cumilla Area Total				3034	1366	29703921	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	103	2337600	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	387072	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	9300	
85	Mymensingh 200 MW PP (United)	IPP	200	200	130	1041600	High Voltage.
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	95	198000	High Voltage.
87	Sutakhal 50 MW Solar PP	IPP	50	50	0	245880	
88	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	450000	
Mymensingh Area Total				622	369	6462252	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1013000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	43	998760	Machine problem
91	Kushinara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3853963	
92	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
93	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	51	1186800	
	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	188400	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	34	651936	GT-8 under maint.
96	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.30	66	77	1700160	Engine problem
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	85	1617445	On test
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	162	4102700	Engine problem
99	Sylhet 20 MW GTTP	PDB	1*20	20	18	418000	
	Sylhet 50MW PP (EPL)	RPP	2*7.2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	492164	
101	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	253260	
104	Bibiyana South 400 MW	PDB	400 MW	383	400	9194600	
Sylhet Area Total				2377	1121	25728488	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	715	14562181	
106	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
107	Fairdipor 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	1	4352	Due to Payra trip
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	315	8423136	Gas shortage
	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Trac)	IPP	7*0.1.4	100	0	63360	Reserve.
112	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	105	1207680	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	15	27360	Line OIL.
	Mongla Orion 100 MW Solar PP	IPP	100	0	0	326160	On test
Khulna Area Total				2129	1151	24614229	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	14688	Reserve.
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	22	385700	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	69	1624000	Machine problem
117	Bhola 95 MW PP (Aggreko)	QRPP	9*11.0	85	11	269267	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	0	7085000	Tripped at 17.37
119	Bhola Nutan Bidul BD LTD	IPP	220	220	225	4398436	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	54	96000	High Voltage.
Barisal Area Total				20</			