

Date : 25-Dec-21				Page -2			
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	90	2152000	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	230	5489845	Gas shortage
4	Ghorasal 78.5 MW PP(RMA3)	QRPP	2*40	0	0	0	Contract Expired
5	Ghorashat 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Under maint.
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	245	5804000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	270	6419350	Gas shortage
9	Meghnaghat 100 MW(IEL)	QRPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3629149	Gas shortage GT-1 Under S/D
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	24	93374	High Voltage.
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	12	145844	Engine problem
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	522900	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*9.5	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*18	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	894816	
20	Kalpoti 52 MW PP (Sinha)	IPP	7*7.9	0	20	151680	
21	Kamalaghat 54 MW PP (Banco Energy)	IPP	3*18	54	35	586880	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	215520	High Voltage.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	390369	Engine problem
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	603897	Engine problem
25	Bossia 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Solar/ (Madhabdip+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	31	742920	Engine problem
27	Maona 33 MW PP (Summit)	SIPP, REB	4*8.73	33	20	658200	Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	835300	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	51	382080	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	277	1914436	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramrangsan 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1124210	
36	Gazipur 100 MW PP	RPCL	100 MW	105	48	111600	Low demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1307520	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	2855520	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	173556	
Kanchan Purbachal Power Generation				55	45	289900	
Dhaka area Total				5560	2238	37506566	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	150	3100000	Gas shortage
41	Razzan 25 MW PP	IPP	2*8.9	25	0	22237	Reserve.
42	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	115290	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	0	770400	33 kv bus S/D
44	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	86	2074500	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 100 MW PP (Baraka Station)	IPP	105 MW	105	0	0	High Voltage.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari -Kalaish 100 MW Peakir	PDB	6*17	102	51	150116	High Voltage.
50	Jullah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	20	39600	High Voltage.
51	Jullah 100 MW PP Unit-3 (Acom)	IPP	0	100	76	755520	High Voltage.
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	446544	
53	Malancha Cig. EPZ (United)	IPP	5*8.73+9*9.34	0	4	534720	
54	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	0	0	Reserve.
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	23641	
56	Arwara 300 MW PP (United)	IPP	300 MW	300	282	5582727	
57	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1369447	
58	Karnaphuli Power Ltd.	IPP	110	110	93	669926	Engine problem
59	Jullah unit-2 (Acom)	IPP	8*13.6	100	70	276480	High Voltage.
60	Anilma Energy Ltd.	IPP	6*21.2	116	55	843055	High Voltage.
Chattogram area Total				2382	960	16774203	
61	Ashuganj TPP Unit- 3	APSCL	1*150	135	0	0	Contract Expired
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	80	1933474	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*175	221	179	4541000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	280	7127600	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	220	4816000	ST preparation
65	Ashuganj 50 MW PP	APSCL	14*3.968	45	5	150984	Gas shortage
66	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	145920	Gas shortage
67	Ashuganj 195MW PP (APSCL-Unit	IPP	20*9.73+1*16	195	78	1221090	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1237512	
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	133	2562618	Engine problem
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
71	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	141	3338880	Engine problem
72	Chandpur 200MW (Desh energy)	IPP	0	200	0	0	High Voltage.
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	399816	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	154440	Engine problem
**	Imoport (Tripura)	Imported power	0	160	86	1732800	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	728990	
76	Jangalia 52 MW PP (Lakdanev)	IPP	6*9.92	52	8	46123	High Voltage.
77	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	240290	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	108	1466640	
81	Bharat 54.5 MW	IPP	3*18.2	54	17	438120	33 kV feeder O/L
	Chandpur 115(Doreen)	IPP	115	0	0	0	On test
Cumilla Area Total				3034	1459	32282207	
82	RPCL 210MW CCPP	IPP	4*35+1*70	202	112	3352320	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	396460	Engine problem
84	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
85	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	10050	
86	Mymensingh 200 MW PP (United)	IPP	200	200	70	482400	High Voltage.
87	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1912800	
88	Sutakhal 50 MW Solar PP	IPP	50	50	0	241340	
89	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	395760	
Mymensingh Area Total				622	338	6781130	
90	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	42	1010000	Machine problem
91	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	1002600	Machine problem
92	Kushthara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3372718	
93	Shajibazar 330 MW CCPP	PDB	9*110	330	0	0	Under maint.
94	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	51	1120200	
95	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	204288	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	72	1669440	
98	Shahjibazar 56MW PP (Shahjibazar)	RPP	32*2.90	86	80	1733760	
99	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	On test
100	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	137	3216150	Machine problem
101	Sylhet 20 MW GTTP	PDB	1*20	20	18	421000	
102	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	18	397228	
104	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
105	Bibiana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
106	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	252360	
107	Bibiana South 400 MW	PDB	400 MW	383	400	9018400	
Sylhet Area Total				2377	1010	23417644	
108	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	709	12459636	
109	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
110	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
111	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
112	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	8	13312	High Voltage.
113	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	210	5423040	Gas shortage
114	Noapara 40 MW PP (Khanjahan Area)	QRPP	5*8.5	0	0	0	Contract Expired
115	Noapara 100 MW PP (Bangla Trust)	IPP	70*1.4	100	0	0	Reserve.
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	73	627360	High Voltage.
117	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
118	Mongla Orion 100 MW Solar PP	IPP	100	0	0	395280	On test
Khulna Area Total				2129	1000	18918628	
119	Barisal 120 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
120	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	20	387800	Engine problem
121	Bhola 225 MW CCPP	PDB	2*63+1*68	194	90	2184504	Machine problem
122	Bhola 95 MW PP (Aggreko)	QRPP	8*11.40	95	11	272495	Gas shortage
123	Payra 1320 MW	BCPCL	2*622	1244	380	8496200	Line O/L
124	Bhola Nutan Bidul BD LTD	IPP	220	220	215	4306855	
125	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	High Voltage.
Barisal Area Total				2046	716	15647854	
126	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
127	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
128	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	25	50918	
129	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
130	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	50	0	0	Reserve.