

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month December, 2021					Day : Tuesday				Date : 28.12.21				
Probable Maximum Demand : 9800 MW					Probable Maximum Generation : 12361 MW					Rule Curve = 103.40 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 99.04 ft					Today = 98.87 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.12.21 (Yesterday)		28.12.21 (Today)		27.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			Description/ Remarks
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	110	110		Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	230	230	230	230	135	Gas Shortage		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	203	199	250	250	161	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage		
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	130	130	150	150	175	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	12	11	11				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	80	102	102	102				
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	31	34	35	35				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	16	16				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	30	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	90	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	98	98	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	270	150	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	53	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	232	300	300				
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	97	50	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Manikganj 55 MW PP (Northern	HFO (IPP)	3x19.3	55	55	35	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	79	96	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikgonj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	23	0	30	0				
	Kanchan Purbachal Power Generation	HFO (IPP)				35	55	55	55		On test		
Dhaka Zone Total					5717	5560	2000	2619	2980	3003	1783	703	
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	86	84	86	144	Low water level & maint.		
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	90	0	0	0	180	Under maint.		
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
38	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	23	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	210	300	300				
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	50	50	100	100				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	77	77	77	77				
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	70				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue		
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	12	5	10				
50	Chattogram 108 MW PP (ECPPV)	HFO (IPP)	16x7.00	108	108	24	30	90	90				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	100	100	100				
54	Chattogram 116 MW PP (Anilma Ener	HFO (IPP)	6x21.06	116	116	51	51	116	116				
Chattogram Zone Total					2442	2382	948	1012	1311	1312	144	735	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	90	90	54	Gas Shortage		
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	30	30				
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	148	158	180	200	63	Gas Shortage		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	220	285	350	350	75	Gas Shortage		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	200	150	150	200	210	Gas Shortage		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	10	10	50	Gas Shortage		
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	115	133	135	137				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	4	50	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	141	136	141	141				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	12	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	21	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
70	Jangalia 52 MW PP (Lakdanevi)	HFO (IPP)	6x8.92	52	52	21	52	52	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+40x1.015+15x1.058	200	200	0	40	0	200				
73	Feni 114 MW Power Plant(Lakdanevi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	68	115	113	113				
75	Bharat 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0		On Test		
**	Import (Tripura)	India		160	160	76	78	138	164				
Cumilla Zone Total					3094	3034	1210	1444	1904	2202	903	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	74	71	120	120	131	Gas Shortage		
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW		
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	115	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	80	177	200	200				
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
82	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0				
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	22	24	22	22				
Mymensingh Zone Total					717	622	335	404	526	474	131	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.12.21 (Yesterday)		28.12.21 (Today)		27.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	43		27	Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	43	43		48	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	72	72	72				
90	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.	09-01-22
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	77	80	80				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	121	122	200	200				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0	341		Under maint.	30-12-21
97	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	75	75				
Sylhet Zone Total						2422	2377	1010	1035	1189	1190		
100	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	105	150	150	305		Gas Shortage	
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	8	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Nospara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	90	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	73	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
** Bheramara Orion 100 MW Solar PP						Solar	55	0	10	0			
Bheramara (HVDC)						India	1000	1000	439	439	444	444	
Khulna Zone Total						2133	2129	747	757	759	1189	305	0
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	20	20	22				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	78	78	90	90	116		Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	320	620	620	924		Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	162	220	200	220				
Barishal Zone Total						2046	2046	545	649	1051	1223	0	1040
115	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	170	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	30				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25				
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	100	90	100				
122	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	33				
123	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	36				
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	121	200	200	99		Gas Shortage	
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	353	305	400	400	109		Gas Shortage	
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	90	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	80	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2179	2179	796	1196	1392	1435	809	0
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	76	111	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total						685	605	281	310	321	313	160	85
Sub-total: Plants in operation						21435	20934	7872.0	9426	11433	12341	4235	3309
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7511	8994	10886	11770				
(B) Plants under long term maintenance/ contract expired													
142	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	16	20	0	20			Running for test purpose	
143	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energysprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						595	0	16	20	0	20		
Gross Total						22031	20934	7888	9446	11433	12361	4235	3309
(C) Actual data of 27.12.21 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	9446.00	MW,	at = 19:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8994.00	MW,	at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9446.00	MW,	at = 19:00 hrs	Dhaka	3298	3298	0	Mymensingh	716	716	0
04.	Minimum Generation (Generation end)	:	5861.00	MW,	at = 5:00 hrs	Chattogram	1059	1059	0	Sylhet	334	334	0
05.	Day-peak Generation (Generation end)	:	7888.00	MW,	at = 12:00 hrs	Khulna	1088	1088	0	Barishal	248	248	0
06.	Evening-peak Generation (Generation end)	:	9446.00	MW,	at = 19:00 hrs	Rajshahi	902	902	0	Rangpur	619	619	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at = 19:00 hrs	Cumilla	730	730	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5991.00	MW,	at = 5:00 hrs					Total	8994	8994	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 102641201 Taka	(c) Coal = 64430286 Taka				
	a) Gas limitation	:	3931	MW			(b) Oil = 421240344 Taka	Total = 588311831 Taka					
	d) Coal supply Limitation	:	160	MW									
	b) Low water level in Kaptai lake	:	144	MW									
	c) Plants under shut down/ maintenance	:	3309	MW									
10.	Total Energy (Generation + India Import)	:	185.05	MKWh		14.	Maximum Temperature in Dhaka was :	27.2° C					
	By Gas = 100.860 MKWH			By Oil = 55.770 MKWH		15.	Export through East-West interconnections :						
	By Coal = 13.543 MKWH			By Hydro = 2.013 MKWH			At evening peak-hour	:	-90	MW,	at 19:00 hrs		
	By Solar= 0.908 MKWH						Maximum	:	-118	MW,	at 18:30 hrs		
11.	Total Gas Supplied	:	776.23	MMCFD			Energy	:	0.097	MKWh			
(D) Forecast of 28.12.21 (Today) Tuesday :													
01.	Maximum Demand	:	9800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12361	MW	(Generation end)	05.	Total Generation	:	191.99	MKWh			
03.	Maximum Shortage	:	-2561	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	25.3° C				

* Captive Power: ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation