

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month December, 2021					Day : Wednesday				Date : 29.12.21				
Probable Maximum Demand : 9500 MW					Probable Maximum Generation : 12253 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.87 ft				Today = 98.75 ft				
					Rule Curve = 103.30 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.12.21 (Yesterday)		29.12.21 (Today)		28.12.21 (Yesterday)		29.12.21 (Today)		Status of Machines under shut-down Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	98	95	110	110	85		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	230	230	230	230	135		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	220	201	250	250	159		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	270	270	190		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	150	150	305		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	11	11	11	11				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	31	34	35	35				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	25	16	16				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	42	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	265	281	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	50	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	112	215	300	300				
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	100	100				
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	50	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	35	35				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	25	0	30	0				
	Kanchan Purbachal Power Generation	HFO (IPP)				55	55	55	55			On test	
Dhaka Zone Total					5717	5560	2108	2552	2964	2984	1926	703	
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	80	84	86	150		Low water level & maint.	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
38	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	48	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	91	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	140	130	300	300				
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	50	100	100	100				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	77	90	77	77				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	70				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment issue	
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	3	5	5				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	80	80	90	90				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	54	54				
52	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	95	110	110	110				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100				
54	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	51	51	116	116				
Chattogram Zone Total					2442	2382	846	1054	1311	1307	150	735	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	90	90	54		Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	30	30				
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	127	178	200	220	43		Gas Shortage	
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	270	350	350	90		Gas Shortage	
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	140	140	250	250	220		Gas Shortage	
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	20	10	10	35		Gas Shortage	
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	107	130	135	137				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	50	50	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	132	130	141	141				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	33	33				
70	Jangalia 52 MW PP (Lakdanevi)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+40x1.015+15x1.08	200	200	0	0	0	200				
73	Feni 114 MW Power Plant(Lakdanevi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	78	118	113	113				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test	
**	Import (Tripura)	India		160	160	80	91	138	164				
Cumilla Zone Total					3094	3034	1286	1446	2024	2272	893	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	69	52	120	120	150		Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	16	104	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	182	185	200	200				
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
82	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0				
83	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	23	24	22	22				
Mymensingh Zone Total					717	622	350	382	526	474	150	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.12.21 (Yesterday)		29.12.21 (Today)		28.12.21 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)					
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	43		27	Under maint.				
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	32	30	43	43		60	Under maint.				
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51							
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163							
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11							
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	68	72	72	72							
90	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	09-01-22			
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	81	80	80							
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	89	88	200	200							
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18							
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10							
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24							
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	30-12-21			
97	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0							
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	411	400	400							
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	75	75							
Sylhet Zone Total						2422	2377	975	1003	1189	1190	0	758			
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	50	45	0	0		365	Gas Shortage				
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	7	0	30							
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	8	0	40							
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220							
105	Nospara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	95	50	100							
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105							
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100							
	Mongla Orion 100 MW Solar PP	Solar (IPP)				64	0	10	0							
**	Bheramara (HVDC)	India		1000	1000	438	436	440	440							
Khulna Zone Total						2133	2129	657	696	605	1035	365	0			
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110							
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	21	20	22							
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	90	90	90	90		104	Under maint.				
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11							
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	480	620	620		764	Line Overload				
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150							
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	200	220							
Barishal Zone Total						2046	2046	617	822	1051	1223	0	868			
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage				
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage				
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50							
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	150	200	200							
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	28	30	30							
119	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25							
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	100	90	100							
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	33	30	33							
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	50	50	50	50							
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	28	0	36							
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage				
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage				
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	122	118	200	200		102	Gas Shortage				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	207	210	400	400		204	Gas Shortage				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22							
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52							
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113							
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	100	113	113							
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0							
Rajshahi Zone Total						2179	2179	771	1065	1392	1435	907	0			
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling				
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200		75	Coal shortage				
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	17	0	0							
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	112	112	113	113							
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
139	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0							
Rangpur Zone Total						685	605	317	328	321	313	160	85			
Sub-total: Plants in operation						21435	20934	7927.0	9348	11383	12233	4551	3149			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7633	9004	10940	11777							
(B) Plants under long term maintenance/ contract expired																
140	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	15	20	0	20					Running for test purpose		
141	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
142	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0					Contract Expired		
143	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0							
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0					Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0					Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0					Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	0	15	20	0	20					
Gross Total						22031	20934	7942	9368	11383	12253	4551	3149			
(C) Actual data of 28.12.21 (Yesterday) Tuesday :																
01.	Max. Demand at eve. peak (Generation end)					9368.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)					9004.00	MW, at = 19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)					9368.00	MW, at = 19:00 hrs									
04.	Minimum Generation (Generation end)					5991.00	MW, at = 4:00 hrs		Dhaka	3339	3339	0	Mymensingh	735	735	0
05.	Day-peak Generation (Generation end)					7942.00	MW, at = 12:00 hrs		Chattogram	1038	1038	0	Sylhet	332	332	0
06.	Evening-peak Generation (Generation end)					9368.00	MW, at = 19:00 hrs		Khulna	1056	1056	0	Barishal	255	255	0
07.	Evening Peak Load-shed (Sub-station end)					0.00	MW, at = 19:00 hrs		Rajshahi	902	902	0	Rangpur	612	612	0
08.	Minimum Generation Forecast up to 8:00 hrs.					5943.00	MW, at = 5:00 hrs		Cumilla	735	735	0				
09.	Generation shortfall at evening peak due to :												Total	9004	9004	0
a)	Gas limitation					4241	MW		13.	Fuel cost :	(a) Gas = 89431900 Taka	(c) Coal = 67513101 Taka				
b)	Coal supply Limitation					160	MW				(b) Oil = 508580713 Taka	Total = 665525714 Taka				
c)	Low water level in Kaptai lake					150	MW									
d)	Plants under shut down/ maintenance					3149	MW		14.	Maximum Temperature in Dhaka was :	26.1° C					
10.	Total Energy (Generation + India Import)					185.49	MKWh		15.	Export through East-West interconnections :						
	By Gas = 90.573 MKWh						By Oil = 65.994 MKWh			At evening peak-hour	: -96	MW, at 19:00 hrs				
	By Coal = 14.235 MKWh						By Hydro = 1.894 MKWh			Maximum	: -166	MW, at 18:00 hrs				
	By Solar= 0.973 MKWh									Energy	: 0.138	MKWh				
11.	Total Gas Supplied					728.82	MMCFD									
(D) Forecast of 29.12.21 (Today) Wednesday :																
01.	Maximum Demand					9500	MW (Generation end)	04.	Maximum Load-shed		0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation						(Generation end)	05.	Total Generation		188.11	MKWh				
03.	Maximum Shortage					-2753	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :		23.9° C					