

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		1-Jan-22		Page -2			
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	100	2050000	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	230	5479309	Gas shortage
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Under maint.
9	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	240	5408000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	180	3981000	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	578669	
15	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	11	50107	Engine problem
16	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	426868	
17	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirganj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	961920	
22	Katpali 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
23	Kamalaghat 54 MW PP(Banco Ener	IPP	3*18	54	35	833544	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	139680	High Voltage
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	948558	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	17	431649	33 kV feeder problem
27	Bosila 108MW PP(OLC)	IPP	12*8.75+1*3.5	0	0	0	
28	Summit Power (Madhabadi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	34	810960	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	22	519200	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	664000	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	51	545246	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	280	4052180	High Voltage
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	88244	Reserve.
35	Bramhangon 100 MW PP (Aggr)	IPP	100	100	0	31384	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	37250	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	95	518260	High Voltage
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	1326284	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1858660	
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	2427840	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	187631	
Kanchan Purbachal Power Gener				55	0	55	537840
Dhaka Area Total				5560	2030	34917603	
42	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	120	2900000	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	17	86122	D/W
45	Teknaf 20MW PP (SolarTech)Teknaf SolarTech Energ	IPP	20	20	0	26055	
46	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	1183200	
47	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	86	2001400	Low water level
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	97	1553127	Engine problem
51	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under SID
52	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	137240	Engine problem
53	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	10	146880	High Voltage
54	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	1944960	Engine problem
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	477600	
56	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	41	655680	
57	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	90	1281600	Engine problem
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	26400	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	115	1215905	High Voltage
60	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1036074	
61	Karnaphuli Power Ltd.	IPP	110	110	110	2085045	
62	Juddah unit-2 (Acorn)	IPP	8*13.6	100	70	1245120	High Voltage
63	Anilma Energy Ltd.	IPP	6*21.2	116	51	1269600	Engine problem
Chattogram Area Total				2382	1673	19272008	
64	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Contract Expired
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	80	1943492	Gas shortage
67	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	166	4320000	#REF!
68	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	150	4058400	Gas shortage
69	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	330	7109000	FGMO
70	Ashuganj 50 MW PP	APSCL	14*3.968	45	5	152568	Gas shortage
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	164160	Gas shortage
72	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1078096	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	3541163	
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	83120	
76	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	137	3405640	Engine problem
77	Chandpur 200MW (Dash energy)	IPP	0	200	17	91680	High Voltage
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	452844	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	230940	
80	Impoport (Tripura)	Imported power	0	160	98	1817280	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	726400	
82	Jangalia 52 MW PP (Kakandaw)	IPP	6*9.92	52	52	506914	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	236710	Engine problem
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	15960	High Voltage
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	114	1277640	
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	444960	33 kV feeder O/L
88	Chandpur 115(Doreen)	IPP	115	0	0	0	On test
Cumilla Area Total				3034	1492	3185754	
89	RPCL 210MW CCPP	IPP	4*35+1*70	202	65	2127360	Gas shortage
90	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	284724	Engine problem
91	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	9100	
93	Mymensingh 200 MW PP (Unitec)	IPP	200	200	184	3583200	Engine problem
94	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	65	736000	High Voltage
95	Sutakhal 50 MW Solar PP	IPP	50	0	0	242410	
96	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	578880	
Mymensingh Area Total				622	358	7563674	
97	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	42	1006000	Machine problem
98	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	0	0	Machine problem
99	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3259418	
100	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
101	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	53	1278600	
102	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	8	205200	
104	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	71	1426464	
105	Shahjibazar 66MW PP (Shahjibaz	RPP	32*2.90	86	81	1863360	
106	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	On test
107	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	190	4554500	Machine problem
108	Sylhet 20 MW GTTP	PDB	1*20	20	18	419000	
109	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
110	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	487776	
111	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	10	46550	GT Synchronized at 15:20
112	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
113	Sylhet 10MW PP (Dash)	RPCL	8*1.95	10	10	246180	
114	Bibiyana South 400 MW	PDB	400 MW	383	400	9041600	
Sylhet Area Total				2377	1070	23865248	
115	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
116	Bheramara (HVDC)	Imported power	2*500	1000	719	13815272	
117	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
118	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	4	20160	
119	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	43520	Reserve.
121	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
122	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
123	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	0	0	Reserve.
124	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	852032	
125	Madhumati 105 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
126	Mongla Orion 100 MW Solar PP	IPP	100	0	0	454320	On test
Khulna Area Total				2129	828	15225304	
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
128	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	23	409500	Engine problem
129	Bhola 225 MW CCPP	PDB	2*63+1*68	194	65	1618000	Machine problem
130	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	273683	Gas shortage
131	Payra 1320 MW	BPCL	2*622	1244	420	9138700	Line O/L
132	Bhola Nutan Bidist BD LTD	IPP	220	220	220	4616727	
133	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				2046	739	16056610	
134	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
135	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
136	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	93789	
137	Bera 70 MW Peaking PP	PDB	9*8.29	71	6	10519	
138	Ammura 50 MW PP(Sinha)	ORPP					