

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month January, 2022					Day : Monday				Date : 03.01.22				
Probable Maximum Demand : 9300 MW					Probable Maximum Generation : 11967 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.16 ft				Today = 98.04 ft				
					Rule Curve = 102.62 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.01.21 (Yesterday)		03.01.22 (Today)		02.01.21 (Yesterday)		03.01.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	93	0	0	0	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	230	320	320	320	45		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	231	232	250	250	128		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	180	200	200	270		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	11	11	11				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	102	102	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	16				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	31	34	35	35				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	20	22	22				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	52	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	82	64	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	285	296	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	73	300	300				
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurastal 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	35	35	35				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	15	0	30	0				
	Kanchan Purbachal Power Generation	HFO (IPP)				17	55	55	55			On test	
Dhaka Zone Total					5717	5560	1918	2188	2724	2744	2085	598	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	84	86	144	Low water level & maint.		
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	0	0	0				
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
38	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	6	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	46	45	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	34	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	210	300	300				
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	50	100	100				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	90	90				
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	70				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue		
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	20	21				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	23	10	10				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	12	90	90				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	100	100				
54	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	51	34	51	51				
Chattogram Zone Total					2442	2382	626	997	1265	1262	144	653	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage		
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage		
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	204	211	200	220				
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	265	295	350	350				
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	140	140	150	150	220	Gas Shortage		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage		
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	150	133	150	150				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	133	135	137				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	25	33	33				
70	Jangalia 52 MW PP (Lakdanevi)	HFO (IPP)	6x8.92	52	52	8	34	52	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+40x1.015+15x1.058	200	200	0	0	0	200				
73	Feni 114 MW Power Plant(Lakdanevi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	35	75	113	113				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0		On Test		
**	Import (Tripura)	India		160	160	76	93	138	164				
Cumilla Zone Total					3094	3034	1235	1388	1893	2141	815	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	67	69	100	100	133	Gas Shortage		
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. - 8MW		
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	32	103	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	184	195	200	200				
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
82	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0				
83	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	25	24	22	22				
Mymensingh Zone Total					717	622	371	411	511	459	133	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.01.21 (Yesterday)		03.01.22 (Today)		02.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	42	42		27	GT 1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
87	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	71	66	66				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	81	80	83				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	190	191	200	200				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	987	1065	1065	1068	0	788		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	4	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	7	0	40				
104	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	105	105				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	100				
	Mongla Orion 100 MW Solar PP	Solar (IPP)				32	0	10	0				
**	Bheramara (HVDC)	India		1000	1000	662	708	684	732				
Khulna Zone Total				2133	2129	764	824	849	1327	410	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	22	24	24				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	50	64	65	65		130	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	460	620	620		784	Line Overload	
113	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BL)	Gas/HSD (IPP)	2x75+1x70	220	220	221	219	200	220				
Barishal Zone Total				2046	2046	587	776	1030	1200	0	914		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	34	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25				
120	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	100	90	100				
121	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32				
122	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	43	50	50	50				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	11	35	0	35				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	167	201	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	306	358	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	78	113	113	113				
133	Sirajgonj 5.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2179	2179	862	1168	1394	1433	601	0		
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	105	112	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Majpara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
	Energypac Power Venture Thakurgaon Ltd.					0	0	0	0				
Rangpur Zone Total				685	605	309	312	321	313	159	85		
Sub-total: Plants in operation				21435	20934	7659.0	9129	11052	11947	4347	3038		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7285	8709	10512	11383				
(B) Plants under long term maintenance/ contract expired													
140	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	27	0	20			Running for test purpose	
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				596	0	0	27	0	20				
Gross Total				22031	20934	7659	9156	11052	11967	4347	3038		
(C) Actual data of 02.01.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	9156.00	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	8709.00	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9156.00	MW, at =	19:00 hrs	Dhaka	3233	3233	0	Mymensingh	725	725	0
04.	Minimum Generation (Generation end)	:	5745.00	MW, at =	5:00 hrs	Chattogram	892	892	0	Sylhet	341	341	0
05.	Day-peak Generation (Generation end)	:	7659.00	MW, at =	12:00 hrs	Khulna	1021	1021	0	Barishal	240	240	0
06.	Evening-peak Generation (Generation end)	:	9156.00	MW, at =	19:00 hrs	Rajshahi	892	892	0	Rangpur	614	614	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:00 hrs	Cumilla	751	751	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5706.00	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	4044	MW									
	d) Coal supply Limitation	:	159	MW									
	b) Low water level in Kapai lake	:	144	MW									
	c) Plants under shut down/ maintenance	:	3038	MW									
10.	Total Energy (Generation + India Import)	:	179.11	MKWh									
	By Gas =	93.356	MKWh	By Oil =	52.583	MKWh							
	By Coal =	14.282	MKWh	By Hydro =	2.066	MKWh							
	By Solar=	0.719	MKWh										
11.	Total Gas Supplied	:	722.84	MMCFD									
(D) Forecast of 03.01.22 (Today) Monday :													
01.	Maximum Demand	:	9300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11967	MW	(Generation end)	05.	Total Generation	:	181.93	MKWh			
03.	Maximum Shortage	:	-2667	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	25.7° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation