

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2022						Day : Friday				Date : 07.01.22					
Probable Maximum Demand : 8500 MW						Probable Maximum Generation : 12210 MW									
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 97.60 ft		Today = 97.48 ft.		Rule Curve = 101.86 ft.					
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.01.22 (Yesterday)		07.01.22 (Today)		06.01.22 (Yesterday)		07.01.22 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
(A) Plants in operation:															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260		0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	100	180	180	80		Gas Shortage			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	0	0	165		Gas Shortage			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	228	250	200	250	110		Gas Shortage			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	180	180	180	270		Gas Shortage			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	11	11	11						
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102						
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19						
18	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	34	34	35	35						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	20	20	20						
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	52	51	51	51						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105						
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	100	149	149						
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35						
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	280	300	300						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149						
27	Keranigonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	197	300	300						
28	Bramhangoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	60	100	100						
29	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	50	100						
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	35	35	35						
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104						
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162						
34	Manikgonj 35MW Solar PP (Inspectra t	Solar (IPP)	1x35	35	35	29	0	30	0						
	Kanchan Purbachal Power Generation	HFO (IPP)				55	55	55	55			On test			
Dhaka Zone Total				5717	5560	1903	2492	2515	2585	2087	598				
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	78	40	40	152		Low water level & maint.			
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0						
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	25	25						
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	46	46	50	50						
41	Sikalbaha 105 MW PP (Baraka Sikalbe	HFO (IPP)	6x18.415	105	105	105	105	105	105						
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
43	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI awaiting			
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	50	100	300	300						
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	20	100	100						
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90						
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	52	70						
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		98	Environment Issue			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	20	21						
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	10	5	30						
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	79	84	90	90						
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	54	54						
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110						
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100						
54	Chattogram 116 MW PP (Anlima Energ	HFO (IPP)	6x21.06	116	116	116	104	116	116						
Chattogram Zone Total				2442	2382	870	971	1282	1301	152	833				
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage			
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage			
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54		Gas Shortage			
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	30	30	16		Gas Shortage			
57	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	0	0	150	200						
58	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	285	270	270	270						
59	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	255	220	220	220	140		Gas Shortage			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	55	55	55						
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	8	8	8	187		Gas Shortage			
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	145	150	150						
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50						
65	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	122	131	130	131						
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200						
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	21	22	22						
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	25	33	33						
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	52	52						
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9						
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	20	0	200						
73	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114						
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	85	113	113	113						
75	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test			
**	Impoport (Tripura)	India		160	160	88	95	138	163						
Cumilla Zone Total				3094	3034	1283	1402	1903	2179	661	0				
76	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	46	100	100	156		Gas Shortage			
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22											

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.01.22 (Yesterday)		07.01.22 (Today)		06.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	42		27	GT 1 Under maint.		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	51	51	51					
87	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
88	Hobiganj 11MW PP Cofidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	68	71	72	72					
90	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	81	81	81					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	190	190	190	190					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	305	330	330					
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0					
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1330	1367	1392	1392	0	447		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCPP	Gas (NWP GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	32	0	35					
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	40					
104	Khulna 225 MW CCPP	HSD (NWP GCL)	1 x 150+1x75	230	230	0	0	0	220					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	96	105	105	105					
107	Madhumati 100 MW PP	HFO (NWP GCL)	6x18.415	105	105	15	50	0	100					
	Mongla Orion 100 MW Solar PP	Solar (IPP)				71	0	11	0					
**	Bheramara (HVDC)	India		1000	1000	663	711	676	724					
Khulna Zone Total					2133	2129	849	918	842	1324	410	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	110	110					
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	20	24	24					
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	91					
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	620	620		1244	Line Overload		
113	Potuahali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	0	150					
114	Bhola 220MW CCPP (Nutan Bidyut BC	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	200	220					
Barishal Zone Total					2046	2046	373	393	1056	1226	0	1244		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50					
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200					
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	30	30					
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	25	25					
120	Chapainawabganj 100 MW Peaking PF	HFO (PDB)	12x8.924	104	104	50	100	90	100					
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32					
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	43	43					
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0					
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWP GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWP GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWP GCL)	1x141+1x79	220	220	155	173	200	200					
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	336	394	400	400					
128	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	43	43	52					
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	95	113	113					
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	90	113	113					
133	Sirajgonj 6.55 MW Solar	Solar (NWP GCL)	1x6	6	6	4	0	6	0					
Rajshahi Zone Total					2179	2179	856	1111	1378	1391	601	0		
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage		
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	112	112	113	113					
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
139	Majipara, Tatulia 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgaon Ltd.	Solar (IPP)	1 x 8	8	8	4	0	8	0					
		HFO (IPP)				0	0	0	0					
Rangpur Zone Total					685	605	316	311	321	313	160	85		
Sub-total: Plants in operation					21435	20934	8136.0	9338	11200	12170	4227	3207		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7781	8931	10750	11678					
(B) Plants under long term maintenance/ contract expired														
140	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	40	40			Running for test purpose		
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	40	40					
Gross Total					22031	20934	8136	9338	11240	12210	4227	3207		

(C) Actual data of 06.01.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	9338.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	8931.00	MW,	at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW
03.	Highest Generation (Generation end)	:	9338.00	MW,	at =	19:00 hrs						Supply MW	Load Shed MW
04.	Minimum Generation (Generation end)	:	5805.00	MW,	at =	5:00 hrs	Dhaka	3267	3267	0	Mymensingh	767	767
05.	Day-peak Generation (Generation end)	:	8136.00	MW,	at =	12:00 hrs	Chattogram	991	991	0	Sylhet	340	340
06.	Evening-peak Generation (Generation end)	:	9338.00	MW,	at =	19:00 hrs	Khulna	1083	1083	0	Barishal	247	247
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Rajshahi	900	900	0	Rangpur	581	581
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5848.00	MW,	at =	5:00 hrs	Cumilla	755	755	0			
09.	Generation shortfall at evening peak due to :	:									Total	8931	8931
	a) Gas limitation	:	3915	MW			13.	Fuel cost :	(a) Gas = 98411613 Taka	(c) Coal = 35571732 Taka			
	d) Coal supply Limitation	:	160	MW					(b) Oil = 435684512 Taka	Total = 569667856 Taka			
	b) Low water level in Kaptai lake	:	152	MW									
	c) Plants under shut down/ maintenance	:	3207	MW			14.	Maximum Temperature in Dhaka was :	26.5° C				
10.	Total Energy (Generation + India Import)	:	184.59	MKWh			15.	Export through East-West interconnections :					
	By Gas = 96.894 MKWH			By Oil = 60.980 MKWh				At evening peak-hour	:	-222	MW,	at	19:00 hrs
	By Coal = 6.964 MKWH			By Hydro = 1.984 MKWh				Maximum	:	-324	MW,	at	18:30 hrs
	By Solar= 0.851 MKWH							Energy	:	0.649	MKWh		
11.	Total Gas Supplied	:	737.42	MMCFD									

(D) Forecast of 07.01.22 (Today) Friday :													
01.	Maximum Demand	:	8500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12210	MW	(Generation end)	05.	Total Generation	:	168.02	MKWh			
03.	Maximum Shortage	:	-3710	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	26.8° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faozul Islam Shaker)
Deputy Secretary, Generation