

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Jan-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	251	5262000	
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1139	412	0	0	Gas shortage
9	Haripur 350MW CCGP(HPL)	IPP	1235+1125	360	167	4500000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	180	4422450	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	ORPP	3*17.08+1*11.3	55	55	963555	
15	Karanganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	24	371378	Engine problem
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	419292	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	0	Gas shortage
21	Sagarang 102 MW PP (Digital Po)	IPP	12*8.924	102	102	1586448	
22	Katobli 52 MW PP (Sinha)	IPP	7*7.9	0	48	600864	
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	35	876240	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	98	680160	High Voltage
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1337875	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	885183	Machine problem
27	Bosila 108MW RPCL	IPP	12*9.0	0	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.87+4*8.73	80	34	798000	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	654900	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	803900	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	51	621120	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	299	5789807	
34	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	258	726040	Low demand
35	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	50	184189	Low demand
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	302548	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	2515968	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	2319600	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.9	104	104	2094160	
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	3658690	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	196241	
Kanchan Purbachal Power Gener				55	0	55	1114920
Dhaka area Total				5560	2494	43706018	
42	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
45	Teknaf 20MW PP (SolarTech/Teknaf SolarTech Energ	IPP	20	20	0	130545	
46	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	3	92640	33 kV feeder fault
47	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	82	1909780	Low water level
48	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka St)	IPP	105 MW	105	91	1326472	Engine problem
51	Hathazari 100 MW Peaking PP	PDB	11*9.9	99	0	0	Under SID
52	Dokhazari-Kalash 100 MW Peaking	PDB	6*17	102	51	206086	Engine problem
53	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	30	56160	High Voltage
54	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2091840	Engine problem
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	478368	
56	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	4	391680	
57	Chattogram 108 MW PP (ECPV)	IPP	18*5.9	108	90	2075820	Engine problem
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	26881	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	150	1021200	High Voltage
60	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1066167	
61	Karnaphuli Power Ltd.	IPP	110	110	110	1952900	
62	Juddah unit-2 (Acorn)	IPP	8*13.6	100	100	1892160	
63	Anilima Energy Ltd.	IPP	6*21.2	116	116	2610709	
Chattogram area Total				2382	992	17383822	
64	Ashuganj TPP Unit-3	APSCCL	1*150	133	0	0	Contract Expired
65	Ashuganj TPP Unit-4	APSCCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCCL	1*150	134	80	1953510	Gas shortage
67	Ashuganj 225 MW CCGP	APSCCL	1*142+1*175	221	142	4319000	#REF!
68	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	140	3583100	Gas shortage
69	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	280	6860000	FGMO
70	Ashuganj 50 MW Peaking PP	APSCCL	14*3.968	45	5	145512	Gas shortage
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	144000	Gas shortage
72	Ashuganj 195MW PP (APSCCL-UR)	IPP	20*9.73+1*16	195	8	217454	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1235276	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	128	3375563	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	50	50	207768	
76	Chandpur 150 MW Peaking PP	IPP	1*106+1*157	163	132	3135770	Engine problem
77	Chandpur 200MW (Dash energy)	IPP	0	200	44	120480	High Voltage
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	469584	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	245700	
80	Import (Tripura)	Imported power	0	160	101	2038080	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	31	698700	
82	Jangalia 52 MW PP (Midanew)	IPP	8*6.92	52	52	831662	
83	Sumitla 25 MW PP (Summit)	SIPP, PDB	3*3.87+2*8.97	25	9	241270	Engine problem
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	200	43008	Low demand
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	21660	High Voltage
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	1750560	
87	Bhairab 54.5 MW	IPP	3*18.2	54	17	436680	33 kV feeder O/L
88	Chandpur 115(Doreen)	IPP	115			0	On test
Cumilla Area Total				3034	1457	32851437	
89	RPCL 210MW CCGP	IPP	4*35+1*70	202	50	1180800	Gas shortage
90	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	488232	
91	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11850	
93	Mymensingh 200 MW PP (Unitec)	IPP	200	200	192	4116000	Engine problem
94	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	108	1699600	Engine problem
95	Sutikhal 50 MW Solar PP	IPP	50	50	0	258660	
96	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	22	552960	
Mymensingh Area Total				622	392	8296102	
97	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	43	1011000	Machine problem
98	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	0	0	Machine problem
99	Kushara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3633790	
100	Shahbazar 330 MW PP (Midanew)	PDB	3*110	330	0	0	Under maint.
101	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	51	1061400	
102	Fenchugonj 44MW (Energyprima)	RPP	12*3.5+5*2	0	0	0	Contract Expired
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	146064	
104	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	68	1525920	
105	Shahbazar 96MW PP (Shahbaz)	RPP	32*2.90	86	78	1749120	
106	Shahbazar 100 MW GTTP	PDB	1*100	100	0	0	
107	Sylhet 225 MW GTTP	PDB	1*142+1*89	231	177	4332330	Machine problem
108	Sylhet 20 MW GTTP	PDB	1*20	20	18	420000	
109	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
110	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	475464	Engine problem
111	Biliana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	320	7242000	FGMO
112	Bibiyanah-III 400 MW CCGP	PDB	400 MW	400	0	0	Under maint.
113	Sylhet 10MW PP (Dash)	RPP	8*1.95	10	10	252000	
114	Bibiyanah South 400 MW	PDB	400 MW	383	400	9272800	
Sylhet Area Total				2377	1355	31121888	
115	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
116	Bheramara (HVDC)	Imported power	2*500	1000	471	11436363	
117	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
118	Fariapur 50 MW Peaking PP	PDB	8*6.89	50	0	0	Reserve.
119	Khulna 225 MW CCGP	NWPGCL	1*150+1*175	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	6	8960	
121	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
122	Noapara 40 MW PP (Khanjahan A)	ORPP	5*8.5	0	0	0	Contract Expired
123	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	60	179520	Low demand
124	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	105	1628160	
125	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
126	Mongla Orion 100 MW Solar PP	IPP	100	0	0	468720	On test
Khulna Area Total				2129	642	13721723	
127	Barisal 110 MW PP (Summit I)	IPP	7*17.076	110	0	0	High Voltage
128	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	25	448700	Engine problem
129	Bhola 225 MW CCGP	PDB	2*63+1*68	194	92	2215612	Machine problem
130	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	269242	Gas shortage
131	Payra 1320 MW	BPCL	2*622	1244	400	8745293	
132	Bhola Nutan Bidat BD LTD	IPP	220	220	222	4387145	
133	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				2046	750	16065899	
134	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
135	Baghabari						