

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 10-Jan-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCPP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1210	180	220	507000	
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	ORPP	240	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	0	0	Gas shortage
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1273+1139	412	0	0	Gas shortage
9	Haripur 350MW CCPP(HPL)	IPP	1235+1125	360	174	5016000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150	450	180	4422500	Gas shortage
11	Meghnaghat 100 MW(EL)	ORPP	1278.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2110+1110	305	0	0	Gas shortage
13	Madangan 102 PP(Summit)	ORPP	617	0	0	0	Contract Expired
14	Madangan-55 MW PP(Summit)	ORPP	3117.08+1111.3	55	55	659000	
15	Karanganj 100 MW PP (Powerpac)	ORPP	813.45	100	36	431569	Engine problem
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	19	388548	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	1278.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCPP	EGCB	1217+118	335	0	0	Gas shortage
21	Sagarjag 102 MW PP (Digital Po)	IPP	1278.924	102	102	1624160	
22	Katolli 52 MW PP (Sinha)	IPP	777.9	0	48	493728	
23	Kamalaghat 54 MW PP(Banco En)	IPP	318	54	35	831600	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	115	712800	High Voltage
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	1321689	
26	Nababganj 55 MW PP (Southern)	IPP	319.3	55	35	860444	Machine problem
27	Bosila 108MW RPCL	IPP	1278.75+113.5	0	0	0	
28	Summit Power (Madhabdi-Ashuli)	SIPP, REB	313.67+478.73	80	34	796560	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	478.73	33	0	654600	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	478.73	33	33	795300	
31	Gazipur 52 MW PP	RPCL	678.9	52	51	545280	
32	Tongi 80 MW GTTP	PDB	11105	105	0	0	Machine problem
33	Koinda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	300	5276616	
34	Karanganj 300 MW PP (APR)	IPP	2561.4	300	306	1185726	
35	Bramhangon 100 MW PP (Aggr)	IPP	100	100	80	312114	Low demand
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	439350	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	134	1961570	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	2241600	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.576	104	104	2042880	
40	Manikganj 162MW PP(MPGL)	IPP	918	162	162	3343690	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	164849	
Kanchan Purbachal Power Gener				55	0	55	532080
Dhaka Area Total				5560	2538	42382843	
42	Chattogram TPP-1	PDB	1210	180	0	0	Gas shortage
43	Chattogram TPP-2	PDB	1210	280	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	378.9	25	17	175883	Engine problem
45	Taksoni 20MW PP (Solartech/Teknaf Solartech Energ	IPP	20	20	0	133570	
46	Patenga 50MW PP (Baraka)	IPP	876.88	50	19	477120	33 kV feeder fault
47	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2140+3150	230	86	1943160	Low water level
48	Sikalbaha 225MW	PDB	1150+1175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka St)	IPP	105 MW	105	85	1644290	Engine problem
51	Hathazari 100 MW Peaking PP	PDB	1118.9	98	0	0	Under SID
52	Dokhazari-Kalaish 100 MW Peaking	PDB	617	102	51	220964	Engine problem
53	Juddah 100 MW Unit-1 (Acorn)	ORPP	813.45	100	70	479880	High Voltage
54	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2070720	Engine problem
55	Marabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	21	453408	
56	Malancha Cig. EP2 (United)	IPP	578.73+379.34	0	10	389760	
57	Chattogram 108 MW PP (ECPV)	IPP	1817.076	108	83	1024160	Engine problem
58	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	26039	
59	Anwara 300 MW PP (Unitec)	IPP	300 MW	300	120	2070000	High Voltage
60	Jodiac Power	IPP	318.55+113.6	54	54	1354076	
61	Karnaphuli Power Ltd.	IPP	110	110	110	2059954	
62	Juddah unit-2 (Acorn)	IPP	813.6	100	100	1800000	
63	Anilima Energy Ltd.	IPP	621.2	116	116	2783836	
Chattogram area Total				2382	1632	19058820	
64	Ashuganj TPP Unit-3	APSCCL	1150	133	0	0	Contract Expired
65	Ashuganj TPP Unit-4	APSCCL	1150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCCL	1150	134	80	1963528	Gas shortage
67	Ashuganj 225 MW CCPP	APSCCL	1142+1175	221	172	4043000	#REF!
68	Ashuganj 450 MW CCPP(North)	APSCCL	1360	360	140	3617000	Gas shortage
69	Ashuganj 450 MW CCPP(South)	APSCCL	1360	360	275	6899000	FGMO
70	Ashuganj 50 MW CCPP	IPP	1473.968	45	5	157968	Gas shortage
71	Ashuganj 55 MW PP (Precision)	RPP	154	55	5	145440	Gas shortage
72	Ashuganj 195MW PP (APSCCL-UR)	IPP	2079.73+1116	195	8	200727	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	679.34	51	51	1245616	
74	Ashuganj 150MW PP (Midland)	IPP	237.015	150	142	3405672	Engine problem
75	Titas 50 MW Peaking PP	PDB	678.92	52	33	515008	Low demand
76	Chandpur 150 MW Peaking PP	IPP	1106+1157	163	0	0	Engine problem
77	Chandpur 200MW (Dash energy)	IPP	0	200	17	279360	High Voltage
78	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	21	478296	
79	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	11	248400	
80	Import (Tripura)	Imported power	0	160	98	1986240	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	478.73	33	33	770600	
82	Jangalia 52 MW PP (Midanew)	IPP	878.92	52	16	596851	High Voltage
83	Cumilla 25 MW (Summit)	SIPP, PDB	313.67+216.97	25	9	234670	Engine problem
84	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	180	4119004	High Voltage
85	Feni Lanka Power	IPP	718.415+119.78	114	17	83220	High Voltage
86	Chowmuhani 113 MW	IPP	1279.78+213.1	113	119	1938720	
87	Bhairab 54.5 MW	IPP	318.2	54	17	430920	33 kV feeder O/L
88	Chandpur 115(Doreen)	IPP	115	0	0	0	On test
Cumilla Area Total				3034	1449	28630140	
89	RPCL 210MW CCPP	IPP	435+1170	202	50	1187520	Gas shortage
90	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	20	459432	
91	Jamalpur 95 MW PP(Powerpac)	IPP	1278.924	8	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	13	3	0	10450	
93	Mymensingh 200 MW PP (Unitec)	IPP	200	200	191	4413600	Engine problem
94	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	99	1552600	High Voltage
95	Sutikhal 50 MW Solar PP	IPP	50	0	0	226840	
96	Tangal Pali Power Gen 22 MW	IPP	46.7	22	22	537600	
Mymensingh Area Total				622	382	8391042	
97	Fenchugonj CCPP Phase-1	PDB	232+1133	70	43	1010000	Machine problem
98	Fenchugonj CCPP Phase-2	PDB	235+1135	90	0	0	Machine problem
99	Kushara 163 MW CCPP (KP)	IPP	1109+1154	163	163	3652609	
100	Shahjibazar 330 MW CCPP	PDB	3110	30	0	0	Under maint.
101	Fenchugonj 51 MW PP (Barakati)	RPP	192.90	51	51	1212600	
102	Fenchugonj 44MW (Energyprima)	RPP	123.3+512	0	0	0	Contract Expired
103	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	214224	
104	Shahjibazar GTTP Unit- 8 & 9	PDB	235	66	70	1430016	
105	Shahjibazar 96MW PP (Shahjibaz)	RPP	327.90	86	81	1909440	
106	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	
107	Sylhet 225 MW GTTP	PDB	1142+1189	231	164	3875880	Machine problem
108	Sylhet 20 MW GTTP	PDB	120	20	18	419000	
109	Sylhet 50MW PP (EPL)	RPP	272	0	0	0	Contract Expired
110	Shahjahanulla 25 MW PP	SIPP, REB	379.34	25	24	538776	
111	Biliana-II 341 MW CCPP (Summit)	IPP	1222+1119	341	290	7187000	FGMO
112	Biliana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
113	Sylhet 10MW PP (Dash)	RPP	81.95	10	10	252380	
114	Biliana South 400 MW	PDB	400 MW	383	400	9379800	
Sylhet Area Total				2377	1325	31093405	
115	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
116	Bheramara (HVDC)	Imported power	2500	1000	477	11624727	
117	Khulna 115 PP MW (KPCL-2)	ORPP	717	0	0	0	Contract Expired
118	Fariapur 50 MW Peaking PP	PDB	878.99	54	12	125280	
119	Khulna 225 MW CCPP	NWPGCL	1150+1175	230	0	0	Reserve.
120	Gopalganj 100 MW Peaking PP	PDB	1676.98	109	12	28160	
121	Bheramara 410 MW CCPP	NWPGCL	1278+1132	410	0	0	Gas shortage
122	Noapara 40 MW PP (Khanjahan A)	ORPP	578.5	0	0	0	Contract Expired
123	Noapara 100 MW PP (Bangla Tr)	IPP	701.4	100	20	97920	Low demand
124	Rupsha 105 MW PP (Orion rupsh)	IPP	618.445	105	105	1516320	
125	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
126	Mongla Orion 100 MW Solar PP	IPP	100	0	0	434160	On test
Khulna Area Total				2129	626	13826567	
127	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	High Voltage
128	Bhola 33 MW PP (Venture)	RPP	134.50	33	24	435400	Engine problem
129	Bhola 225 MW CCPP	PDB	2163+1168	194	92	2209121	Machine problem
130	Bhola 95 MW PP (Aggreko)	ORPP	961.10	95	11	270003	Gas shortage
131	Payra 1320 MW	BPCL	2122	1244	390	8567693	Line O/L
132	Bhola Nutan Bidut BD LTD	IPP	220	220	220	5264700	
133	United Payra Power Ltd.	IPP	818.5+119.5	150	0	0	Line O/L
Barisal Area Total				2046	737	16746824	
134	Baghabari 71 MW GTTP	PDB	171	71	0	0	Gas shortage
135	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage
136	Baghabari 50						