

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2022					Day : Wednesday				Date : 12.01.22			
Probable Maximum Demand : 9850 MW					Probable Maximum Generation : 11250 MW				Rule Curve = 100.90 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.88 ft.				Today = 96.73 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.01.22 (Yesterday)		12.01.22 (Today)		11.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	220	180	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	151	130	140	140	230	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	170	160	160	280	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	40	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	37	61	65	65			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	18	19	19			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.3	80	80	34	34	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	20	20	33	33			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	33	32	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105			
23	Kodda 150MW PP	HFO (BPD-RPCL)	9x17.06	149	149	136	98	149	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	288	293	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	302	200	300			
28	Branthangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	35	35	35			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	30	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55		On test	
36	Kalpoti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	44	48	51	51			
Dhaka Zone Total					5853	5696	2042	2519	2503	2573	2002	963
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	85	75	75	145		Low water level & maint.
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	15	17	25	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	19	25	25	25			
43	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	105	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	140	135	300	300			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	100	100	100			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafthazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	21	21			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	6	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	83	78	90	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
56	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total					2442	2382	946	1097	1293	1272	145	833
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	100	80	54	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	29	5	40	Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	155	163	216	170	58	Gas Shortage	
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	345	295	0	250			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	140	140	0	140	220	Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	50	5			
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	135	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	44	50	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	34	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	16	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	24	25	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9			
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.315+15x1.288	200	200	0	150	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	98	109	113	113			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0		On Test	
**	Import (Tripura)	India		160	160	97	101	138	163			
Cumilla Zone Total					2944	2899	1207	1436	1455	1843	688	0
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	50	55	55	55	152	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. - 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	115	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	180	189	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	19	0	50	0			
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total					717	622	400	396	466	414	152	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.01.22 (Yesterday)		12.01.22 (Today)		11.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	42	42		27	GT 1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
89	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	110	130	130				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	40	72	72				
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	81	81				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	145	126	125	125				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	20	24	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	330	330				
99	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	400	260	260				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total						2422	2377	1280	1156	1154	0	447	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	2	34	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	15	0	40				
106	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	60	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	67	0	16	0				
**	Bheramara (HVDC)	India		1000	1000	484	477	490	490				
Khulna Zone Total						2233	2229	673	731	721	1090	410	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	21	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	400	620	620		844	Line Overload	
116	Potashali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	222	221	200	220				
Barishal Zone Total						2046	2046	639	744	1057	1227	0	844
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
119	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	172	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	17	38	30	30				
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	100	90	100				
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	32	32				
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	50	34	50				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	169	189	150	200				
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	377	400	400				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	34	34	43				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total						2179	2179	948	1295	1285	1364	601	0
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
137	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	111	113	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
142	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Energygap Power Venture Thakurgaon Ltd							7	0	0	0			
Rangpur Zone Total						685	605	322	312	321	313	160	85
Sub-total: Plants in operation						21521	21035	8457.0	9726	10255	11250	4158	3172
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								8306	9553	10072	11049		
(B) Plants under long term maintenance/ contract expired													
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0	0			
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0	0		Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0	0			
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0	0		Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0	0		Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0	0		Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						545	0	0	0	0	0		
Gross Total						22066	21035	8457	9726	10255	11250	4158	3172
(C) Actual data of 11.01.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	9726.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9552.50	MW, at = 19:00 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	9726.00	MW, at = 19:00 hrs		3593.5	3593.5	0	Mymensingh	816	816	0	
04.	Minimum Generation (Generation end)	:	6210.00	MW, at = 5:00 hrs		1098	1098	0	Sylhet	337	337	0	
05.	Day-peak Generation (Generation end)	:	8457.00	MW, at = 12:00 hrs		1085	1085	0	Barishal	247	247	0	
06.	Evening-peak Generation (Generation end)	:	9726.00	MW, at = 19:00 hrs		967	967	0	Rangpur	614	614	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:00 hrs		795	795	0	Cumilla				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5854.00	MW, at = 5:00 hrs		Total				9553	9553	0	
09.	Generation shortfall at evening peak due to :					Fuel cost :				(c) Coal = 65198444 Taka			
	a) Gas limitation	:	3853	MW		(a) Gas = 88857037 Taka				Total = 706517449 Taka			
	d) Coal supply Limitation	:	160	MW		(b) Oil = 552461968 Taka							
	b) Low water level in Kapali lake	:	145	MW									
	c) Plants under shut down/ maintenance	:	3172	MW									
10.	Total Energy (Generation + India Import)	:	193.58	MKWh	14.	Maximum Temperature in Dhaka was : 27.8° C							
	By Gas = 89.672 MKWH		By Oil = 73.595 MKWh	15.	Export through East-West interconnections :								
	By Coal = 13.712 MKWH		By Hydro = 1.942 MKWh		At evening peak-hour		:	26	MW, at	19:00 hrs			
	By Solar= 0.874 MKWH				Maximum		:	-12	MW, at	7:00 hrs			
11.	Total Gas Supplied	:	687.89	MMCFD		Energy		:	0.031	MKWh			
(D) Forecast of 12.01.22 (Today) Wednesday :													
01.	Maximum Demand	:	9850	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	11250	MW (Generation end)	05.	Total Generation : 196.05 MKWh							
03.	Maximum Shortage	:	-1400	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 25.2° C							

* Captive Power: ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazool Islam Shaker)
Deputy Secretary, Generation