

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 12-Jan-22		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	220	4706000	
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP(MAX)	QRPP	34*3.35	108	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Under maint.
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	96	3046000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	150	3686000	Gas shortage
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	862692	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	58	724262	Engine problem
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	390096	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla	QRPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	1846800	
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	47	1063824	Engine problem
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	17	785880	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1518240	High Voltage
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1336320	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	884485	Engine problem
25	Bosila 108MW PP(PLC)	IPP	12*8.75+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	25	709440	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	17	356100	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	24	514000	Engine problem
29	Saidpur 52 MW PP	RPCL	6*8.9	52	51	802560	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit	IPP	18*17.076	300	300	5788471	
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	301	3416548	
33	Bramhangonj 100 MW PP (Aggr	IPP	100	100	100	1232153	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	1449038	
35	Kodda 149 MW PP Unit-1 (Summit	IPP	149	149	149	2551820	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2506800	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2556480	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3705120	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	82703	
Kanchan Purbachal Power Gener			IPP	55	55	998640	
Dhaka area Total				5696	2465	47520472	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Razzan 25 MW PP	IPP	3*8.9	25	17	276694	Engine problem
43	Teknaf 20MW PP (Solartechn)Teknaf	Solartechn Energ	20	20	0	0	126090
44	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	25	611040	High Voltage
45	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	79	1932800	Low water level
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St	IPP	105 MW	105	105	1569011	
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
49	Dohazari -Kalaish 100 MW Peakir	PDB	6*17	102	51	319239	Engine problem
50	Juidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	80	471120	Engine problem
51	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2043840	Engine problem
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	454656	
53	Malancha Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	9	408480	
53	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	83	2060380	Engine problem
54	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	16080	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	65	948436	High Voltage
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1358167	
57	Karnaphuli Power Ltd.	IPP	110	110	110	2080027	
58	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2107200	
59	Anilma Energy Ltd.	IPP	6*21.2	116	116	2773800	
Chattogram area Total				2382	1004	19584760	
60	Ashuganj TPP Unit- 3	APSCL	1*150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
62	Ashuganj TPP Unit- 5	APSCL	1*150	134	100	2304140	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	227	4965000	#REF!
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	1638000	
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	360	4683000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	496584	Gas shortage
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	54	865920	
66	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	45	284363	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1196932	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	132	3052727	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	52	33	444600	High Voltage
70	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
71	Chandpur 200MW (Dach energy)	IPP	0	200	34	279360	High Voltage
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	488700	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	242640	
**	Import (Tripura)	Imported power	0	160	87	1799040	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	8	4115900	Engine problem
75	Jangalia 52 MW PP (Kandanaev)	IPP	6*9.92	52	25	366326	High Voltage
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	233840	Engine problem
77	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	140	652032	High Voltage
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	54720	High Voltage
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	119	1839600	
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	444360	33 kV feeder O/L
Chandpur 115(Doreen)			IPP	115		0	On test
Cumilla Area Total				2899	1516	26758384	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	51	1369920	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	348732	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	7800	
85	Mymensingh 200 MW PP (United	IPP	200	200	182	3787200	Engine problem
86	Jamalpur 115 MW PP (United)	IPP	115 MW	115	107	1835000	High Voltage
87	Sutakhal 50 MW Solar PP	IPP	50	50	0	172870	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	22	534240	
Mymensingh Area Total				622	382	8050762	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1014000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	0	0	Under maint.
91	Kushlara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3157891	Frequency control
92	Shahjibazar 330 MW CCPP	PDB	0	3110	0	0	Under maint.
93	Fenchugonj 51 MW PP (Baraka)	RPP	19*2.90	51	51	1209600	
93	Fenchuganj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	261456	Engine problem
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	63	1622112	
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	78	1880640	
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	126	2782280	Machine problem
99	Sylhet 20 MW GTTP	PDB	1*20	20	18	414000	
100	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	517224	
101	Bibiana-II 341 MW CCPP (Summit	IPP	1*222+1*119	341	280	7272500	FGMO
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
103	Sylhet 10MW PP (EPL)	RPP	6*1.95	10	10	247800	
104	Bibiyana South 400 MW	PDB	400 MW	383	260	5988400	Gas Shortage
Sylhet Area Total				2377	1094	26367403	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	478	10930909	
106	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
107	Fardpur 50 MW Peaking PP	PDB	6*6.89	54	32	311520	Engine problem
108	Khulna 225 MW PP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	10	12800	
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
110	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	100	682560	
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1604640	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	149924	Line O/L
113	Mongla Orion 100 MW Solar PP	IPP	100	100	0	122400	On test
Khulna Area Total				2229	725	13814733	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	High Voltage
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	21	411600	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	91	2193594	Machine problem
117	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	271358	Gas shortage
118	Payra 1320 MW	BPCL	2*622	1244	430	8941000	Line O/L
119	Bhola Nutan Bidrut BD LTD	IPP	220	220	224	5044527	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				2046	777	16862079	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
122	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
123	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	590128	
123	Bera 70 MW Peaking PP	PDB	9				