

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 19-Jan-22		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	MW	KWH
1	Ghorasal Repowered CCPP-Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	200	4770000	
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	141	3586000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	170	4099000	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	740825	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	58	701349	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	348696	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
19	Gaagapur 102 MW PP (Digital Power)	IPP	12*8.924	102	96	1705392	
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	42	728736	
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	35	869760	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	1546560	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1314210	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	884104	Engine problem
25	Bosila 108MW PP(RCLC)	IPP	12*9.75+1*3.5	0	0	0	
26	Summit Power (Madhabaddi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	25	721680	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	30	762500	
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	24	495900	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	42	653280	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	5590252	
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	270	894024	
33	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	100	605463	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	98	518350	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	2136096	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2325600	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.7	104	104	2388480	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3608840	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	172450	
Kanchan Purbachal Power Gener				55	55	1115640	
Dhaka Area Total				5696	2485	43289987	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Razzan 25 MW PP	IPP	3*8.9	25	17	233470	Engine problem
42	Teknaf 20MW PP (SolarTech)Teknaf	SolarTech Energ	20	20	0	121095	
43	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	50	804000	
44	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	76	1826400	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka St)	IPP	105 MW	105	101	1391709	
48	Hathazari 100 MW Peaking PP	IPP	11*8.9	98	0	0	Under S/D
49	Dokhazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	164077	Fuel shortage
50	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	30	609480	
51	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2077440	Engine problem
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	17	378720	
	Malancha, Cig. EP2 (United)		5*8.73+3*9.34	0	2	501120	
53	Chattogram 108 MW PP (ECPV)	IPP	18*7.7	108	87	1944000	Engine problem
54	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	25561	
55	Anwara 300 MW PP (United)	IPP	300 MW	300	115	2544218	High Voltage
56	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1361457	
57	Karnaphuli Power Ltd.	IPP	110	110	110	1966280	
58	Juddah unit-2 (Acorn)	IPP	8*13.6	100	100	1773120	
59	Anilma Energy Ltd.	IPP	6*21.2	116	116	2468945	
Chattogram Area Total				2382	1616	20791692	
60	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	80	1923456	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1*142+1*175	221	144	3883000	#REF!
62	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	140	3611300	Gas shortage
63	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	300	7249000	FGMO
64	Ashuganj 50 MW PP	APSCL	14*3.968	45	5	148392	Gas shortage
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	142560	Gas shortage
66	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	8	100363	
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1200704	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	142	3173163	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	50	50	514480	
70	Chandpur 150 MW PP	PDB	1*106+1*57	163	0	0	Under maint.
71	Chandpur 200MW (Dash energy)	IPP	0	200	26	213600	High Voltage
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	502992	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	227700	
**	Impoport (Tripura)	Imported power	0	160	102	1974720	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	14	486700	Engine problem
75	Jangalia 52 MW PP (Lakhandevi)	IPP	6*9.92	52	34	384418	High Voltage
76	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	237520	Engine problem
77	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	170	246336	
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	34	132240	High Voltage
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	115	1630440	
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	439560	33 kV feeder O/L
	Chandpur 115(Doreen)	IPP	115	0	0	8840	On test
Cumilla Area Total				2899	1478	2842684	
81	RPCL 210MW CCPP	IPP	4*35+1*70	202	50	1074240	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	501120	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8600	
85	Mymensingh 200 MW PP (Unitec)	IPP	200	200	191	4176000	
86	Jamalpur 115 MW PP (Unitec)	IPP	115 MW	115	99	2469500	
87	Sutikhal 50 MW Solar PP	IPP	50	0	0	0	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	22	532800	
Mymensingh Area Total				622	384	8391010	
89	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1009000	Machine problem
90	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	624600	Machine problem
91	Kushlara 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3108763	Frequency control
92	Shahjibazar 330 MW CCPP	PDB	3*110	330	155	3788000	Gas shortage
93	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	51	1188000	
	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	210240	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	69	1426656	
96	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	78	1853760	
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Machine problem
98	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	121	2897730	Machine problem
99	Sylhet 20 MW GTTP	PDB	1*20	20	18	271000	
	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	530112	
101	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	300	7135500	FGMO
102	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
103	Sylhet 10MW PP (Dash)	RPP	6*1.95	10	10	235440	
104	Bibiyana South 400 MW	PDB	400 MW	383	401	9270400	
Sylhet Area Total				2377	1441	33549201	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	715	16757090	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	6*8.89	54	27	237120	Engine problem
108	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
109	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	13568	Reserve.
110	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tre	IPP	70*1.4	100	94	168000	
112	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	1639200	
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
	Mongla Orion 100 MW Solar PP	IPP	100	0	0	469440	On test
Khulna Area Total				2229	941	19284418	
114	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	High Voltage
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	22	424200	Engine problem
116	Bhola 225 MW CCPP	PDB	2*63+1*68	194	90	2182996	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	343302	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	410	8477400	Line O/L
119	Bhola Nutan Bidrut BD LTD	IPP	220	220	220	4872027	
120	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
Barisal Area Total				2046	753	16299925	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
122	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
123	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	673975	
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	51	567147	Engine problem
124	Ammura 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	Contact expired