

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 20-Jan-22							Page -2
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	195	4867000	
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP(MAX)	ORPP	34*3.35	108	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	138	3530000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	170	4048250	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	760905	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	63	792338	Engine problem
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	381852	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	93	1694448	Engine problem
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	48	793056	
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	35	878040	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	115	1801920	High Voltage
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1320231	
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	17	735792	Engine problem
25	Bosila 108MW PP(PLC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power (Madhabaddi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	34	785580	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	30	797700	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	26	445500	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	51	660480	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
31	Kodda 300 MW PP Unit-2 (Summit	IPP	18*17.076	300	300	5650471	
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	252	832822	
33	Bramhangonj 100 MW PP (Aggr	IPP	100	100	100	365083	
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	348647	
35	Kodda 149 MW PP Unit-1 (Summit	IPP	149	149	149	2504016	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2428800	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2310720	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3667680	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	183454	
Kanchan Purbachal Power Gener				55	55	1030320	
Dhaka area Total				5696	2437	43615165	
40	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage
41	Chattogram TPP-2						