

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2022					Day : Sunday				Date : 23.01.22			
Probable Maximum Demand : 9750 MW					Probable Maximum Generation : 12030 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.24 ft				Today = 95.09 ft			
									Rule Curve = 98.80 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.01.22 (Yesterday)		23.01.22 (Today)		22.01.22 (Yesterday)		23.01.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0				Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	200	200	200	200				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	190			Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	365			Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	108			Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0		105		Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	20			Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	187	155	180	205			Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	180	200	270			Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	412			Gas Shortage
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	210			Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	217	118		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	335			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	35	40	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	58	60	60			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	25	25	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	22	22			
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	15	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
23	Kodda 150MW PP	HFO (BPD-BRPCL)	9x17.06	149	149	115	150	150	150			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	255	281	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	158	200	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	12	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55			
36	Kalpoti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	48	48	51	51			
Dhaka Zone Total					5853	5696	2019	2430	2611	2681	2332	598
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76	154		Low water level & maint.
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	180	Gas Shortage		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	25	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	25	38	50	50			
43	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	5	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	0	100	260	260			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	30	50	100	100			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	17	17			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	15	10	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	84	89	90	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	102	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	121	116	116	116			
Chattogram Zone Total					2442	2382	618	1022	1279	1264	514	473
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	129	Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	125	100	100	100	34	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	30	30			
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	222	186	210	210			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	345	300	360	360	60	Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	180	260	265	260	100	Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	25	56	55	55			
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	26	26	26	169	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	140	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	50	48	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	163	Gas Shortage		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	12	31	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	9	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	20	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	11	43	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	9	9			
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.015+15x1.088	200	200	0	20	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	62	113	113	113			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	7	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				13	0	0	0			On Test
**	Import (Tripura)	India		160	160	84	110	138	163			
Cumilla Zone Total					2944	2899	1414	1588	2103	2225	655	0
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	67	70	70	135	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	107	108	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	193	194	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	22	22	22			
Mymensingh Zone Total					717	622	369	411	481	429	135	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.01.22 (Yesterday)		23.01.22 (Today)		22.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	43		27	GT 1 Under maint.		
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51					
89	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	130	130	130					
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	68	70	70					
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	160	160	160	170		Gas Shortage		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	81					
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage		
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage		
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	10		Gas Shortage		
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	15	16	15	15	9		Gas Shortage		
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	290	330	330					
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0					
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	265	260	260	260					
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work		
Sylhet Zone Total						2422	2377	1337	1319	1387	1389	263	27	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	29	0	35					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40					
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220					
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	60	100					
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	105	105					
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100					
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	12	0	50	0					
**	Bheramara (HVDC)	India		1000	1000	717	717	730	730					
Khulna Zone Total						2233	2229	819	846	995	1330	410	0	
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	24	25	25					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	91					
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	440	620	620	804		Line Overload		
116	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150					
117	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	216	220	220	220					
Barishal Zone Total						2046	2046	634	786	1077	1227	0	804	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
119	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	164	200	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	52	44	44					
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	98	90	100					
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	12	40	32	32					
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0	50		Under maint.		
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	117	114	120	120	106		Gas Shortage		
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	202	161	235	250	253		Gas Shortage		
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	22	22					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	25	43	52					
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0					
Rajshahi Zone Total						2129	2129	633	958	1129	1157	960	50	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage		
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage		
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode		
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	107	113	113	113					
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
143	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
144	Energypac Power Venture Thakurgonj Ltd.	HFO (IPP)				0	0	0	0					
Rangpur Zone Total						685	605	311	313	321	328	159	85	
Sub-total: Plants in operation						21471	20985	8154.0	9673	11383	12030	5428	2037	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								8033	9530	11214	11852			
(B) Plants under long term maintenance/ contract expired														
145	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
146	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired	
147	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
148	Bogra 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
149	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021	
150	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021	
151	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						595	50	0	0	0	0			
Gross Total						22066	21035	8154	9673	11383	12030	5428	2037	
(C) Actual data of 22.01.22 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	9673.00	MW,	at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9530.00	MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9673.00	MW,	at =	19:00 hrs	Dhaka	3521	3521	0	Mymensingh	886	886	0
04.	Minimum Generation (Generation end)	:	5754.00	MW,	at =	5:00 hrs	Chattogram	1035	1035	0	Sylhet	340	340	0
05.	Day-peak Generation (Generation end)	:	8154.00	MW,	at =	12:00 hrs	Khulna	1075	1075	0	Barishal	245	245	0
06.	Evening-peak Generation (Generation end)	:	9673.00	MW,	at =	19:00 hrs	Rajshahi	977	977	0	Rangpur	668	668	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:00 hrs	Cumilla	783	783	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6205.00	MW,	at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:												
a)	Gas limitation	:	5115	MW			13.	Fuel cost :	(a) Gas = 94401905 Taka	(c) Coal = 64757993 Taka				
b)	Coal supply Limitation	:	159	MW					(b) Oil = 438932510 Taka	Total = 588092408 Taka				
c)	Low water level in Kaptai lake	:	154	MW										
d)	Plants under shut down/ maintenance	:	2037	MW										
10.	Total Energy (Generation + India Import)	:	186.79	MKWh			14.	Maximum Temperature in Dhaka was :	24.3° C					
	By Gas = 91.291 MKWH						15.	Export through East-West interconnections :						
	By Coal = 13.616 MKWH							At evening peak-hour :	-230	MW,	at	19:00 hrs		
	By Solar= 0.376 MKWH							Maximum :	-332	MW,	at	20:00 hrs		
11.	Total Gas Supplied	:	754.10	MMCFD				Energy	0.725	MKWh				
(D) Forecast of 23.01.22 (Today) Sunday :														
01.	Maximum Demand	:	9750	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12030	MW	(Generation end)		05.	Total Generation	:	188.27	MKWh			
03.	Maximum Shortage	:	-2280	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	25.5° C				