

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2022					Day : Wednesday					Date : 26.01.22				
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 12076 MW					Rule Curve = 98.20 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 94.76 ft.					Today = 94.62 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.01.22 (Yesterday)		26.01.22 (Today)		25.01.22 (Yesterday)		26.01.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	144	200	200	200					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365			Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	85	77	150	150	283			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	150	150	150	150	300			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	46	59	60	60					
16	Garganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22					
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	34	34	35	35					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	16	22	22					
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	21	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	43	51	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150					
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	280	264	300	300					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	82	304	200	300					
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100					
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100					
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	142	162	162	162					
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	26	0	30	0					
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	37	55	55	55					
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	47	48	51	51					
Dhaka Zone Total				5853	5696	2142	2458	2531	2601	2440	598			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	79	79	78	78	151			Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0					
40	Rozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	25	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	3	30	50	50					
43	Sikalbaha 105 MW PP (Baraka Sikabaha	HFO (IPP)	6x18.415	105	105	105	105	105	105					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	297	260	300					
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	50	40	100	100					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98			Environment Issue	
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	14	5	5					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	74	83	90	90					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	17	54	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	85	110	110					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100					
56	Chattogram 116 MW PP (Anlima Ener	HFO (IPP)	6x21.06	116	116	109	116	116	116					
Chattogram Zone Total				2442	2382	899	1143	1278	1293	511	473			
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	100	100	100	100	34			Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	30	30					
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	193	197	210	210					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	350	300	350	350	60			Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	250	250	270	270	110			Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	54	56	55	55					
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	26	26	26	26	169			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	150	142	150	150					
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	50	48	50					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	30	48	50	80	115			Gas Shortage	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	90	85	200	200					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11					
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	8	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	9	9					
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	0	140	100	200					
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	26	116	113	113					
77	Bharoi 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0				On Test	
**	Impoport (Tripura)	India		160	160	95	113	138	163					
Cumilla Zone Total				2944	2899	1577	1810	2148	2305	617	0			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	50	50	50	50	152			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22					
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. : 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	108	115	115					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	193	200	200	200					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0					
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	22	22	22	22					
Mymensingh Zone Total				717	622	385	402	461	409	152	0			

No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.01.22 (Yesterday)		26.01.22 (Today)		25.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	30	42	43	53	40	GT 1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	130	130		Gas Shortage		
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	68	70	70				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	135	160	160	195		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	80	81				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	10		Gas Shortage	
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	341	310	330	330				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	260	260	260	260	123		ST Under maint.	
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total						2422	2377	1338	1275	1388	1390	341	40
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	29	35	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	98	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	723	725	739	739				
Khulna Zone Total						2233	2229	932	963	1024	1339	410	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	24	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	90	92	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	390	620	620	854		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CCPP (Nutan Bidyut BE)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2046	2046	637	737	1077	1227	0	854
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	50	50				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	162	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	28	53	53				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	30	100	90	100				
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	3	40	40	40				
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0	50		Under maint.	
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	118	114	120	120	106		Gas Shortage	
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	166	127	260	260	287		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	20	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	34	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total						2129	2129	606	920	1180	1184	994	50
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	103	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
	Energypac Power Venture Thakurgaon Ltd.	HFO (IPP)				19	0	0	0				
Rangpur Zone Total						685	605	326	313	321	328	159	85
Sub-total: Plants in operation						21471	20985	8842.0	10021	11408	12076	5624	2100
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						8621	9770	11122	11774				
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogura 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						595	50	0	0	0	0		
Gross Total						22066	21035	8842	10021	11408	12076	5624	2100
(C) Actual data of 25.01.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10021.00	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9770.00	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10021.00	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	6289.00	MW, at =	4:00 hrs	Dhaka	3576	3576	0	Mymensingh	888	888	0
05.	Day-peak Generation (Generation end)	:	8842.00	MW, at =	12:00 hrs	Chattogram	1108	1108	0	Sylhet	343	343	0
06.	Evening-peak Generation (Generation end)	:	10021.00	MW, at =	19:00 hrs	Khulna	1097	1097	0	Barishal	246	246	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:00 hrs	Rajshahi	1015	1015	0	Rangpur	706	706	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6434.00	MW, at =	5:00 hrs	Cumilla	791	791	0				
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	5314	MW									
	d) Coal supply Limitation	:	159	MW									
	b) Low water level in Kaptai lake	:	151	MW									
	c) Plants under shut down/ maintenance	:	2100	MW									
10.	Total Energy (Generation + India Import)	:	199.04	MKWh									
	By Gas =	88.568	MKWh	By Oil =	75.270								
	By Coal =	13.554	MKWh	By Hydro =	1.394								
	By Solar =	0.782	MKWh										
11.	Total Gas Supplied	:	741.15	MMCFD									
(D) Forecast of 26.01.22 (Today) Wednesday :													
01.	Maximum Demand	:	10200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12076	MW	(Generation end)	05.	Total Generation	:	202.59	MKWh			
03.	Maximum Shortage	:	-1876	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	25.5° C					