

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2022		Day : Thursday				Date : 27.01.22						
Probable Maximum Demand :		10200 MW		Probable Maximum Generation :		12140 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 94.62 ft		Today = 94.46 ft		Rule Curve = 98.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.01.22 (Yesterday)		27.01.22 (Today)		26.01.22 (Yesterday) Gen. shortfall for :	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	195	200	200	200			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	99	127	150	150	233	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	150	150	150	150	300	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	60	60	60			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	30	34	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	25	30			
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	17	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105			
23	Kodda 150MW PP	HFO (BPD-RPCL)	9x17.06	149	149	133	133	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	286	300	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	145	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	12	303	200	300			
28	Branhangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	50	100	100	100			
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	50	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	21	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	0	0	55	55			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	48	48	51	51			
Dhaka Zone Total				5853	5696	2004	2474	2534	2609	2390	598	
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	83	83	78	83	147	Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	30	39	50	50			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	98	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HQPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	260	300			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	20	10	100	100			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	80	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20			
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			5	7	5	25			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	83	89	90	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	54	54			
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	110	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	80	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	1024	1122	1270	1311	507	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	130	75	100	100	59	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	5	5	5	40		
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	187	124	160	180			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	330	280	320	360	80	Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	255	180	180	200	180	Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	53	5	5	6			
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	8	8	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	43	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	136	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	50	50	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	45	49	50	80	114	Gas Shortage	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	94	85	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	20	20	21			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	8	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	46	52	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	9	9			
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	99x1.4+6x1.915+15x1.099	200	200	0	100	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	105	114	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	27	118	113	113			
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				10	0	0	0			On Test
**	Impopr (Tripura)	India		160	160	105	116	138	163			
Cumilla Zone Total				2944	2899	1721	1604	1886	2123	789	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	50	61	80	100	141	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	109	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	193	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	20	0	50	0			
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	18	22	22	22			
Mymensingh Zone Total				717	622	392	414	491	459	141	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.01.22 (Yesterday)		27.01.22 (Today)		26.01.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30			GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	130	130	53		Gas Shortage	
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	69	66	66				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	136	132	160	160	198		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	81				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	178	177	180	180	54		Gas Shortage	
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	10		Gas Shortage	
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibianna-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	330	330				
99	Bibianna-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibianna South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	45	133	400	400		250	ST Under maint.	
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1039	1149	1512	1513	344	40	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	35	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	10	20	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	90	90	90				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	54	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	725	728	739	739				
Khulna Zone Total					2233	2229	898	873	1009	1324	410	0	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	8	26	25	26				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	92	91	92				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	330	420	620	620		824	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2046	2046	660	769	1077	1229	0	824	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	43	43	43	43				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	10	161	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	50	50	50				
122	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.524	104	104	50	99	90	100				
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	19	40	40	40				
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0		50	Under maint.	
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	120	118	130	150	102		Gas Shortage	
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	207	162	300	300	252		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total					2129	2129	746	981	1220	1244	955	50	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	108	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energyrac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
Rangpur Zone Total					685	605	311	313	321	328	159	85	
Sub-total: Plants in operation					21471	20985	8795.0	9699	11320	12140	5695	2070	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					8605	9490	11076	11878					
(B) Plants under long term maintenance/contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	108irganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					595	50	0	0	0	0	0	0	
Gross Total					22066	21035	8795	9699	11320	12140	5695	2070	
(C) Actual data of 26.01.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	: 9699.00 MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 9490.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 9699.00 MW, at = 19:30 hrs	Dhaka	3434	3434	0	Mymensingh	853	853	0			
04.	Minimum Generation (Generation end)	: 6434.00 MW, at = 5:00 hrs	Chattoagram	1101	1101	0	Sylhet	332	332	0			
05.	Day-peak Generation (Generation end)	: 8795.00 MW, at = 12:00 hrs	Khulna	1042	1042	0	Barishal	251	251	0			
06.	Evening-peak Generation (Generation end)	: 9699.00 MW, at = 19:30 hrs	Rajshahi	1004	1004	0	Rangpur	697	697	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs	Cumilla	776	776	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6218.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas Limitation	: 5389 MW	13.	Fuel cost :		(a) Gas = 89209192 Taka	(c) Coal = 65959162 Taka						
d)	Coal supply Limitation	: 159 MW		(b) Oil = 612047615 Taka		Total = 767215969 Taka							
b)	Low water level in Kaptai lake	: 147 MW											
c)	Plants under shut down/ maintenance	: 2070 MW	14.	Maximum Temperature in Dhaka was :		26.2° C							
10.	Total Energy (Generation + India Import)	: 199.01 MKWh	15.	Export through East-West interconnections :									
	By Gas = 83.523 MKWh	By Oil = 79.453 MKWh		At evening peak-hour		: -244 MW, at 19:30 hrs							
	By Coal = 13.684 MKWh	By Hydro = 1.942 MKWh		Maximum		: -258 MW, at 20:00 hrs							
	By Solar= 0.670 MKWh			Energy		: 0.6785 MKWh							
11.	Total Gas Supplied	: 726.70 MMCFD											
(D) Forecast of 27.01.22 (Today) Thursday :													
01.	Maximum Demand	: 10200 MW (Generation end)	04.	Maximum Load-shed		: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 12140 MW (Generation end)	05.	Total Generation		: 209.29 MKWh							
03.	Maximum Shortage	: -1940 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :		23.1° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation