

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 29-Jan-22							Page -2
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
				Unit No. X Capacity	MW	MW	KWH
1	Ghorasal Repowered CCPP-Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	220	5274000	
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorashal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
9	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	321	6724000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	210	4905750	Gas shortage
11	Meghnaghat 100 MW(IEEL)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	40	471226	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	56	387768	Engine problem
16	Narsingh 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	432468	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	975312	
22	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	48	1155744	
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	35	786960	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	115	753600	High Voltage
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	905438	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	728030	Engine problem
27	Bosila 108MW PP(ELC)	IPP	12*9.75+1*3.5	0	0	0	
28	Summit Power,(Madhabdidi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	25	702780	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	20	368100	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	18	269400	Engine problem
31	Gazpur 52 MW PP	RPCL	6*8.9	52	51	361440	
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	253	4323162	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	175	500042	Low demand
35	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	80	252700	Low demand
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	70	212241	Low demand
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	1901952	
38	Gazpur 100 MW PP	RPCL	100 MW	105	105	2185200	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2065920	
40	Manikgonj 162MW PP(MPLG)	IPP	9*18	162	144	2478240	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	157897	
42	Kanchan Purbachal Power Gener	IPP	55	55	55	1132560	
Dhaka area Total				5696	2508	40411930	
43	Chattogram TPP-1	PDB	1*210	180	0	0	Under maint.
44	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
45	Razzan 25 MW PP	IPP	3*8.9	25	17	82310	Engine problem
46	Teknaf 20MW PP (Solartechnology)	Solartechnology	20	20	0	99495	
47	Patenga 50MW PP (Baraka)	IPP	6*6.88	50	40	972960	Engine problem
48	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	82	1999145	Low water level
49	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sil	IPP	105 MW	105	68	685815	High Voltage
52	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
53	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	227045	Fuel shortage
54	Juddah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	10	25560	High Voltage
55	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	1129920	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	16	389088	Engine problem
57	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	17	512640	
58	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	88	1695360	Engine problem
59	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	27961	
60	Anwara 300 MW PP (United)	IPP	300 MW	300	300	4772291	
61	Jodiac Power	IPP	3*18.55+1*3.6	54	17	189085	High Voltage
62	Karnaphuli Power Ltd.	IPP	110	110	34	289380	High Voltage
63	Juddah unit-2 (Acorn)	IPP	8*13.6	100	60	157440	High Voltage
64	Anilma Energy Ltd.	IPP	6*21.2	116	116	2634545	
65	Chattogram area Total			2382	1606	15890940	
66	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
68	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	144	3983000	#REF!
70	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	220	5347900	Gas shortage
71	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	6896000	FGMO
72	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	138528	Gas shortage
73	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	152160	Gas shortage
74	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1126944	
76	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	147	2544218	
77	Titas 50 MW Peaking PP	PDB	6*6.92	52	50	528784	
78	Chandpur 150 MW CCPP	IPP	1*106+1*57	163	80	1443650	ST Under maint.
79	Chandpur 200MW (Dash energy)	IPP	0	200	83	701280	High Voltage
80	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	369432	
81	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	223740	
82	Impoport (Tripura)	Imported power	0	160	113	2157120	
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	8	417100	Engine problem
84	Jangalia 52 MW PP (Kandana)	IPP	6*9.92	52	52	982330	
85	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	216110	Engine problem
86	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	70	117504	Low demand
87	Feni Lanka Power	IPP	7*18.415+1*9.78	114	88	437760	High Voltage
88	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	108	999600	33 kV feeder O/L
89	Bhairab 54.5 MW	IPP	3*18.2	54	17	445680	On test
90	Chandpur 115(Doreen)	IPP	115	0	0	104640	
91	Cumilla Area Total			2891	1584	29534207	
92	RPCL 210MW CCPP	IPP	4*35+1*70	202	110	2586240	Gas shortage
93	Tangail 22 MW PP(Powerpac)	SIPP, PDB	6*2.90	22	22	391788	
94	Jamalpur 95 MW PP(Doreen)	IPP	12*8.924	8	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11900	
96	Mymensingh 200 MW PP (United)	IPP	200	200	194	3955200	
97	Jamalpur 115 MW PP (United)	IPP	115 MW	115	99	1639200	Engine problem
98	Sutikhal 50 MW Solar PP	IPP	50	50	0	291520	
99	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	22	522000	
100	Mymensingh Area Total			622	447	9397848	
101	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	30	715000	Machine problem
102	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	624080	Machine problem
103	Kushlara 163 MW CCPP (KP)	IPP	1*109+1*54	163	110	2873536	Gas shortage
104	Shahjibazar 330 MW CCPP	PDB	3*110	330	134	3229000	Gas shortage
105	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	47	996900	
106	Fenchugonj 44MW (Energyprima)	RPP	12*3.5+5*2	0	0	0	Contract Expired
107	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	220224	
108	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	40	1273248	
109	Shahjibazar 96MW PP (Shahjibaz)	RPP	32*2.90	86	81	1682880	
110	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Machine problem
111	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	177	4059910	Machine problem
112	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
113	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
114	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	506520	Engine problem
115	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	290	7610500	FGMO
116	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
117	Sylhet 10MW PP (D)	RPP	6*1.95	10	0	0	Gas shortage
118	Bibiyana South 400 MW	PDB	400 MW	383	400	9091000	
119	Sylhet Area Total			2377	1366	32882498	
120	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
121	Bheramara (HVDC)	Imported power	2*500	1000	734	16911272	
122	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
123	Faridpur 50 MW Peaking PP	PDB	6*6.89	54	18	76800	
124	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
125	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	211840	Reserve.
126	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
127	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
128	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	89	211200	Engine problem
129	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	91	1473120	Engine problem
130	Madhumati 105 MW PP	RPP	100 MW	105	0	0	Line O/L
131	Mongla Orion 100 MW Solar PP	IPP	100	0	0	513390	On test
132	Khulna Area Total			2229	932	19397592	
133	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
134	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	24	424200	Engine problem
135	Bhola 225 MW CCPP	PDB	2*63+1*68	194	91	2222394	Machine problem
136	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	273424	Gas shortage
137	Payra 1320 MW	BPCL	2*622	1244	390	8431300	Line O/L
138	Bhola Nutan Biddut BD LTD	IPP	220	220	220	4734027	
139	United Payra Power Ltd.	IPP	6*18.5+1*9.5	150	0	0	Line O/L
140	Barisal Area Total			2046	736	16085345	
141	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
142	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
143	Baghabari 5						

145	Rangpur 113 MW PP (Confidence)	IPP	113 MW	113	107	1700515	Engine problem
146	Sympa Solar Power 8MW	IPP	8 MW	8	0	30478	
	Energypac Power Venture Thakun	IPP	115	0	0	85440	On test
Rangpur Area Total				605	306	6675833	
Total				21035	9869	188111154	
Eastern Grid Total				13976	6911	128116523	
Western Grid Total				7059	2958	59994631	
National Grid Total				21035	9869	188111154	