

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2022					Day : Thursday				Date : 03.02.22					
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 12204 MW									
Water Level of Kaptai Lake at 06:00 AM					Today = 93.45 ft.				Rule Curve = 96.72 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 93.45 ft.		03.02.22 (Today)		02.02.22 (Yesterday)		Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening	Day	Evening				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	220	220					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365			Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	243	252	300	300	108			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	220	220	220	230			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage	
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40					
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	59	60	60					
16	Gazipour 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102					
17	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22					
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	34	34	35	35					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x7.71	33	33	20	25	20	20					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x7.71	33	33	33	13	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150					
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	54	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	265	275	300	300					
26	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	221	200	300					
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100					
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100					
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	162	160	160					
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0					
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	37	43	55	55					
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	42	47	51	51					
Dhaka Zone Total				5853	5696	2189	2639	2771	2841	2195	598			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
39	Kapla 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	40	40	40					
43	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	68	105	105	105					
44	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	300	300	260	300					
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	20	100	100					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	70	90	90					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
50	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98			Environment Issue	
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20					
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	13	10	20					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	89	89	97	97					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	51	110	110					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	40	50	100	100					
57	Chattogram 116 MW PP (Anlima Eren)	HFO (IPP)	6x21.06	116	116	116	116	116	116					
Chattogram Zone Total				2442	2382	887	1003	1240	1266	544	473			
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5	40			Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	184	202	220	220					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	345	275	360	360	85			Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	150	150	235	260	210			Gas Shortage	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	10	5	5	45			Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	26	26	8	8	169			Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	140	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	45	50	50	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	85	122	135	135	41			Gas Shortage	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	100	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	21	21					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	0	0	100	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	51	52	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	108	113	113					
78	Bharoi 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	Chandpur 115(Doreen)	HFO (IPP)				104	0	0	0				On Test	
80	Import (Tripura)	India		160	160	94	108	138	134					
Cumilla Zone Total				2944	2899	1445	1530	2019	2140	853	0			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	83	101	110	110	101			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. : 8MW	
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	109	109	110	110					
85	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	194	193	200	200					
86	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
87	Sultakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0					
88	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	22	22	22					
Myensingh Zone Total				717	622	465	447	516	464	101	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.02.22 (Yesterday)		03.02.22 (Today)		02.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	53	194	GT-1 Under maint.		
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51					
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110			Gas Shortage		
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	69	70	70					
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	138	136	135	135			Gas Shortage		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	78	75	80					
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage		
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage		
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage		
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	330	330					
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0					
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work		
Sylhet Zone Total						2422	2377	1376	1430	1466	1471	330	40	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	4	0	35					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40					
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	85	80	100					
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	105	105					
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100					
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	78	0	50	0					
**	Bheramara (HVDC)	India		1000	1000	731	731	751	751					
Khulna Zone Total						2233	2229	899	910	1036	1351	410	0	
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	21	20	24					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	90	90	92					
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	83	87	76	76					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	430	560	620	620		684	Line Overload		
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150					
117	Bhola 220MW CCPP (Nutan Bidyut BE	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0					
Barishal Zone Total						2046	2046	619	758	916	1072	0	684	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34					
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	200	200					
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	48	50	50					
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	49	100	90	100					
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	40					
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31					
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	126	126	130	130	94		Gas Shortage		
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	268	226	325	325	188		Gas Shortage		
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	22	22					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	91	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2129	2129	736	982	1226	1271	883	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage		
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode		
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	100	113	113	113					
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
141	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
	Energypac Power Venture Thakurgaon Ltd.	HFO (IPP)				14	0	0	0					
Rangpur Zone Total						685	605	318	312	321	328	160	85	
Sub-total: Plants in operation						21471	20985	8934.0	10011	11511	12204	5476	1880	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								8772	9830	11302	11983			
(B) Plants under long term maintenance/ contract expired														
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Bogura 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired							595	50	0	0	0			
Gross Total						22066	21035	8934	10011	11511	12204	5476	1880	
(C) Actual data of 02.02.22 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	10011.00	MW, at = 19:00 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9830.00	MW, at = 19:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10011.00	MW, at = 19:00 hrs			MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6103.00	MW, at = 5:00 hrs		Dhaka	3590	3590	0	Mymensingh	884	884	0	
05.	Day-peak Generation (Generation end)	:	8934.00	MW, at = 12:00 hrs		Chattogram	1098	1098	0	Sylhet	336	336	0	
06.	Evening-peak Generation (Generation end)	:	10011.00	MW, at = 19:00 hrs		Khulna	1139	1139	0	Barishal	237	237	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:00 hrs		Rajshahi	1027	1027	0	Rangpur	734	734	0	
08.	Minimum Generation Forecast up to 8:00 hrs	:	6186.00	MW, at = 5:00 hrs		Cumilla	785	785	0					
09.	Generation shortfall at evening peak due to :	:								Total	9830	9830	0	
a)	Gas limitation	:	5132	MW		13.	Fuel cost :	(a) Gas = 97714057 Taka	(c) Coal = 76809186 Taka					
d)	Coal supply Limitation	:	160	MW				(b) Oil = 482376632 Taka	Total = 656899875 Taka					
b)	Low water level in Kaptai lake	:	184	MW										
c)	Plants under shut down/ maintenance	:	1880	MW		14.	Maximum Temperature in Dhaka was : 27.7° C							
10.	Total Energy (Generation + India Import)	:	199.83	MKWh		15.	Export through East-West interconnections :							
	By Gas = 93.977 MKWh			By Oil = 67.421 MKWh		At evening peak-hour	:	-325	MW, at 19:00 hrs					
	By Coal = 16.352 MKWh			By Hydro = 1.105 MKWh		Maximum	:	-337	MW, at 8:00 hrs					
	By Solar= 1.041 MKWh					Energy	:	0.873	MKWh					
11.	Total Gas Supplied	:	738.70	MMCFD										
(D) Forecast of 03.02.22 (Today) Thursday :														
01.	Maximum Demand	:	10200	MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	12204	MW (Generation end)		05.	Total Generation : 203.60 MKWh							
03.	Maximum Shortage	:	-2004	MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 26.7° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation