

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month February, 2022					Day : Saturday				Date : 05.02.22				
Probable Maximum Demand : 9100 MW					Probable Maximum Generation : 12484 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 93.33 ft		Today = 93.21 ft		Rule Curve = 96.44 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.02.22 (Yesterday)		05.02.22 (Today)		04.02.22 (Yesterday)		05.02.22 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	152	0	0				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	297	333	330	330	27	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	200	225	225	250	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage		
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	40	40				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	60	60				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	64	102	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	16	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x3.73	80	80	31	34	35	35				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	18	16	20	20				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	32	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	105	105				
23	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	0	0	150	150				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	150	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	126	200	300				
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	0	0	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	160	160				
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	5	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	35	55	55	55				
36	Kalpoti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	41	46	51	51				
Dhaka Zone Total					5853	5696	1085	1705	2586	2656	2134	598	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	0	17	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	39	40	40				
43	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	17	34	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	150	230	260	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	20				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			26	37	10	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	95	71	97	97				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	0	100	100				
56	Chattogram 116 MW PP (Arima Ener	HFO (IPP)	6x21.06	116	116	114	116	116	116				
Chattogram Zone Total					2442	2382	608	681	1240	1266	544	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	29	30	30	16		Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	185	226	220	220				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	265	320	360	360	40		Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	150	0	150	260	360		Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	40	40	50		Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	73	112	112	122		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	120	150	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	130	137	135	135				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	7	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	34	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+40x1.015+15x1.088	200	200	0	0	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	17	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	65	113	113				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test	
**	Impoport (Tripura)	India		160	160	70	72	138	134				
Cumilla Zone Total					2944	2899	1098	1279	2098	2304	851	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	110	111	165	165	91		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. - 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	35	110	110				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	38	100	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
84	Sutakbahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0				
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	18	22	22	22				
Mymensingh Zone Total					717	622	202	290	571	519	91	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.02.22 (Yesterday)		05.02.22 (Today)		04.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	20	30	30		50	GT 1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	0	30	30			GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	28	48	51	51				
89	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	69	69	70	70				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	136	132	135	135	198		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	75	80			Gas Shortage	
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	330	330				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	330	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total						2422	2377	1287	1308	1466	1471	334	50
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	70	105	105				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	28	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	737	641	752	752				
Khulna Zone Total						2233	2229	800	711	1037	1352	410	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	11	8	20	24				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	79	90	92				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	0	76	76				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	0	620	620	1244		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	200	210	220	220				
Barishal Zone Total						2046	2046	613	297	1136	1292	0	1244
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
119	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	34	34				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	50	50				
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	100	90	100				
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	31				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	138	138	140	140	82		Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	253	333	340	340	81		Gas Shortage	
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	52	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	70	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	50	113	113				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total						2129	2129	452	770	1251	1296	764	0
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode	
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	109	113	113				
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
143	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
144	Energypac Power Venture Thakurgonj Ltd.	HFO (IPP)				0	0	0	0				
Rangpur Zone Total						685	605	199	309	321	328	159	85
Sub-total: Plants in operation						21471	20985	6344.0	7350	11706	12484	5287	2450
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6281	7277	11589	12360				
(B) Plants under long term maintenance/ contract expired													
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
146	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
147	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
148	Bogra 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
149	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
150	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
151	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						595	50	0	0	0	0		
Gross Total						22066	21035	6344	7350	11706	12484	5287	2450
(C) Actual data of 04.02.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	7350.00	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	7277.00	MW, at = 19:30 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	7350.00	MW, at = 19:30 hrs		Dhaka	2653	2653	0	Mymensingh	626	626	0	
04.	Minimum Generation (Generation end)	5908.00	MW, at = 6:00 hrs		Chattogram	959	959	0	Sylhet	271	271	0	
05.	Day-peak Generation (Generation end)	6344.00	MW, at = 09:00 hrs		Khulna	862	862	0	Barishal	228	228	0	
06.	Evening-peak Generation (Generation end)	7350.00	MW, at = 19:30 hrs		Rajshahi	746	746	0	Rangpur	358	358	0	
07.	Evening Peak Load-shed (Sub-station end)	0.00	MW, at = 19:30 hrs		Cumilla	574	574	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	4663.00	MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	4944	MW		13.	Fuel cost :	(a) Gas = 93481236 Taka	(c) Coal = 50796399 Taka					
b)	Coal supply Limitation	159	MW				(b) Oil = 168788028 Taka	Total = 313065663 Taka					
c)	Low water level in Kaptai lake	184	MW										
d)	Plants under shut down/ maintenance	2450	MW										
10.	Total Energy (Generation + India Import)	150.50	MKWh	14.	Maximum Temperature in Dhaka was : 25.7° C								
	By Gas = 92.659 MKWH		By Oil = 27.639 MKWh	15.	Export through East-West interconnections :								
	By Coal = 10.431 MKWH		By Hydro = 1.056 MKWh		At evening peak-hour : -336 MW, at 19:30 hrs								
	By Solar= 0.462 MKWH				Maximum : -439 MW, at 18:30 hrs								
11.	Total Gas Supplied	692.95	MMCFD		Energy : 0.921 MKWh								
(D) Forecast of 05.02.22 (Today) Saturday :													
01.	Maximum Demand	9100	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	12484	MW (Generation end)	05.	Total Generation : 186.34 MKWh								
03.	Maximum Shortage	-3384	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 23.7° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation